

# **Pyrogel XT/XTF Insulation**

**TECHNICAL GUIDE**



## Contents

<b>Thermal Conductivity</b>	<b>3</b>
ASTM C 177 – Thermal Conductivity via Guarded Hot-Plate Apparatus	
<b>Non-Combustibility and Fire Performance</b>	<b>3</b>
ASTM E 84 – Surface Burning Characteristics	
ASTM E 1354 – Cone Calorimetry	
BS EN 13501-1: 2007 – Reaction to Fire Performance	
BSS 7239 – Toxicity of Combustion Products	
ISO 1182:1990 – Test for Non-Combustibility	
UL 1709 – Rapid Rise Fire Tests of Protection Materials for Structural Steel (Pyrogel XTF only)	
<b>Dimensional Stability</b>	<b>5</b>
ASTM C 356 – Linear Shrinkage under Soaking Heat	
ASTM C 411 (Flat Plate) – Hot Surface Performance	
ASTM C 411/C 447 (Pipe Configuration) – Hot Surface Performance/ Estimation of Maximum Use Temperature	
<b>Water Resistance/Permeability</b>	<b>6</b>
ASTM C 1104 – Water Vapor Sorption	
ASTM C 1511 – Determination of Water Retention	
ASTM C 1559 – Water Wicking	
<b>Other</b>	<b>7</b>
ASTM C 165 – Compressive Strength	
ASTM C 592-04 – Heat and Vibration Aging	
ASTM C 795 – Corrosion Test	
ASTM D 5304 – Determination of Tensile Strength	
<b>Appendix A</b>	<b>8</b>
ASTM C 177 – THERMAL CONDUCTIVITY VIA GUARDED HOT-PLATE APPARATUS	
<b>Appendix B</b>	<b>18</b>
ASTM E 84 – SURFACE BURNING CHARACTERISTICS	
<b>Appendix C</b>	<b>23</b>
ASTM E 1354 – CONE CALORIMETRY	
<b>Appendix D</b>	<b>25</b>
ISO 1182:1990 – TEST FOR NON-COMBUSTIBILITY	
<b>Appendix E</b>	<b>30</b>
BSS 7239 – TOXICITY OF COMBUSTION PRODUCTS	
<b>Appendix F</b>	<b>36</b>
UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL	
<b>Appendix G</b>	<b>131</b>
ASTM C 411/C 447 – HOT SURFACE PERFORMANCE	
<b>Appendix H</b>	<b>135</b>
ASTM C 356 & C 411 – LINEAR SHRINKAGE AND HOT SURFACE PERFORMANCE	
<b>Appendix I</b>	<b>140</b>
MECHANICAL RESILIENCE AND WATER RESISTANCE	
<b>Appendix J</b>	<b>145</b>
ASTM C 795 – CORROSION TEST	
<b>Appendix K</b>	<b>148</b>
ASTM C 592-04 – HEAT AND VIBRATION AGING	
<b>Appendix L</b>	<b>151</b>
BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE	



## Thermal Conductivity

### THERMAL CONDUCTIVITY OF PYROGEL XT ACCORDING TO ASTM C 177

Third-party validation of the thermal conductivity of Pyrogel XT was acquired at temperatures ranging from 0°–650°C (32°–1200°F) under a compressive load of 2 psi. The final report displaying the full thermal conductivity curve is shown in **Appendix A**.

## Non-Combustibility and Fire Performance

### ASTM E 84 – SURFACE BURNING CHARACTERISTICS

Pyrogel XT was tested in accordance with ASTM E 84, the Standard Test Method for Surface Burning Characteristics of Building Materials, and is given in **Appendix B**. Pyrogel XT exhibited no ignition during testing and thus satisfies the criteria for a Class A rating with a flame spread index: 0, smoke developed index: 0, and fuel contribution: 0.

### ASTM E 1354 – STANDARD TEST METHOD FOR HEAT AND VISIBLE SMOKE RELEASE RATES FOR MATERIALS AND PRODUCTS USING AN OXYGEN CONSUMPTION CALORIMETER

Pyrogel XT was tested in accordance with ASTM E 1354 at an incident heat flux equivalent to a cellulosic fire (50 kW/m<sup>2</sup>). The testing was performed in triplicate with no signs of ignition for all samples, resulting in a total heat release of zero and effective heat of combustion of 730 J/g. These third-party test results can be found in **Appendix C**.

### BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

The reaction to fire performance of Pyrogel XT was evaluated via **BS EN 13501-1:2007**. Pyrogel XT (5-10 mm) achieved a reaction to fire classification of A2-s1, d0 for construction applications and as a suspended ceiling membrane. **EN ISO 1716** and **EN 13823** were carried out as part of this testing, and all results were compliant for Class A2 classification. Third-party test results can be found in **Appendix L**. (Click bolded text to jump to specific section.)

## Non-Combustibility and Fire Performance

### BSS 7239:88 – TEST METHOD FOR TOXIC GAS GENERATION BY MATERIALS ON COMBUSTION

Quantitative analysis of potential toxic combustion gases was determined for Pyrogel XT via Boeing Support Specification 7239. Specifically, representative production samples were exposed to flaming combustion conditions (25 kW/m<sup>2</sup>) as dictated by ASTM E 662. The levels of CO, HF, HCl, NO<sub>x</sub>, SO<sub>2</sub> and HCN were determined via Dräger colorimetric gas analyses. All of the gases were below the detection limits with the exception of CO and NO<sub>x</sub>, which exhibited levels of 100 and 5.0 ppm, respectively. While no specific pass/fail criteria exists for BSS 7239, the measured levels of CO and NO<sub>x</sub> are significantly below the accepted transportation industry standards of 3500 and 100 ppm, respectively. The third-party test results for BSS 7239 can be found in **Appendix E**.

### ISO 1182:1990 – TEST FOR NON-COMBUSTIBILITY

The non-combustibility of Pyrogel XT was assessed via the methods outlined in ISO 1182. The mean duration of flaming, average specimen temperature and average furnace temperature for a representative sample of Pyrogel XT was 0 sec, 32°C and 27°C (90°F and 81°F), respectively. This performance meets the criteria for non-combustibility as set forth in the 1990 edition of ISO 1182 and is consistent with a Euroclass A2 Fire classification. Third-party ISO 1182 test results can be found in **Appendix D**.

### UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL (Pyrogel XTF only)

Testing was conducted on Pyrogel XTF to evaluate its fire resistance. Testing was conducted in accordance with UL 1709-05 Standard for Rapid Rise Fire Tests of Protection Materials for Structural Steel. Results were as follows:

12 mm → 68 min	48 mm → 184 min
30 mm → 132 min	66 mm → >240 min

The third-party test results for UL 17090-05 can be found in **Appendix F**.

## **Dimensional Stability**

### **ASTM C 356 – LINEAR SHRINKAGE UNDER FULL THERMAL SOAK**

The dimensional stability of Pyrogel XT at elevated temperatures was ascertained by testing according to the methods outlined in ASTM C 356. A linear shrinkage of 1.3% and a total mass loss of 1.1% was observed for Pyrogel XT after a 24-hour exposure at 650°C (1200°F). Third-party ASTM C 356 test results can be found in **Appendix H**.

### **ASTM C 411 – HOT SURFACE PERFORMANCE (FLAT PLATE CONFIGURATION)**

The maximum use temperature of Pyrogel XT was confirmed by testing material according to ASTM C 411 in a flat plate configuration. Specifically, a 60 mm stack-up of Pyrogel XT was exposed to a hot surface at 650°C for a period of 96 hours. The maximum midpoint temperature of the stack-up was measured at 463°C with a cold face temperature of 65.6°C, indicating the absence of any unusual exothermic heat rise. After testing, Pyrogel XT retained structural integrity and exhibited no signs of warping, delamination, or cracking. Third-party test results for ASTM C 411 can be found in **Appendix H**.

### **ASTM C 411/C 447 – ESTIMATION OF MAXIMUM USE TEMPERATURE AND HOT SURFACE PERFORMANCE (PIPE CONFIGURATION)**

The maximum use temperature of Pyrogel XT was assessed using the methods outlined in ASTM C 447 using material shrinkage and degradation in thermal performance during ASTM C 411 testing as the main criteria. Specifically, 60 mm of Pyrogel XT was installed on a 3.5" pipe and subjected to heating to 650°C (1200°F) for a period of 96 hours. The average percent shrinkage across the leading edge (i.e. hot face) was measured at 1.77%. Interply thermocouples located between layers 2-3, 4-5, 6-7, 8-9, and 10-11 were stable throughout the test, indicating the absence of any exothermic heat rise. Third-party ASTM C 411/C 447 test results are found in **Appendix G**.



## Water Resistance/Permeability

### ASTM C 1104 – WATER VAPOR SORPTION

The amount of water absorbed upon exposure to high humidity conditions was determined via the methods outlined in ASTM C 1104. Specifically, Pyrogel XT exhibits an average weight gain of 2.25% upon exposure to 95% RH at 49°C for 96 hours. Pyrogel XT exceeds the requirements for water vapor sorption as outlined in ASTM C 547, the Standard Specification for Mineral Fiber Pipe Insulation. Third party test results can be found in **Appendix I, Table 2**.

### ASTM C 1511 – DETERMINATION OF WATER RETENTION

Water retention test results for Pyrogel XT are given in **Appendix I, Table 3**. The average weight gain for a 10" x 10" sample was 16.3 grams, which translates to a water uptake of 4.2 vol %. It was estimated that a significant majority of this water uptake was attributed to the presence of microscopic water droplets adhered to the surface of the insulation and not solely from bulk absorption. We have thus conducted testing using a modified ASTM C1511 procedure that includes the removal of these surface species via contact with saturated paper towel. The results of this testing indicated that the bulk water uptake of Pyrogel XT was consistently <0.5 vol %.

### ASTM C 1559 – WATER WICKING

The propensity for Pyrogel XT to wick water was determined by the methods outlined in ASTM C 1559. Pyrogel XT is hydrophobic and exhibits no water wicking for the duration of the test (168 hours). Third-party test results are shown in **Appendix I, Table 5**.

## Other

### ASTM C 165 - COMPRESSIVE STRENGTH

The compressive resistance of Pyrogel XT was acquired according to the methods outlined in ASTM C 165. Specifically, the compressive resistance was determined at 10% and 25% strain for Pyrogel XT. The compressive stress at 10% and 25% strain for a single ply of Pyrogel XT was determined to be 102.9 kPa and 182.9 kPa, respectively. Similar results were obtained for a 5-ply specimen, which exhibited a compressive resistance of 103.1 kPa and 217.4 kPa at a 10% and 25% strain, respectively. Third party results are shown in **Appendix I, Table 4**.

### ASTM C 592-04 – HEAT AND VIBRATION AGING

The heat and vibration aging characteristics of Pyrogel XT were tested via ASTM C592-04 (Section 11.11, Modified). The specimen was thermally soaked at 400°C for 96 hours and then vibrated horizontally for 6 hours (12 Hz, displacement of 3 mm peak to peak). Pyrogel XT showed a -0.19% mass change after vibration. Third-party test results can be found in **Appendix K**.

### ASTM C 795 – CORROSION TEST

This report details the results of a 28-day corrosion test (ASTM C 692) and the pH and chemical testing of water extraction (ASTM C 871) of Pyrogel XT BLKT 1205 as determined by ASTM C 795, standard specification for thermal insulation for use in contact with austenitic stainless steel. Pyrogel XT BLKT 1205 met the chemical requirements of ASTM C 795, falling within the “Acceptable” range of the “Acceptability Curve.” Third party results are shown in **Appendix J**.

### ASTM D 5034 – TENSILE STRENGTH

The tensile strength of Pyrogel XT was determined for a single ply of 5 mm material according to the methods outlined in ASTM D 5034, Standard Test Method for Breaking Strength and Elongation of Textile Fabrics. The average tensile strength for Pyrogel XT was determined to be 490 N in the machine direction and 370 N in the cross-direction. Third-party test results can be found in **Appendix I, Table 6**.

**Appendix A** ASTM C 177 – THERMAL CONDUCTIVITY



Report on the

**THERMAL CONDUCTIVITY and  
THERMAL RESISTANCE of AEROGEL MAT**

Prepared for:

**Aspen Aerogels Inc.**  
**30 Forbes Road**  
**Northborough, Massachusetts 01532**


Prepared by:

**NETZSCH Instruments, Inc.**  
**Testing Services**

Report Number: 621001443

Work Performed Under Purchase Order Number: 306132

Submitted By:

  
Robert C. Campbell  
Applications Laboratory Manager

May 2008



### Appendix A ASTM C 177 – THERMAL CONDUCTIVITY



#### Report on the Apparent Thermal Conductivity and Thermal Resistance of Aerogel Mat

NETZSCH Instruments was contracted by Aspen Aerogels to evaluate one aerogel mat insulation material for apparent thermal conductivity at nominal mean temperatures of 0, 50, 100, 200, 350, 500 and 600°C by the guarded hot plate method.

The material was identified as given in Table 1 and was submitted as a pair dimensioned approximately 305 mm square by 6 mm thickness. The samples were cut to 200 mm diameter for testing.

The specimens were positioned horizontally with heat flow up and down during the tests. The test results are given in Table 1 after a description of equipment and procedure.

#### Thermal Conductivity

Thermal conductivity is the material property that determines the amount of heat that will flow through an object when a temperature difference exists across the object. Thermal conductivity is a steady state property; it can only be directly measured under conditions in which the temperature distribution is not changing and all heat flows are steady. The fundamental equation that governs steady-state heat flow in a slab geometry is:

$$Q = (\lambda \times \Delta T \times A) / \Delta x \quad (1)$$

where

$Q$  = the rate of heat flow through the slab  
(W or Btu/h)

$\lambda$  = the thermal conductivity of the slab material  
(W/m K or Btu/h-ft-°F)

$\Delta T$  = the temperature difference across the slab  
(°C or °F)

$\Delta x$  = the thickness (m or ft)

$A$  = the cross sectional area (m<sup>2</sup> or ft<sup>2</sup>)

## Appendix A ASTM C 177 – THERMAL CONDUCTIVITY



Materials that have low values of thermal conductivity allow only a small amount of heat flow and are called thermal insulators. Materials with large values of thermal conductivity allow more heat to flow across the slab with the same temperature difference. Thermal conductivity is a material property and does not depend upon the geometry of the sample. In general, thermal conductivity is a function of the mean sample temperature. The material comprising the slab is often a mixture of materials. It could be a layered composite or a material containing gas cells in which heat can be transferred by convection and radiation as well as by conductivity through the material. In these cases the parameter,  $\lambda$ , defined in Equation (1) is an "effective" or "apparent" thermal conductivity for the heterogeneous material.

### Experimental Procedure for Testing by ASTM C 177-97

Testing was performed in accordance with ASTM C 177-97, *Steady-State Heat Flux Measurements and Thermal Transmission Properties by Means of the Guarded Hot Plate Apparatus*, utilizing a Holometrix Model TCFGM guarded hot plate instrument (SN GHP-3). A schematic diagram of the test facility is shown in Figure 1. Two samples sandwiched a heating unit, which consisted of a central metering section and an annular guard section. This composite stack was mounted between two cooling units and surrounded with an environmental heater unit, a fluid-cooled shroud, and edge insulation. The metering section of the heating unit consisted of a metering area heater and metering area surface plates, while the guard section was comprised of a single guard heater and guard surface plates. The cooling units consisted of a cooling plate, a cooling unit heater, and a cooling surface plate. All surface plates were fabricated of 10 mm (0.38 inch) thick steel, were smoothly finished to conform to a true plane to within 0.025 percent, and were treated to have a total hemispherical emittance of 0.82 at 24 °C (75 °F).

The heating unit was fabricated by sandwiching a two-element mica heater unit between two thin sheets of ceramic fiber paper and two surface plates. The overall geometry of the heating unit was 200 mm (8 inches) in diameter, with the metering area being the central 100 mm (4 inch) round section. The unit was bolted together at four points, one being in the metering section. The two sections of the heater unit were separated by a 3 mm (0.125 inch) gap around the perimeter of the metering section. The specific area of the metering section was  $8.36 \times 10^{-3} \text{ m}^2$  ( $9.00 \times 10^{-2} \text{ ft}^2$ ). The area of the gap represented 3.3 percent of the total metering section area. The area of the metering section was determined by measurements to the centers of the gap. A 16-junction differential thermopile was installed between the mica heating unit and the surface plates such that alternate junctions

**Appendix A** ASTM C 177 – THERMAL CONDUCTIVITY



were in the metering and guard sections respectively and close to the annular gap between the sections. This thermopile was fabricated of 32-gauge Type-K Chromel/Alumel wire. The sensitivity of this thermopile was approximately 0.33 mV/°C (0.18 mV/°F) at 24 °C (75 °F).

The metering area heater was connected to a Sorenson DC Power Supply. A 0.001  $\Omega$  precision resistor was connected in series with the heater and the voltage drop across this resistor (0.001 times the current) was monitored. The voltage across the heater was measured directly. The output of the differential thermopile was connected to a differential temperature controller which supplied power to the guard heater such that the thermopile output was minimized.

The cooling units consisted of a 10 mm (0.38 inch) thick copper plate which had a series of interconnected 6 mm (0.25 inch) diameter copper tubes soldered to the plate and foamed in place with a spray urethane foam, a mica electric resistance heater unit, and a surface plate. The plates and heater were similar in cross section to the heating unit. The tubing was connected to a temperature controlled circulating chiller unit and a control thermocouple was attached to the underside of the surface plate and connected to a temperature controller. Temperature control at the surface plates was accomplished by operating the circulating chiller continuously and reheating with the electrical resistance heaters.

The environmental heating unit consisted of a sheathed electric resistance cable heater sandwiched between two tightly fitting passivated stainless steel rings 300 mm (12 inches) in diameter by 100 mm (4 inches) high. The electric resistance heater was connected to a temperature controller. The environmental heating unit and test stack were enclosed by a bell jar. The approximate dimensions of the bell jar were 457mm (18 inches) in diameter by 711mm (28 inches) high. The temperature of the environmental heating unit was controlled and monitored by thermocouples attached to its inner surface. The interspaces between the test stack, environmental heating unit, and bell jar were filled with loose-fill insulation material.

Temperature measurements were performed by utilizing Type-K Chromel/Alumel thermocouples calibrated to the special limits of error specified in ASTM E 230, *Temperature-Electromotive Force (EMF) Tables for Standardized Thermocouples*. All thermocouple sensors were fabricated with #30 AWG wire. The thermocouples were fixed to the surface plates by cementing them into 1.6 mm (0.062 inch) square grooves that had been machine-cut into all the surface plates. A total of two thermocouples were cemented into each working surface; one in the metering section and one in the guard section. The temperature sensors



**Appendix A** ASTM C 177 – THERMAL CONDUCTIVITY



were referenced to an Acromag Model 320 Electronic Ice Reference. The setpoint accuracy for the reference is  $\pm 0.5\text{ }^{\circ}\text{C}$  ( $\pm 0.9\text{ }^{\circ}\text{F}$ ) with a  $0.1\text{ }^{\circ}\text{C}$  ( $0.2\text{ }^{\circ}\text{F}$ ) stability over an eight-hour period. The voltage drops, current, and thermopile output were metered with a Hewlett Packard Data Acquisition Unit, Model 3497, having a range of  $\pm 1\mu\text{V}$  to 300V. The resolution of the meter is 1 microvolt with a maximum error of 0.01 percent of the output and  $\pm 2$  microvolts over an eight-hour period.

In operation, a steady temperature equilibrium was established in the test system. The temperatures of the cooling surface plates were set to their required levels. The required temperature difference across each sample was maintained by the adjustment of the power to the metering area heater. If no specific temperature difference was required, a  $40\text{ }^{\circ}\text{C}$  ( $75\text{ }^{\circ}\text{F}$ ) difference was used. The temperature of the environmental heating unit was controlled to the mean sample temperature level. The differential output was checked and adjusted such that the thermopile output was maintained between  $\pm 0.01\text{ mV}$ . At equilibrium, established after ensuring that during twenty-one regular sets of ten – one minute readings, the apparent thermal conductivity did not change by more than 0.5 percent and that there was no consistent drift, the power to the metering area heater was measured with the precision resistor network and the temperatures of the working surfaces were evaluated from thermocouple readings.

The apparent thermal conductivity was calculated from

$$\lambda = \frac{Q \times L}{A \times \Delta T}$$

and the thermal resistance was calculated from

$$R = \frac{A \times \Delta T}{Q}$$

where

- $\lambda$  = apparent thermal conductivity, W/m-K (Btu-in/hr-ft<sup>2</sup>-°F)
- $Q$  = power dissipation in the metering heater, W (Btu/hr)
- $L$  = total thickness of both test specimens, m (inches)
- $A$  = the metering surface area taken twice, m<sup>2</sup> (ft<sup>2</sup>)
- $\Delta T$  = total temperature difference across both specimens, °C (°F)
- $R$  = thermal resistance, m<sup>2</sup>-K/W (hr-ft<sup>2</sup>-°F/Btu)

**Appendix A** ASTM C 177 – THERMAL CONDUCTIVITY



The instrument performance was verified using the National Institute of Standards and Technology Standard Reference Material 1450b. The calibration specimen is a high-density fibrous glass material, 25.4 mm (1.00 inch) thick, having a thermal resistance of approximately 0.803 m<sup>2</sup>·K/W (4.56 hr·ft<sup>2</sup>·°F/Btu) at 24 °C (75 °F). The overall uncertainty of the thermal resistance of the standard is estimated by NIST to be 2 percent. The instrumentation is verified every six months and after any repair or modification.

**Appendix A** ASTM C 177 – THERMAL CONDUCTIVITY



Test Results


The test results are given in Table 1 and are plotted in Figure 2. The results reported apply only to the specimens that were tested.

A load of approximately 2 PSI was applied to the stack during testing. Prior to testing, the average compression of several extra pieces of the material under a load of 2 PSI was measured with a Satec T500 mechanical tester to be about 6%. Rigid spacers were cut for each sample to a thickness 6% lower than the sample thickness measured with a drop gauge. Under the stack load, the instrument plates made contact with the spacers to ensure a known and uniform plate gap and sample thickness.

The thermal conductivity and resistance results are estimated to be accurate to within  $\pm 5\%$ .




**Appendix A** ASTM C 177 – THERMAL CONDUCTIVITY




**Figure 1. Schematic Diagram of Guarded Hot Plate Instrument**

### Appendix A ASTM C 177 – THERMAL CONDUCTIVITY

											
<p>Table 1</p> <p>ASTM C177 THERMAL CONDUCTIVITY TEST RESULTS</p>											
Specimen	Test Thickness		Test Density		Temperature			Apparent Thermal Conductivity		Thermal Resistance	
	mm	inch	kg/m <sup>3</sup>	lbs/ft <sup>3</sup>	Mean °C	°F	Avg. Delta °C	SI	British	SI	British
Pyrogel XT Flexible Insulation Blanket	5.86	0.231	183	11.4	0	32	40	0.0182	0.126	0.322	1.83
					50	122	40	0.0195	0.135	0.301	1.71
					100	212	40	0.0212	0.147	0.276	1.57
					200	391	41	0.0250	0.173	0.234	1.33
					350	661	41	0.0362	0.251	0.162	0.919
					500	931	41	0.0574	0.398	0.102	0.579
					649	1200	42	0.0959	0.665	0.0611	0.347
<p>Reference: Report No. 621001443</p> <p>8</p> <p>May 2008</p>											
<p>Thermal Conductivity SI Units: W/m-K</p> <p>Thermal Conductivity British Units: Btu-in/hr-°F-ft²</p> <p>Thermal Resistance SI Units: m²-K/W</p> <p>Thermal Resistance British Units: hr-°F-ft²/Btu</p>											

Appendix A    ASTM C 177 – THERMAL CONDUCTIVITY



#### Appendix B ASTM E 84 – SURFACE BURNING CHARACTERISTICS



Accredited  
Testing Laboratory  
TL-216

Page 1 of 5

**TEST REPORT**  
for

ASPEN AEROGELS

30 Forbes Road  
Northborough, MA 01532

**Surface Burning Characteristics of Building Materials**

**ASTM E-84-07**

Test Report No: FH-1814

Assignment No: H-513

Test Date: 3/7/2008

Report Date: 3/11/2008

Subject Material: Pyrogel XT

Prepared by:   
Richard A. Costolnick  
Senior Test Engineer

Reviewed by:   
Robert J. Menchetti  
Director, Laboratory Facilities  
and Testing Services

The results reported in this document apply to specific samples submitted for measurement.  
No responsibility is assumed for performance of any other specimen.  
This report may not be reproduced, except in full, without the written approval of the laboratory.  
The laboratory's test reports in no way constitutes or implies product certification, approval  
or endorsement by this laboratory.

1650 Military Road • Buffalo, NY 14217-1198  
(716)873-9750 • Fax (716)873-9753 • [www.ngctestingservices.com](http://www.ngctestingservices.com)

### Appendix B ASTM E 84 – SURFACE BURNING CHARACTERISTICS



FH-1814  
Aspen Aerogels  
3/11/2008  
Page 2 of 5

#### **MATERIAL TESTED:**

Material submitted by Aspen Aerogels, Northborough, MA, was described by the client as:

#### **PYROGEL XT**

#### **Flexible Insulation Blanket**

The submitted samples consisted of a single continuous roll, 24 in. wide and cut to the required 24 ft. length.

#### **METHOD OF SUPPORT:**

The test specimen was supported by 2.0 in. galvanized steel poultry netting, placed over 1/4 in. diameter steel rods spaced 24 in. on center.

#### **RESULTS:**

The results can be found on page 3 of this report.



Appendix B    ASTM E 84 – SURFACE BURNING CHARACTERISTICS

FH-1814

ASPEN AEROGELS

3/11/2008

Page 3 of 5

RESULTS:

MATERIAL TESTED	TEST NO.	SUPPORT	SIDE EXPOSED	CALCULATED FLAME SPREAD	CALCULATED SMOKE DEVELOPED
PYROGEL XT	1	WIRE & RODS	SYMMETRICAL	0.00	0.05

---

MATERIAL TESTED	SUPPORT	SIDE EXPOSED	FLAME SPREAD INDEX*	SMOKE DEVELOPED INDEX*
RED OAK FLOORING (CALIB.)	DECKS	NA	100	100
CEMENT BOARD (CALIB.)	SELF	NA	0	0

PYROGEL XT	WIRE & RODS	SYMMETRICAL	0	0
------------	-------------	-------------	---	---

CLASS "A"

CLASS "B"

CLASS "C"

FSI

<25

26-75

76-200

SDI

0-450

0-450

0-450

\* Flame Spread/Smoke Developed Index is the result (or average of the results of multiple tests), rounded to the nearest multiple of 5.

## Appendix B ASTM E 84 – SURFACE BURNING CHARACTERISTICS

# Fire Testing Laboratory

ADC DRAFT (IN. H2O) 0.082  
 GAS PRESS. (IN. H2O) 0.288  
 GAS VOL. (CF) 49.56  
 BTU/lcf 1000  
 SHUTTER 3"  
 TEMP. 13° BURIED 105°F

FLAME SPREAD- 0.00  
 AREA UNDER THE CURVE (min.-ft.) 0.00  
 SMOKE DEVELOPED- 0.05


DATE 3/7/2008  
 TEST #: FH-1814  
 TEST METHOD: ASTM E-84-07  
 CLIENT: ASPEN AEROGELS  
 PROJECT #: H-513  
 SAMPLE: PYROGEL XT  
 MATERIAL: FLEXIBLE INSULATION BLANKET  
 METHOD OF SUPPORT: WIRE & RODS  
 REMARKS: IGNITION @ :NONE  
 MAX. FLAME FRONT 0.0' @ 10:30  
 NO IGNITION

#	TIME (Min.)	TIME (Sec.)	DISTANCE (Ft.)
1	0	0	0.0
2	10	0	0.0
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			


WITNESSED BY: E-MAIL ngctest@nationalgypsum.com

1660 MILITARY ROAD, BUFFALO, 14217 TEL 716-873-9760 FAX 716-873-9753

Appendix B ASTM E 84 – SURFACE BURNING CHARACTERISTICS



### Appendix C ASTM E 1354 – CONE CALORIMETRY



**The Govmark Organization, Inc.**

96-D Allen Boulevard  
Farmingdale, New York 11735-5626 USA  
Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956  
e-mail: info@govmark.com

Page 1

Received: 03/05/2008	Completed: 03/24/2008	Letter: F	md	P.O.#: 306131	Test Report #: 2-72387-0-
<b>Client's Identification</b> Pyrogel XT, Flexible insulation blanket					
<b>Tested For:</b> Cindy MacLaurin Aspen Aerogels 30 Forbes Road, Bldg. B Northborough, MA 01532			<b>Key Test:</b> ASTM E 1354 645  Tel: 1-(508)-691-1132 Ext: Fax: 1-(508)-691-1114		

PC: 48H (ME)

TEST PERFORMED: ASTM E 1354 - Heat Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter

HEAT FLUX: ☐ 35 kW/m²; ☒ 50 kW/m²; ☐ Other:

RETAINING WIRE GRID PLACED OVER FACE OF SPECIMEN: ☒ Yes; ☐ No


CATEGORY:	RESULTS			
	Specimen #1	Specimen #2	Specimen #3	AVERAGE
Ignitability (expressed as Time To Sustained Ignition (TIG)) (seconds):	NI	NI	NI	NI
Peak Heat Release Rate (kW/m²):	27.0	9.0	6.1	14.0
Average Heat Release Rate (Avg HRR) --				
At 60 seconds (kW/m²):	5.8	3.1	1.9	3.6
At 180 seconds (kW/m²):	7.5	2.5	2.4	4.1
At 300 seconds (kW/m²):	5.5	1.6	2.5	3.2
At test end (kW/m²):	NC	NC	NC	NC
Average Mass Loss Rate (g/m² sec):	0.6	0.4	0.3	0.4
Total Heat Release (MJ/m²):	0.0	0.0	0.0	0.0
Visible Smoke Development of Material (expressed as the Specific Extinction Area (SEA)) --				
At 180 seconds (m²/kg):	NC	NC	NC	NC
At test end (m²/kg):	474	575	475	508
Effective Heat of Combustion (MJ/kg):	0.50	1.51	0.17	0.73
Test Length (seconds):	1,800	1,800	1,800	1,800

(Page 1 of 2)

PAGE 01/02



GOVMARK

03/28/2008 11:55 16312938956

File Copy 



### Appendix C ASTM E 1354 – CONE CALORIMETRY

 <b>The Govmark Organization, Inc.</b>		96-D Allen Boulevard Farmingdale, New York 11735-5626 USA Tel: +1 (631) 293-8944 Fax +1 (631) 293-8956 e-mail: info@govmark.com	
Received: 03/05/2008		Completed: 03/24/2008	
Letter: F		md	
P.O.#: 306131		Test Report #: 2-72387-0-	
<b>Client's Identification</b> Pyrogel XT, Flexible insulation blanket			
<b>Tested For:</b> Cindy MacLaurin Aspen Aerogels 30 Forbes Road, Bldg. B Northborough, MA 01532		<b>Key Test:</b> ASTM E 1354 645  Tel: 1-(508)-691-1132 Fax: 1-(508)-691-1114	
<b>ABBREVIATIONS WHICH MAY BE USED:</b>  NC = Not calculated; all flaming extinguished prior to this time point. NR = Not recorded. NA = Not available. NI = NO ignition			
<b>ACCEPTANCE CRITERIA:</b> None cited.			
<b>REMARKS:</b> None.			
<b>CERTIFICATION:</b> I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by ASTM E 1354.			
 _____ AUTHORIZED SIGNATURE THE GOVMARK ORGANIZATION, INC. /jb			
(Page 2 of 2)			

The results contained in this report relate only to item(s) tested. The test report shall not be reproduced, except in full, without written approval from The Govmark Organization, Inc.

*File Copy*

PAGE 02/02

GOVMARK

16312938956 93/28/2008 11:55



**Appendix D** ISO 1182:1990 – NON-COMBUSTIBILITY

Intertek ETL SEMKO

Page 1 of 5

ISO 1182:1990  
Fire test / Building / Non-combustibility test

Pyrogel XT

Project No. 3148592SAT-001

March 31, 2008

Prepared for:  
Aspen Aerogels  
30 Forbes Rd, Building B  
Northborough, MA 01532

Intertek Testing Services NA, Inc.  
16015 Shady Falls Road  
Elmendorf, Texas 78112  
Telephone: 210-635-8100 Fax: 1-210-635-8101  
e-mail: [www.intertek-etlsemko.com](http://www.intertek-etlsemko.com)

### Appendix D ISO 1182:1990 – NON-COMBUSTIBILITY

Project No. 3148592SAT-001  
Aspen Aerogels

March 31, 2008  
Page 2 of 5

#### ABSTRACT

*The specimens submitted by Aspen Aerogels and identified as "Pyrogel XT" were tested in accordance with ISO 1182 Non-combustibility test.*


This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

This report contains a total of 5 pages.

  
John Gutierrez  
Technician

March 31, 2008

Reviewed and approved:

  
Servando Romo  
Project Manager

March 31, 2008

Intertek ETL SEMKO

**Appendix D** ISO 1182:1990 – NON-COMBUSTIBILITY

Project No. 3148592SAT-001  
Aspen Aerogels

March 31, 2008  
Page 3 of 5

### I. INTRODUCTION

This report describes the results of the ISO 1182 Non-combustibility test. It may be important to ascertain whether a material will or will not contribute directly to fire development and this test has been designed to allow this to be done. Its results will provide information from which regulating authorities will be assisted in deciding whether the material in question may be used without undue hazard in certain locations in buildings. From a technical point of view, the test gives no absolute statement concerning "non-combustibility".

*The test results relate only to the behavior of the test specimens of a material under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use.*

### II. PURPOSE

The results of the ISO 1182 test method may be used for the determination of the combustibility performance of a building material under specified conditions. (750°C). The method is intended for the testing of building materials but is not applicable to the testing of products which are coated, faced or laminated.

### III. TEST SPECIMENS

Five specimens of materials were tested. The specimens were cylindrical with a diameter of 45 mm and a height of 52 mm. The volume of the specimens was 82.6 cm<sup>3</sup>. The specimens consisted of flexible insulation blanket.

Intertek ETL SEMKO

**Appendix D** ISO 1182:1990 – NON-COMBUSTIBILITY

Project No. 3148592SAT-001  
Aspen Aerogels

March 31, 2008  
Page 4 of 5

**IV. TEST PROCEDURE**

Prior to testing, the specimens were conditioned at  $60^{\circ} \pm 5^{\circ}\text{C}$  for twenty-four hours, then stored in a desiccator and cooled to ambient temperature. When the power to the furnace is adjusted so that the average furnace temperature is  $750 \pm 5^{\circ}\text{C}$  for at least ten minutes, the samples are placed on the specimen holder and instrumented with thermocouples. The thermocouples are placed on the outer surface at mid-height and the geometric center of the specimen. Once the specimen has been instrumented, the holder (with the specimen) is placed in the furnace and the timing device is started. The furnace and specimen temperatures are recorded during the test. The specimen is kept in the furnace until final temperature equilibrium. The mass of the specimens is recorded before and after testing.

**V. RESULTS AND OBSERVATIONS**

Specimens submitted by: Aspen Aerogels

Date received: March 26, 2008 (This specimen was received in good condition.)

Date tested: March 28, 2008

Specimen ID: Pyrogel XT

Description of specimen: Flexible Insulation Blanket

Environmental Conditions:  $70^{\circ}\text{F}$  and 63% r.h.

This Test Witnessed by: Owen Evans and Chris Abeles

**Intertek** ETL SEMKO



#### Appendix D ISO 1182:1990 – NON-COMBUSTIBILITY

Project No. 3148592SAT-001  
Aspen Aerogels

March 31, 2008  
Page 5 of 5

The results of these tests are presented in the following tables:

Specimen Number	1	2	3	4	5
Initial Furnace Temp. (°C)	746	748	755	754	751
Mass Before Test (grams)	14.75	15.18	14.16	13.99	14.42
Sustained Flaming (sec.)	None	None	None	None	None
Mass After Test (grams)	14.14	14.59	13.51	13.43	13.91
Percent Mass Loss	4.14	3.89	4.59	4.00	3.54
Average Percent Mass Loss of Five Specimens	4.03				
Mean Duration of Sustained Flaming (sec.)	None				

#### FURNACE TEMPERATURES

Specimen Number	1	2	3	4	5
Max. Furnace Temperature (°C)	809.9	811.0	819.0	799.9	808.9
Final Furnace Temperature (°C)	775.8	783.0	792.3	777.0	785.3
Furnace Temperature Rise (°C)	34.1	28.0	26.7	22.9	23.6
Average Furnace Temperature Rise of Five Specimens	27.1				

#### SPECIMEN SURFACE TEMPERATURES

Specimen Number	1	2	3	4	5
Max. Surface Temperature (°C)	828.8	823.7	832.1	826.2	814.6
Final Surface Temperature (°C)	788.2	796.4	801.6	793.2	787.9
Surface Temperature Rise (°C)	40.6	27.3	30.5	33.0	26.7
Average Surface Temperature Rise of Five Specimens	31.6				

#### SPECIMEN CENTER TEMPERATURES

Specimen Number	1	2	3	4	5
Max. Center Temperature (°C)	922.7	917.7	903.6	901.8	908.3
Final Center Temperature (°C)	762.7	776.0	770.2	761.6	767.3
Center Temperature Rise (°C)	160.0	141.7	133.4	140.2	141.0
Average Center Temperature Rise of Five Specimens	143.3				

#### Test Notes: (Time in Min : Sec. Top View Only)

Sample #1 had glowing flash spots at 0:59 (min:sec), no flame ignition visible.  
Sample #2 had glowing flash spots at 0:58 (min:sec), no flame ignition visible.  
Sample #3 had glowing flash spots at 1:01 (min:sec), no flame ignition visible.  
Sample #4 had glowing flash spots at 1:22 (min:sec), no flame ignition visible.  
Sample #5 had glowing flash spots at 1:15 (min:sec), no flame ignition visible.

Intertek ETL SEMKO



**Appendix E** BSS 7239 – TOXIC GAS GENERATION

Page 1 of 6

**Intertek**

BSS 7239-88  
Test Method for Toxic Gas Generation by  
Materials on Combustion

Pyrogel XT

Project No. 3146774SAT-002

March 22, 2008

Prepared for:

Aspen Aerogels, Inc.  
30 Forbes Rd, Building B  
Northborough, MA 01532

Intertek Testing Services NA, Inc.  
16015 Shady Falls Road  
Elmendorf, Texas 78112  
Telephone: 210-635-8100 Fax: 1-210-635-8101  
e-mail: [www.intertek-etlsemko.com](mailto:www.intertek-etlsemko.com)

**Appendix E** BSS 7239 – TOXIC GAS GENERATION

Project No. 3146774SAT-002  
Aspen Aerogels, Inc.

March 22, 2008  
Page 2 of 6

**Abstract**

*Specimens submitted by Aspen Aerogels, Inc. and identified as "Pyrogel XT", were tested in accordance with BSS 7239-88 by the procedures reported herein. Concentrations of the gases CO, HF, HCl, NO<sub>x</sub>, SO<sub>2</sub>, and HCN were determined. For results see page 6, table 2*

*This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.*

This report contains a total of 6 pages.

  
John Gutierrez  
Technician

March 22, 2008

Reviewed and approved:

  
Servando Romo  
Project Manager

March 22, 2008

Intertek

**Appendix E** BSS 7239 – TOXIC GAS GENERATION

Project No. 3146774SAT-002  
Aspen Aerogels, Inc.

March 22, 2008  
Page 3 of 6

**INTRODUCTION**

The determination of the gaseous products of smoke (often called "fire gases"), including those due to either pyrolysis or combustion, is a difficult problem. The composition of the smoke from most products is affected by the nature of the fire test procedure that created the smoke (i.e., flaming or nonflaming conditions, specimen size and configuration, external applied heat flux, etc.). Gas sampling considerations include the time at which sampling of the atmosphere was initiated and the duration of the sampling (smoke concentrations can change with time); the position of the sampling probe (concentrations can change with location in a chamber); the method of sampling (a major cause of error in fire gas analysis); and the actual method of analysis. Sampling and analysis of fire gases are described in some detail in ASTM E800 ("Standard Guide for Measurement of Gases Present or Generated During Fires"), to which the reader is referred.

One of the common test methods for creating "smoke" is the ASTM E662 smoke chamber (a method fundamentally the same as BSS 7238), which provides for both flaming and nonflaming combustion of 76 mm x 76 mm (3-in. x 3-in.) specimens exposed to an external radiant heat flux of 25 kW/m<sup>2</sup>. The smoke is retained within the confines of the 500-L chamber. For this test procedure, analysis of gaseous components is performed starting at four minutes into the test run. Only the flaming exposure is specified. Actual analysis of the gases of interest may be performed directly using Dräger® colorimetric gas analysis tubes; by trapping the gases in solution impingers (bubblers) and subsequently analyzing the anions by ion-selective electrodes, titration or liquid chromatography; or by instruments designed to measure the specific gas(es) of interest (e.g., gas chromatographic methods, NDIR or FTIR analyzers).

The following gases are required to be measured by this test standard:

CO	carbon monoxide
HF	hydrogen fluoride
HCl	hydrogen chloride
NO <sub>x</sub>	nitrogen oxides (both NO, nitric oxide, and NO <sub>2</sub> , nitrogen dioxide, are detected)
SO <sub>2</sub>	sulfur dioxide
HCN	hydrogen cyanide

Intertek

**Appendix E** BSS 7239 – TOXIC GAS GENERATION

Project No. 3146774SAT-002  
Aspen Aerogels, Inc.

March 22, 2008  
Page 4 of 6

In our test procedures, Dräger® colorimetric gas analysis tubes are used. These devices are small glass tubes containing one or more chemical indicators/absorbents that change color when a specific gas reacts with the chemical inside the tube. The length of the coloration is proportional to the concentration of the gas when a fixed volume of the test atmosphere is drawn through the tube (which is accomplished by a hand pump). These tubes have several distinct advantages over other analytical methods for fire gases under the conditions of this test procedure. They are pre-calibrated; they are relatively simple to operate; there is nothing between the gas of interest and the analysis tube; the results are straight-forward and immediate; and this single technique can be used for each of the gases specified (plus several other common gases). Other procedures require more extensive instrumentation with calibration by standard solutions or gases; they introduce additional sampling concerns (which are different for each gas); and no single technique can be used for the six gases specified.

Information is available on each of the Dräger tubes describing the potential interferences for each tube and the range of concentrations over which the tube is calibrated. The stated accuracy of these tubes is in the range of 10-15 percent; however, the combination of sampling errors and analytical uncertainty in other methods could also approach this. In our procedure, we burn several test specimens and take an average of these readings in an effort to minimize the uncertainty in the results.

*This standard is intended to measure and describe the properties of materials or products in response to heat and flame under controlled laboratory conditions and is not intended to describe or appraise the fire hazard or fire risk of materials, products, or assemblies under actual fire conditions.*

**TEST PROCEDURE**

Specimens were exposed to flaming conditions in the smoke chamber, in accordance with the procedures in ASTM E662. Gas analyses for the species listed below were performed using Dräger® gas detector tubes. Specimens were exposed to flaming conditions for four minutes; then the igniter was extinguished, the specimen was displaced from the radiant heat flux, any excess pressure within the chamber was released, and the analyses were started within one minute.

Intertek



### Appendix E BSS 7239 – TOXIC GAS GENERATION

Project No. 3146774SAT-002  
Aspen Aerogels, Inc.

March 22, 2008  
Page 5 of 6

Gas samples were extracted using the gas analysis tubes from points approximately six inches from the top of the chamber and four inches from either side wall. Although this is not the same location as given in BSS 7239

(i.e., 12 in. from the ceiling, in the center of the chamber), our sampling location was determined after considerable reflection on the advantages and disadvantages of various sampling schemes using these tubes. It is our belief that there would be no difference in the two sampling locations using our method of specimen exposure and sampling methodology.

Different tubes were drawn simultaneously from two different locations at opposite sides of the chamber in order to reduce the total time required for sampling. For replicate tests, tubes were drawn by a different operator from the other location. The gases more likely to change concentration due to reaction with moisture or soot in the chamber (i.e., HCl, HCN, HF) are drawn first in order to minimize their residence time in the chamber; while CO is sampled last, since its concentration will not change with time.

Table 1 is a listing of the specific gas detector tubes used in this study

Table 1. Identification of Gas Analysis Tubes used

Gas	Draeger Tube No.	Concentration Range, ppm	Number of Strokes
CO	5/c	10-300	10
HF	1.5/b	1.5 - 15	20
HCl	1/a	1-10	10
NO <sub>x</sub>	2/a	5-100	5
SO <sub>2</sub>	0.5/a	1 - 25	10
HCN	2/a	2 - 30	5

#### CRITERIA

In general the airline industry limits (in ppm) are as follows: CO=3500, HF=200, HCl=500, NO<sub>x</sub>= 100, SO<sub>2</sub> =100 and HCN=150. These limits are not set by the BSS 7239 standard.

Other limits may be required depending on the end use of the product so it is recommended that the proper governing organizations be contacted.

Intertek



**Appendix E** BSS 7239 – TOXIC GAS GENERATION

Project No. 3146774SAT-002  
Aspen Aerogels, Inc.

March 22, 2008  
Page 6 of 6

**RESULTS**

Specimens submitted by: Aspen Aerogels, Inc.

Date received: March 3, 2008 (This specimen was received in good condition.)

Date tested: March 21, 2008

Specimen ID: Pyrogel XT

Description of specimen: Flexible Insulation Blanket

Environmental conditions: 70°F and 60% r.h.

**Specimen preparation and mounting method**

The sample was prepared by the client and consisted of a 3 in. x 3 in. x 0.23 in. sheet insulation. The specimen was subjected to the standard conditioning and mounting methods.

Table 2. Test Results with notations  
(concentrations in ppm unless otherwise noted)

No.	HCl	HCN	HF	NO <sub>x</sub>	SO <sub>2</sub>	CO
1 Flaming	<1	N.D.	N.D.	5	N.D.	100
2 Flaming	<1	N.D.	N.D.	5	N.D.	100
Average	NA	N.D.	N.D.	5.00	N.D.	100

NOTES:  
N.D. = "none detected"  
N/A = Not Available

Intertek

**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

**TEST REPORT**



**REPORT NUMBER: 3159033**  
ORIGINAL ISSUE DATE: August 28, 2008  
REVISED DATE: N/A

**EVALUATION CENTER**  
16015 Shady Falls Road  
Elmendorf, TX 78112  
(voice) 210-635-8100  
(fax) 210-635-8101  
www.intertek-etlsemko.com

**RENDERED TO**  
  
**Aspen Aerogels, Inc.**  
30 Forbes Road  
Building B  
NORTHBOROUGH MA 01532

PRODUCT EVALUATED: Pyrogel® XTF Insulation Material  
EVALUATION PROPERTY: Safety Fire Resistance

**Report of Testing Pyrogel® XTF Insulation Material for compliance with the applicable requirements of the following criteria: UL 1709-05 Standard for Safety Rapid Rise Fire Tests of Protection Materials for Structural Steel**

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 2 of 95

## 1 Table of Contents

ITEM	PAGE
1 Table of Contents	2
2 Introduction	3
3 Test Samples	3
4 Testing and Evaluation Methods	4
5 Testing and Evaluation Results	5
6 Conclusions	9
Appendices	
Appendix A: Assembly Drawings	11
Appendix D: Temperature Data	15
Appendix E: Photographs	69
Revision Summary / Last Page of Report	95

Intertek

**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 3 of 95

## 2 Introduction

Intertek Testing Services NA (Intertek) has conducted testing for Aspen Aerogels, Inc. on Pyrogel® XTF Insulation Material, to evaluate its fire resistance. Testing was conducted in accordance with UL 1709-05 Standard for Safety Rapid Rise Fire Tests of Protection Materials for Structural Steel. This evaluation took place on August 21, 2008.

## 3 Test Samples

### 3.1. SAMPLE SELECTION

Samples of Pyrogel® XTF were submitted to Intertek directly from the client. Samples were not independently selected for testing. Samples were received at the Evaluation Center on August 18, 2008

### 3.2. SAMPLE AND ASSEMBLY DESCRIPTION

Intertek technicians installed 14 thermocouples onto the web on each of six W10 X 49 standard columns, 8' long. The thermocouples were installed across 4 zones: A-A, 5; B-B, 3; C-C, 3; and D-D, 3 (see Appendix A).

Representatives from Aspen Aerogels, Inc. installed the Pyrogel® XTF insulation onto the columns. Each of the column web cavities were filled with 19 -21 strips of Pyrogel® XTF (8.9" X 98" X nominal 6mm) to provide a nominal 120mm of insulation on each side of the web. The strips were held in place with 2-3 bands of 0.047" O.D. stainless steel wire (see Appendix C).

Courses (sections) of the Pyrogel® XTF insulation, either 32" or 48" wide and of varying lengths, were wrapped around the web-filled columns in layers (2, 5, 8, 8, 12, 14) alternating the 32" and 48" width insulation to stagger circumferential seams without telescoping. For the thicker, multi-layered columns (P5 – 14) some courses were "double length" and wrapped around twice – 2 layers per course. Some of the columns started with the 32" width and some with the 48" (see configuration table, next page). Each course of insulation overlapped itself by nominally 5", but butted up to the course above and/or below it on the column. If the first course consisted of 32" insulation, the second course was 48" insulation and *visa versa*, staggering the butt joints of the layer beneath it. A 48" course of insulation was the preferred outermost layer on a column to reduce the number of circumferential seams closest to the heat of the furnace. Each course was held in place with 2-3 bands of 0.047" O.D. stainless steel wire, then secured with ½" 0.02 stainless steel bands with ½" stainless steel wing seals, applied 12" o.c. but no closer than 2" from the edge of a seam, tightened with a pistol-grip banding tool (see Appendix A).

The installation process started with the application of a thin film of spray adhesive (3M Hi-Strength 90 Spray Adhesive or Foster Fos-Stik Clear Adhesive Spray 85-45) in a 3 - 4" strip down the leading edge of the section of insulation and the corresponding area of the web-fill strip where the installation would begin. The first course was always installed at the bottom of the column. The leading edge was attached to the edge of the web-fill layers (NOT on the

**Intertek**

## Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 4 of 95

metal beam) and wrapped counterclockwise, overlapping itself to a point half way across the web where it started (approx 5") and was held in place with 0.047" O.D wire. Another course was applied above that one, and one above that (if using 32" widths), butting the seams, completing the first course on the column.

The second course was installed in the same fashion as the first but used the alternate width of insulation to overlap the circumferential seams of the previous layer, and was started at the edge of the web-fill on the opposite side of the column (staggering longitudinal seams). Additional courses followed the same process, alternating the width of insulation used as well as the side of the beam as its starting point. The stainless steel bands were applied after each 2 layers (not courses) of wrapping.

The 96" tall columns were covered with 3 strips of 36" wide, 0.02 stainless steel cladding, each strip overlapping itself 3" and overlapping the one below it by 6". The cladding was installed with a slip-joint when overlapping an adjacent piece and each section was secured with ½" 0.02 stainless steel bands and wing seals, installed 12" o.c. Finally, #42 blind rivets with 2 #8 flat stainless steel washers were installed 6" o.c. down the longitudinal seam and in 4 equidistant places around the overlapping circumferential seams (see Appendix A).

### 4 Testing and Evaluation Methods

The completed column assemblies were placed in the Laboratory's full scale horizontal furnace in two rows of 3 each. The test was initiated at 10:55 a.m. on Thursday, August 21, 2008. Representatives from Aspen Aerogels, Inc. were in attendance. The ambient temperature and humidity at the time were 84°F and 76%RH. The outputs of all test specimens and furnace probes were monitored by a 300 channel Yokogawa, Inc., Model Darwin Data Acquisition Unit. The computer was programmed in LabVIEW to send the commands to the data acquisition systems to sample the data input lines and to convert the raw data into a usable format (i.e., degrees Fahrenheit) for display on screen and storage as an ASCII tab-delimited text file. The data was saved at 60-second intervals. Following the test, the files were imported into MS Excel for tabular and graphical display. The maximum allowed temperature for any one thermocouple on a column was 1200°F and for the TC Average within a section was 1000 °F.

#### 4.1. TEST STANDARD

Testing was conducted in accordance with UL 1709-05 Standard for Safety Rapid Rise Fire Tests of Protection Materials for Structural Steel.

Intertek



### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 5 of 95

## 5 Testing and Evaluation Results

### 5.1. RESULTS AND OBSERVATIONS

The test was initiated at 10:55 A.M. on August 21, 2008 and ran for 240 minutes. The observations made during the test are listed below:

Time (min:sec)	Observation
0:00	Test initiated
10:00	Smoke from the furnace, around the lid
21:00	Flame from around the samples
72:54	TC #11 from P2 exceeds max allowed temp
152:00	TC #11 from P5 exceeds max allowed temp
205:00	TC #9 from P8A exceeds max allowed temp
209:00	TC #3 from P8B exceeds max allowed temp
241:00	Test terminated

The test results for each column are presented below.

#### Column P2 (12mm):

Though the first thermocouple to exceed the 1200°F maximum occurred during the 72<sup>nd</sup> minute of the test (TC #11) the maximum allowable TC average (1000°F) was exceeded at the 68-minute mark.

In accordance with the UL 1709 test standard, a calculation for any correction to the indicated fire resistance period was done. The correction factor was then mathematically added to the indicated fire resistance period, yielding the fire resistance period achieved by this specimen:

ITEM	DESCRIPTION	TEST VALUE
C	correction factor	-0.53 minutes -32 seconds
I	indicated fire-resistance period	68 minutes
A	area under the curve of indicated average furnace temperature for the first three fourths of the indicated period	89134 (°F•min)
As	area under the standard furnace curve for the same part of the indicated period	90188 (°F•min)
	FIRE RESISTANCE PERIOD ACHIEVED BY THIS SPECIMEN ==>	67 minutes

**Intertek**

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 6 of 95

Note: The standard specifies that the fire resistance be determined to the nearest integral minute. Consequently, if the correction factor is less than 30 seconds, and the test specimen met the criteria for the full indicated fire resistance period, no correction is deemed necessary.

#### Column P5 (30mm):

Though the first thermocouple to exceed the 1200°F maximum occurred during the 152<sup>nd</sup> minute of the test (TC #11), the maximum allowable TC average (1000°F) was exceeded at the 131-minute mark.

In accordance with the UL 1709 test standard, a calculation for any correction to the indicated fire resistance period was done. The correction factor was then mathematically added to the indicated fire resistance period, yielding the fire resistance period achieved by this specimen:

ITEM	DESCRIPTION	TEST VALUE
C	correction factor	-0.47 minutes -28 seconds
I	indicated fire-resistance period	131 minutes
A	area under the curve of indicated average furnace temperature for the first three fourths of the indicated period	176129 (°F•min)
As	area under the standard furnace curve for the same part of the indicated period	177091 (°F•min)
	FIRE RESISTANCE PERIOD ACHIEVED BY THIS SPECIMEN ==>	131 minutes

Note: The standard specifies that the fire resistance be determined to the nearest integral minute. Consequently, if the correction factor is less than 30 seconds, and the test specimen met the criteria for the full indicated fire resistance period, no correction is deemed necessary.

#### Column P8A (48mm):

Though the first thermocouple to exceed the 1200°F maximum occurred during the 205<sup>th</sup> minute of the test (TC #9) the maximum allowable TC average (1000°F) was exceeded at the 184-minute mark.

In accordance with the UL 1709 test standard, a calculation for any correction to the indicated fire resistance period was done. The correction factor was then mathematically added to the indicated fire resistance period, yielding the fire resistance period achieved by this specimen:

**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 7 of 95

ITEM	DESCRIPTION	TEST VALUE
C	correction factor	-0.37 minutes -22 seconds
I	indicated fire-resistance period	184 minutes
A	area under the curve of indicated average furnace temperature for the first three fourths of the indicated period	250286 (°F•min)
As	area under the standard furnace curve for the same part of the indicated period	251051 (°F•min)
	FIRE RESISTANCE PERIOD ACHIEVED BY THIS SPECIMEN ==>	184 minutes

Note: The standard specifies that the fire resistance be determined to the nearest integral minute. Consequently, if the correction factor is less than 30 seconds, and the test specimen met the criteria for the full indicated fire resistance period, no correction is deemed necessary.

**Column P8B (48mm):**

Though the first thermocouple to exceed the 1200°F maximum occurred during the 209<sup>th</sup> minute of the test (TC #3) the maximum allowable TC average (1000°F) was exceeded at the 175-minute mark.

In accordance with the UL 1709 test standard, a calculation for any correction to the indicated fire resistance period was done. The correction factor was then mathematically added to the indicated fire resistance period, yielding the fire resistance period achieved by this specimen:

ITEM	DESCRIPTION	TEST VALUE
C	correction factor	-0.40 minutes -24 seconds
I	indicated fire-resistance period	175 minutes
A	area under the curve of indicated average furnace temperature for the first three fourths of the indicated period	237294 (°F•min)
As	area under the standard furnace curve for the same part of the indicated period	238108 (°F•min)
	FIRE RESISTANCE PERIOD ACHIEVED BY THIS SPECIMEN ==>	175 minutes

Note: The standard specifies that the fire resistance be determined to the nearest integral

**Intertek**

**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 8 of 95

minute. Consequently, if the correction factor is less than 30 seconds, and the test specimen met the criteria for the full indicated fire resistance period, no correction is deemed necessary.

**Column P11 (66mm):**

Neither the individual nor the average thermocouple maximums were exceeded during the 240-minute test.

In accordance with the UL 1709 test standard, a calculation for any correction to the indicated fire resistance period was done. The correction factor was then mathematically added to the indicated fire resistance period, yielding the fire resistance period achieved by this specimen:

ITEM	DESCRIPTION	TEST VALUE
C	correction factor	-0.37 minutes -22 seconds
I	indicated fire-resistance period	240 minutes
A	area under the curve of indicated average furnace temperature for the first three fourths of the indicated period	327951 (°F•min)
As	area under the standard furnace curve for the same part of the indicated period	328709 (°F•min)
	FIRE RESISTANCE PERIOD ACHIEVED BY THIS SPECIMEN ==>	240 minutes

Note: The standard specifies that the fire resistance be determined to the nearest integral minute. Consequently, if the correction factor is less than 30 seconds, and the test specimen met the criteria for the full indicated fire resistance period, no correction is deemed necessary.

**Column P14 (84mm):**

Neither the individual nor the average thermocouple maximums were exceeded during the 240-minute test.

In accordance with the UL 1709 test standard, a calculation for any correction to the indicated fire resistance period was done. The correction factor was then mathematically added to the indicated fire resistance period, yielding the fire resistance period achieved by this specimen:

ITEM	DESCRIPTION	TEST VALUE
C	correction factor	-0.37 minutes -22 seconds
I	indicated fire-resistance period	240 minutes
A	area under the curve of indicated average	

**Intertek**



### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 9 of 95

	furnace temperature for the first three fourths of the indicated period	327951 (°F•min)
As	area under the standard furnace curve for the same part of the indicated period	328709 (°F•min)
	FIRE RESISTANCE PERIOD ACHIEVED BY THIS SPECIMEN ==>	240 minutes

Note: The standard specifies that the fire resistance be determined to the nearest integral minute. Consequently, if the correction factor is less than 30 seconds, and the test specimen met the criteria for the full indicated fire resistance period, no correction is deemed necessary.

#### Summary of fire resistance achieved by each column:

P2 (12mm).....67 minutes  
P5 (30mm) .....131 minutes  
P8A (48mm) .....184 minutes  
P8B (48mm) .....175 minutes  
P11 (66mm) .....240 minutes  
P14 (84mm) .....240 minutes

## 6 Conclusion

Intertek Testing Services NA (Intertek) conducted testing for Aspen Aerogels, Inc., on Pyrogel® XTF Insulation Material, to evaluate its fire resistance. Testing was conducted in accordance with UL 1709-05 Standard for Safety Rapid Rise Fire Tests of Protection Materials for Structural Steel. The P2 (12mm) column received a fire resistance rating of 67 minutes, the P5 (30mm) column received a fire resistance rating of 131 minutes, the P8A (48mm) column received a fire resistance rating of 184 minutes, the P8B (48mm) column received a fire resistance rating of 175 minutes, the P11 (66mm) column received a fire resistance rating of 240 minutes, and the P14 (84mm) column received a fire resistance rating of 240 minutes. This evaluation was completed on August 21, 2008.

The conclusions of this test report may not be used as part of the requirements for Intertek product certification. Authority to Mark must be issued for a product to become certified.

**Intertek**


**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 10 of 95

**INTERTEK TESTING SERVICES NA**

Reported by:

  
\_\_\_\_\_  
Michael A Brown  
Technical Writer

Reviewed by:

  
\_\_\_\_\_  
Mike Dey  
Project Manager, Fire Resistance

**Intertek**

**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 11 of 95


APPENDIX A  
Assembly Drawings

**Intertek**

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 12 of 95



INTERTEK TESTING SERVICES NA, INC.  
Project No. 3159033

Aspen Aerogels, Inc.

Fig. 1 Thermocouple Layout

**Intertek**




**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 13 of 95

**Example of the Application of Courses of Insulation:**




Intertek

#### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 14 of 95



- Cladding was 36" wide and long enough to enclose the column with a 6" longitudinal overlapping seam
- Using 3 strips of 36" on the 8' high column allowed for 6" circumferential overlapping seams

**Intertek**

**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 15 of 95

APPENDIX B  
Temperature Data

Intertek


**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 16 of 95

Aspen Aerogels, Inc.  
Project No. 3159033  
Furnace Interior Temperatures

21 August 2008



Intertek




**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 17 of 95

Aspen Aerogels, Inc.  
Project No. 3159033  
P2 Individual Temperatures

21 August 2008



Intertek


**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 18 of 95

Aspen Aerogels, Inc.  
Project No. 3159033  
P2 Max and Ave Temperatures

21 August 2008



Intertek


**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 19 of 95

Aspen Aerogels, Inc.  
Project No. 3159033  
P5 Individual Temperatures

21 August 2008



Intertek


**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 20 of 95

Aspen Aerogels, Inc.  
Project No. 3159033  
P5 Max and Ave Temperatures

21 August 2008



Intertek


**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 21 of 95

Aspen Aerogels, Inc.  
Project No. 3159033  
P8A Individual Temperatures

21 August 2008



Intertek




Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 22 of 95

Aspen Aerogels, Inc.  
Project No. 3159033  
P8A Max and Ave Temperatures

21 August 2008




**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 23 of 95

Aspen Aerogels, Inc.  
Project No. 3159033  
P8B Individual Temperatures

21 August 2008



Intertek


**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 24 of 95

Aspen Aerogels, Inc.  
Project No. 3159033  
P8B Max and Ave Temperatures

21 August 2008



Intertek


**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 25 of 95

Aspen Aerogels, Inc.  
Project No. 3159033  
P11 Individual Temperatures

21 August 2008



Intertek


**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 26 of 95

Aspen Aerogels, Inc.  
Project No. 3159033  
P11 Max and Ave Temperatures

21 August 2008



Intertek




**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 27 of 95

Aspen Aerogels, Inc.  
Project No. 3159033  
P14 Individual Temperatures

21 August 2008



Intertek


**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 28 of 95

Aspen Aerogels, Inc.  
Project No. 3159033  
P14 Max and Ave Temperatures

21 August 2008



Intertek

Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 29 of 95

21 August 2008

Time (min)	UL 1709 Std Average (°F)	Furnace Average (°F)	Furnace Probe #1 (°F)	Furnace Probe #2 (°F)	Furnace Probe #3 (°F)	Furnace Probe #4 (°F)	Furnace Probe #5 (°F)	Furnace Probe #6 (°F)	Furnace Probe #7 (°F)	Furnace Probe #8 (°F)	Furnace Probe #9 (°F)
0	100	84	84	84	84	84	84	84	badprobe	84	86
1	400	303	321	488	470	250	312	237	badprobe	187	186
2	800	531	614	758	885	806	479	481	badprobe	386	336
3	1400	990	957	1207	1130	998	937	1013	badprobe	881	791
4	1885	1457	1385	1590	1490	1494	1455	1501	badprobe	1429	1342
5	1917	1735	1621	1803	1775	1726	1794	1768	badprobe	1727	1654
6	1917	1853	1771	1903	1899	1842	1904	1867	badprobe	1856	1820
7	1917	1927	1851	1952	1975	1912	1974	1920	badprobe	1941	1903
8	1917	1946	1880	1949	1980	1927	1981	1953	badprobe	1958	1921
9	1917	1980	1897	1969	2007	1943	1994	1963	badprobe	1972	1943
10	1917	1980	1903	1967	2018	1939	1987	1956	badprobe	1985	1944
11	1917	1954	1903	1957	1994	1933	1962	1959	badprobe	1963	1939
12	1917	1957	1904	1962	2002	1935	1984	1957	badprobe	1967	1942
13	1917	1951	1897	1962	2004	1938	1980	1946	badprobe	1966	1938
14	1917	1923	1871	1906	1968	1898	1943	1909	badprobe	1927	1915
15	1917	1910	1891	1908	1969	1888	1950	1907	badprobe	1919	1904
16	1917	1912	1890	1922	1972	1886	1943	1886	badprobe	1915	1900
17	1917	1914	1892	1922	1969	1890	1942	1907	badprobe	1919	1903
18	1917	1917	1894	1924	1977	1893	1946	1905	badprobe	1921	1905
19	1917	1922	1873	1903	1974	1899	1949	1912	badprobe	1920	1910
20	1917	1925	1874	1907	1977	1903	1950	1917	badprobe	1930	1913
21	1917	1925	1881	1906	1908	1905	1901	1918	badprobe	1935	1915
22	1917	1922	1879	1933	1953	1900	1951	1916	badprobe	1930	1912
23	1917	1920	1878	1936	1944	1902	1950	1915	badprobe	1927	1910
24	1917	1923	1879	1940	1983	1900	1947	1914	badprobe	1930	1911
25	1917	1926	1886	1936	1954	1905	1950	1923	badprobe	1933	1914
26	1917	1930	1890	1941	1974	1908	1954	1920	badprobe	1935	1916
27	1917	1930	1894	1943	1950	1912	1959	1928	badprobe	1937	1920
28	1917	1923	1885	1940	1948	1904	1900	1914	badprobe	1938	1912
29	1917	1921	1887	1937	1949	1900	1947	1913	badprobe	1927	1909
30	1917	1924	1888	1909	1947	1903	1950	1921	badprobe	1928	1910
31	1917	1923	1890	1937	1943	1903	1949	1920	badprobe	1928	1911
32	1917	1927	1890	1942	1953	1908	1950	1918	badprobe	1930	1913
33	1917	1910	1887	1927	1943	1896	1940	1909	badprobe	1920	1905
34	1917	1907	1878	1923	1927	1898	1932	1900	badprobe	1911	1895
35	1917	1908	1878	1926	1933	1898	1934	1903	badprobe	1908	1893
36	1917	1908	1879	1924	1932	1889	1936	1901	badprobe	1908	1893
37	1917	1909	1883	1925	1931	1891	1935	1903	badprobe	1911	1894
38	1917	1916	1885	1933	1940	1899	1945	1910	badprobe	1915	1899
39	1917	1919	1892	1933	1932	1898	1944	1916	badprobe	1919	1901
40	1917	1921	1891	1941	1949	1904	1944	1915	badprobe	1920	1904
41	1917	1920	1893	1940	1939	1902	1947	1916	badprobe	1922	1906
42	1917	1924	1896	1942	1952	1905	1949	1919	badprobe	1923	1907
43	1917	1926	1898	1942	1942	1908	1954	1925	badprobe	1925	1910
44	1917	1928	1900	1947	1952	1910	1953	1922	badprobe	1926	1911
45	1917	1932	1906	1957	1955	1914	1956	1926	badprobe	1930	1914
46	1917	1935	1910	1961	1963	1915	1960	1927	badprobe	1931	1917
47	1917	1928	1904	1944	1950	1911	1954	1923	badprobe	1925	1913
48	1917	1923	1899	1941	1949	1902	1948	1919	badprobe	1920	1908
49	1917	1919	1897	1937	1944	1900	1943	1915	badprobe	1915	1902
50	1917	1918	1894	1940	1942	1899	1944	1912	badprobe	1915	1900
51	1917	1919	1896	1938	1939	1900	1942	1915	badprobe	1916	1900
52	1917	1917	1895	1936	1949	1898	1940	1912	badprobe	1911	1898
53	1917	1918	1894	1936	1945	1899	1941	1913	badprobe	1913	1899
54	1917	1918	1895	1941	1948	1894	1942	1915	badprobe	1911	1897
55	1917	1921	1897	1942	1953	1899	1943	1919	badprobe	1913	1898
56	1917	1920	1899	1942	1948	1900	1943	1917	badprobe	1915	1900
57	1917	1921	1900	1941	1945	1902	1944	1913	badprobe	1916	1901
58	1917	1921	1899	1938	1947	1903	1946	1915	badprobe	1915	1901
59	1917	1921	1899	1942	1952	1901	1942	1914	badprobe	1915	1900
60	1917	1920	1899	1945	1942	1900	1944	1912	badprobe	1915	1899
61	1917	1919	1897	1940	1947	1901	1942	1912	badprobe	1912	1899
62	1917	1918	1896	1941	1938	1900	1943	1914	badprobe	1911	1898
63	1917	1919	1898	1942	1941	1901	1942	1917	badprobe	1915	1899

Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 30 of 95

21 August 2008

Time (min)	UL 1709 Std Average (°F)	Furnace Average (°F)	Furnace Probe #1 (°F)	Furnace Probe #2 (°F)	Furnace Probe #3 (°F)	Furnace Probe #4 (°F)	Furnace Probe #5 (°F)	Furnace Probe #6 (°F)	Furnace Probe #7 (°F)	Furnace Probe #8 (°F)	Furnace Probe #9 (°F)
54	1917	1521	1900	1944	1950	1902	1943	1912	badprobe	1914	1899
55	1917	1519	1898	1940	1943	1901	1942	1917	badprobe	1912	1898
56	1917	1520	1898	1909	1943	1902	1948	1917	badprobe	1915	1900
57	1917	1522	1900	1942	1950	1903	1945	1920	badprobe	1915	1901
58	1917	1522	1902	1942	1942	1906	1946	1919	badprobe	1916	1902
59	1917	1523	1904	1943	1947	1907	1947	1917	badprobe	1918	1902
70	1917	1523	1902	1941	1950	1906	1947	1919	badprobe	1916	1905
71	1917	1523	1900	1947	1942	1906	1950	1915	badprobe	1917	1906
72	1917	1521	1899	1942	1943	1903	1945	1916	badprobe	1914	1903
73	1917	1518	1898	1941	1941	1901	1942	1909	badprobe	1911	1899
74	1917	1518	1898	1941	1932	1898	1943	1910	badprobe	1910	1898
75	1917	1518	1895	1940	1955	1899	1941	1903	badprobe	1910	1896
76	1917	1517	1897	1937	1937	1899	1942	1917	badprobe	1910	1897
77	1917	1518	1897	1906	1944	1898	1940	1909	badprobe	1908	1896
78	1917	1514	1895	1901	1955	1897	1940	1908	badprobe	1909	1893
79	1917	1519	1893	1906	1942	1898	1939	1909	badprobe	1908	1893
80	1917	1518	1895	1939	1945	1898	1938	1912	badprobe	1907	1893
81	1917	1515	1896	1935	1939	1899	1938	1907	badprobe	1909	1894
82	1917	1517	1894	1938	1945	1899	1940	1914	badprobe	1909	1894
83	1917	1517	1895	1938	1944	1901	1941	1912	badprobe	1908	1894
84	1917	1513	1896	1938	1941	1898	1941	1912	badprobe	1908	1894
85	1917	1510	1892	1940	1942	1898	1941	1913	badprobe	1907	1894
86	1917	1518	1894	1941	1935	1902	1940	1912	badprobe	1909	1894
87	1917	1518	1896	1941	1946	1901	1943	1911	badprobe	1909	1896
88	1917	1519	1898	1942	1947	1901	1942	1911	badprobe	1912	1896
89	1917	1518	1898	1942	1939	1902	1943	1915	badprobe	1911	1897
90	1917	1519	1896	1941	1940	1901	1944	1915	badprobe	1911	1897
91	1917	1518	1898	1939	1945	1902	1942	1912	badprobe	1911	1897
92	1917	1520	1898	1943	1938	1905	1945	1915	badprobe	1913	1896
93	1917	1522	1902	1945	1941	1905	1948	1917	badprobe	1916	1901
94	1917	1523	1902	1944	1949	1907	1949	1917	badprobe	1915	1901
95	1917	1522	1902	1943	1947	1904	1948	1918	badprobe	1915	1900
96	1917	1522	1903	1941	1957	1904	1948	1914	badprobe	1914	1899
97	1917	1522	1903	1940	1945	1906	1948	1921	badprobe	1915	1900
98	1917	1521	1901	1938	1945	1905	1947	1917	badprobe	1914	1900
99	1917	1523	1904	1947	1942	1907	1948	1917	badprobe	1914	1902
100	1917	1524	1905	1944	1954	1905	1947	1919	badprobe	1915	1901
101	1917	1521	1903	1942	1949	1905	1948	1915	badprobe	1913	1901
102	1917	1522	1901	1942	1949	1905	1945	1918	badprobe	1914	1901
103	1917	1520	1899	1944	1947	1904	1944	1912	badprobe	1912	1900
104	1917	1521	1899	1941	1959	1904	1945	1913	badprobe	1913	1900
105	1917	1520	1901	1941	1943	1906	1943	1917	badprobe	1912	1900
106	1917	1521	1901	1941	1945	1905	1944	1917	badprobe	1913	1900
107	1917	1522	1903	1941	1951	1907	1945	1915	badprobe	1914	1901
108	1917	1524	1904	1944	1955	1908	1948	1920	badprobe	1916	1902
109	1917	1523	1904	1943	1948	1907	1950	1916	badprobe	1916	1903
110	1917	1520	1902	1939	1940	1906	1943	1915	badprobe	1913	1901
111	1917	1521	1901	1939	1943	1905	1946	1919	badprobe	1914	1901
112	1917	1521	1901	1943	1941	1905	1944	1918	badprobe	1913	1900
113	1917	1521	1901	1940	1946	1905	1946	1917	badprobe	1913	1899
114	1917	1519	1901	1941	1938	1904	1943	1914	badprobe	1911	1899
115	1917	1518	1900	1938	1938	1903	1942	1911	badprobe	1911	1898
116	1917	1518	1901	1936	1940	1904	1941	1913	badprobe	1910	1899
117	1917	1520	1901	1939	1946	1906	1943	1917	badprobe	1911	1900
118	1917	1520	1900	1939	1944	1903	1944	1917	badprobe	1913	1899
119	1917	1522	1900	1938	1957	1904	1947	1915	badprobe	1913	1900
120	1917	1520	1902	1938	1938	1905	1944	1919	badprobe	1915	1901
121	1917	1521	1904	1938	1947	1906	1945	1914	badprobe	1913	1901
122	1917	1522	1903	1940	1951	1906	1945	1915	badprobe	1913	1901
123	1917	1522	1905	1940	1943	1908	1947	1918	badprobe	1916	1902
124	1917	1524	1904	1942	1949	1909	1947	1919	badprobe	1916	1903
125	1917	1525	1906	1943	1949	1910	1949	1918	badprobe	1918	1905
126	1917	1523	1905	1942	1949	1906	1946	1918	badprobe	1915	1903
127	1917	1521	1903	1939	1943	1907	1946	1915	badprobe	1916	1902

Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 31 of 95

21 August 2008

Time (min)	UL 1709 Std Average (°F)	Furnace Average (°F)	Furnace Probe #1 (°F)	Furnace Probe #2 (°F)	Furnace Probe #3 (°F)	Furnace Probe #4 (°F)	Furnace Probe #5 (°F)	Furnace Probe #6 (°F)	Furnace Probe #7 (°F)	Furnace Probe #8 (°F)	Furnace Probe #9 (°F)
128	1917	1624	1905	1940	1959	1906	1947	1918	bad/probe	1915	1903
129	1917	1622	1903	1941	1943	1908	1947	1917	bad/probe	1917	1903
130	1917	1623	1903	1939	1947	1908	1948	1918	bad/probe	1918	1903
131	1917	1623	1904	1939	1947	1907	1948	1916	bad/probe	1916	1903
132	1917	1624	1905	1940	1945	1910	1947	1919	bad/probe	1920	1905
133	1917	1624	1907	1939	1944	1910	1947	1917	bad/probe	1919	1905
134	1917	1624	1907	1937	1945	1909	1947	1920	bad/probe	1919	1905
135	1917	1623	1909	1965	1952	1904	1943	1918	bad/probe	1913	1901
136	1917	1624	1912	1956	1948	1905	1942	1917	bad/probe	1911	1900
137	1917	1624	1914	1963	1947	1902	1942	1914	bad/probe	1912	1898
138	1917	1625	1915	1957	1954	1906	1942	1919	bad/probe	1911	1900
139	1917	1621	1912	1949	1946	1901	1938	1917	bad/probe	1910	1897
140	1917	1618	1910	1954	1938	1897	1935	1909	bad/probe	1906	1893
141	1917	1616	1903	1963	1943	1893	1932	1909	bad/probe	1902	1890
142	1917	1614	1904	1947	1933	1894	1933	1905	bad/probe	1903	1890
143	1917	1614	1901	1958	1931	1893	1932	1908	bad/probe	1900	1889
144	1917	1612	1901	1948	1932	1893	1931	1904	bad/probe	1901	1888
145	1917	1613	1902	1960	1928	1895	1932	1905	bad/probe	1902	1889
146	1917	1615	1903	1963	1935	1893	1934	1908	bad/probe	1903	1891
147	1917	1615	1905	1966	1935	1895	1931	1905	bad/probe	1902	1889
148	1917	1614	1904	1963	1934	1894	1932	1905	bad/probe	1902	1890
149	1917	1613	1901	1957	1933	1893	1930	1904	bad/probe	1900	1889
150	1917	1615	1904	1952	1945	1893	1932	1905	bad/probe	1902	1889
151	1917	1617	1905	1963	1943	1895	1934	1911	bad/probe	1904	1891
152	1917	1618	1906	1969	1945	1895	1934	1910	bad/probe	1903	1891
153	1917	1619	1905	1963	1939	1896	1932	1907	bad/probe	1903	1891
154	1917	1617	1906	1965	1942	1895	1933	1909	bad/probe	1904	1892
155	1917	1617	1907	1959	1935	1896	1935	1910	bad/probe	1903	1891
156	1917	1617	1904	1956	1935	1898	1934	1908	bad/probe	1905	1892
157	1917	1619	1906	1966	1946	1897	1935	1913	bad/probe	1904	1893
158	1917	1617	1906	1967	1941	1898	1934	1907	bad/probe	1904	1892
159	1917	1619	1908	1968	1939	1897	1935	1909	bad/probe	1905	1893
160	1917	1620	1909	1965	1951	1897	1935	1911	bad/probe	1905	1894
161	1917	1620	1907	1965	1949	1899	1936	1910	bad/probe	1906	1894
162	1917	1620	1910	1966	1948	1900	1937	1909	bad/probe	1907	1895
163	1917	1620	1908	1955	1948	1898	1937	1909	bad/probe	1908	1895
164	1917	1619	1912	1946	1949	1899	1937	1912	bad/probe	1907	1895
165	1917	1620	1911	1949	1947	1899	1937	1914	bad/probe	1907	1895
166	1917	1622	1910	1965	1944	1902	1939	1913	bad/probe	1909	1896
167	1917	1620	1908	1957	1942	1899	1938	1911	bad/probe	1907	1896
168	1917	1622	1908	1959	1949	1902	1939	1915	bad/probe	1909	1897
169	1917	1623	1912	1968	1950	1900	1938	1913	bad/probe	1910	1897
170	1917	1623	1912	1965	1945	1902	1939	1913	bad/probe	1910	1896
171	1917	1619	1910	1965	1944	1898	1935	1910	bad/probe	1907	1895
172	1917	1617	1906	1967	1941	1895	1933	1905	bad/probe	1904	1892
173	1917	1614	1904	1954	1940	1893	1929	1901	bad/probe	1901	1889
174	1917	1614	1903	1946	1943	1894	1930	1904	bad/probe	1901	1889
175	1917	1613	1905	1944	1942	1894	1929	1904	bad/probe	1900	1889
176	1917	1616	1905	1958	1936	1891	1931	1903	bad/probe	1903	1889
177	1917	1615	1903	1961	1942	1894	1933	1907	bad/probe	1903	1890
178	1917	1614	1904	1958	1924	1896	1933	1904	bad/probe	1904	1891
179	1917	1617	1905	1965	1942	1896	1932	1907	bad/probe	1904	1891
180	1917	1615	1906	1963	1939	1895	1931	1905	bad/probe	1904	1891
181	1917	1617	1906	1968	1944	1896	1933	1908	bad/probe	1905	1892
182	1917	1617	1907	1950	1944	1898	1933	1908	bad/probe	1905	1894
183	1917	1619	1906	1906	1944	1899	1934	1911	bad/probe	1906	1894
184	1917	1617	1909	1951	1938	1897	1934	1913	bad/probe	1905	1894
185	1917	1619	1908	1969	1940	1899	1937	1912	bad/probe	1907	1895
186	1917	1620	1908	1967	1943	1899	1936	1910	bad/probe	1906	1895
187	1917	1617	1909	1905	1951	1897	1934	1909	bad/probe	1906	1894
188	1917	1619	1907	1939	1941	1899	1934	1908	bad/probe	1907	1894
189	1917	1621	1907	1969	1948	1896	1934	1910	bad/probe	1907	1894
190	1917	1618	1907	1962	1937	1900	1934	1910	bad/probe	1908	1895
191	1917	1619	1910	1947	1945	1901	1935	1913	bad/probe	1908	1896



Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 32 of 95

21 August 2008

Time (min)	UL 1709 Std Average (°F)	Furnace Average (°F)	Furnace Probe #1 (°F)	Furnace Probe #2 (°F)	Furnace Probe #3 (°F)	Furnace Probe #4 (°F)	Furnace Probe #5 (°F)	Furnace Probe #6 (°F)	Furnace Probe #7 (°F)	Furnace Probe #8 (°F)	Furnace Probe #9 (°F)
192	1917	1918	1911	1926	1948	1899	1935	1908	badprobe	1907	1896
193	1917	1917	1905	1964	1941	1807	1934	1909	badprobe	1905	1893
194	1917	1917	1908	1933	1948	1899	1938	1907	badprobe	1907	1895
195	1917	1915	1912	1940	1939	1900	1934	1923	badprobe	1907	1896
196	1917	1917	1911	1910	1940	1901	1936	1930	badprobe	1909	1896
197	1917	1919	1912	1907	1950	1903	1938	1933	badprobe	1909	1899
198	1917	1918	1912	1908	1945	1902	1939	1933	badprobe	1909	1899
199	1917	1918	1912	1908	1951	1900	1938	1935	badprobe	1908	1897
200	1917	1918	1913	1908	1943	1902	1938	1934	badprobe	1909	1898
201	1917	1918	1913	1908	1943	1903	1938	1936	badprobe	1909	1899
202	1917	1918	1913	1907	1943	1901	1938	1936	badprobe	1910	1899
203	1917	1921	1913	1908	1955	1903	1939	1937	badprobe	1910	1900
204	1917	1920	1913	1907	1950	1902	1939	1937	badprobe	1910	1900
205	1917	1921	1915	1910	1947	1904	1940	1936	badprobe	1912	1901
206	1917	1919	1913	1908	1943	1903	1938	1937	badprobe	1910	1900
207	1917	1922	1916	1908	1964	1905	1940	1939	badprobe	1911	1901
208	1917	1920	1914	1910	1948	1903	1940	1936	badprobe	1911	1900
209	1917	1922	1915	1908	1957	1904	1940	1937	badprobe	1912	1901
210	1917	1922	1916	1909	1946	1908	1942	1939	badprobe	1913	1902
211	1917	1921	1915	1909	1953	1903	1940	1936	badprobe	1911	1901
212	1917	1922	1915	1909	1959	1905	1940	1937	badprobe	1913	1901
213	1917	1921	1915	1909	1949	1903	1939	1936	badprobe	1912	1901
214	1917	1921	1916	1907	1942	1906	1940	1936	badprobe	1913	1902
215	1917	1921	1915	1908	1950	1903	1940	1939	badprobe	1912	1901
216	1917	1921	1915	1909	1949	1903	1941	1936	badprobe	1912	1901
217	1917	1922	1916	1909	1949	1906	1942	1939	badprobe	1914	1903
218	1917	1923	1917	1911	1949	1908	1943	1940	badprobe	1914	1904
219	1917	1923	1917	1908	1950	1907	1942	1940	badprobe	1913	1904
220	1917	1917	1911	1905	1939	1901	1935	1934	badprobe	1908	1900
221	1917	1914	1908	1900	1936	1899	1933	1932	badprobe	1905	1896
222	1917	1912	1906	1899	1937	1895	1931	1930	badprobe	1902	1893
223	1917	1913	1906	1899	1944	1895	1931	1930	badprobe	1903	1893
224	1917	1913	1908	1899	1939	1897	1932	1933	badprobe	1904	1894
225	1917	1912	1906	1901	1935	1896	1932	1929	badprobe	1904	1894
226	1917	1913	1907	1899	1941	1898	1932	1931	badprobe	1905	1894
227	1917	1914	1908	1897	1942	1897	1933	1933	badprobe	1906	1895
228	1917	1914	1909	1901	1939	1898	1934	1932	badprobe	1906	1896
229	1917	1916	1909	1900	1946	1899	1934	1933	badprobe	1907	1896
230	1917	1915	1910	1903	1933	1899	1934	1933	badprobe	1907	1897
231	1917	1915	1910	1902	1942	1899	1934	1933	badprobe	1907	1896
232	1917	1916	1909	1902	1941	1898	1934	1934	badprobe	1908	1897
233	1917	1913	1908	1902	1933	1897	1934	1932	badprobe	1906	1896
234	1917	1916	1911	1902	1948	1898	1934	1934	badprobe	1906	1896
235	1917	1915	1910	1902	1938	1898	1934	1934	badprobe	1907	1897
236	1917	1916	1910	1903	1945	1898	1933	1933	badprobe	1906	1896
237	1917	1917	1911	1904	1944	1899	1937	1936	badprobe	1909	1898
238	1917	1918	1911	1901	1939	1900	1936	1935	badprobe	1908	1897
239	1917	1917	1912	1904	1948	1900	1935	1934	badprobe	1907	1897
240	1917	1917	1911	1904	1944	1900	1936	1934	badprobe	1907	1897

Max Temp  
Max Allowed

Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 33 of 95

21 August 2008

Time (min)	P2 P2Max (°F)	P2 AAAvs (°F)	P2 Sec A-A TC #1 (°F)	P2 Sec A-A TC #2 (°F)	P2 Sec A-A TC #3 (°F)	P2 Sec A-A TC #4 (°F)	P2 Sec A-A TC #5 (°F)	P2 BBAvs (°F)	P2 Sec B-B TC #6 (°F)	P2 Sec B-B TC #7 (°F)	P2 Sec B-B TC #8 (°F)	P2 CCAvs (°F)	P2 Sec C-C TC #9 (°F)
0	83	83	83	83	83	83	83	82	83	82	82	83	badAc
1	83	83	83	83	83	83	83	82	83	82	82	82	badAc
2	83	83	83	83	83	83	83	83	83	83	82	83	badAc
3	84	83	83	83	84	83	83	83	84	82	82	83	badAc
4	87	84	84	83	87	84	83	84	86	83	83	85	badAc
5	92	85	88	82	92	86	84	85	89	80	88	86	badAc
6	103	92	99	82	103	88	88	92	96	80	99	91	badAc
7	122	102	116	82	122	96	95	102	110	81	116	99	badAc
8	148	117	140	84	148	107	108	115	128	82	138	110	badAc
9	169	131	160	86	169	119	118	129	147	84	157	123	badAc
10	191	148	189	89	191	133	131	143	165	86	176	135	badAc
11	217	163	214	93	217	147	145	157	182	93	195	149	badAc
12	242	180	236	99	242	161	159	170	197	96	216	166	badAc
13	268	198	261	106	268	175	172	186	217	105	237	182	badAc
14	289	212	285	113	289	186	186	203	238	113	258	197	badAc
15	312	228	300	122	312	204	201	220	260	121	280	212	badAc
16	333	243	318	130	333	220	218	237	276	131	300	228	badAc
17	354	260	337	140	354	236	231	253	298	140	320	242	badAc
18	375	278	356	150	375	252	248	269	317	151	340	257	badAc
19	398	292	375	161	398	269	261	288	336	162	360	273	badAc
20	417	308	388	173	417	285	277	303	355	173	380	288	badAc
21	437	325	411	184	437	301	292	320	374	185	401	305	badAc
22	458	342	429	197	458	318	308	337	393	197	421	320	badAc
23	477	358	446	209	477	334	323	354	411	210	442	336	badAc
24	498	374	463	222	498	351	338	371	429	223	461	350	badAc
25	515	390	480	235	515	367	353	388	447	235	481	365	badAc
26	534	405	496	249	534	384	368	405	465	250	500	380	badAc
27	552	422	513	262	552	400	383	422	483	263	519	398	badAc
28	570	438	529	276	570	417	399	439	501	277	539	411	badAc
29	588	454	545	290	588	433	414	455	518	290	557	426	badAc
30	605	469	561	304	605	448	428	472	535	304	577	442	badAc
31	622	485	575	318	622	465	443	488	552	318	595	458	badAc
32	639	500	592	332	639	481	458	505	566	332	614	473	badAc
33	655	515	607	345	655	497	473	521	586	348	632	488	badAc
34	671	530	622	359	671	512	487	537	602	360	649	503	badAc
35	688	545	638	373	688	527	502	553	618	375	666	518	badAc
36	701	559	651	387	701	542	516	568	634	389	682	533	badAc
37	718	574	665	400	718	557	530	584	650	400	699	548	badAc
38	731	588	679	414	731	572	544	599	665	417	714	563	badAc
39	745	602	694	427	745	587	558	614	681	431	731	578	badAc
40	761	616	708	440	761	601	572	629	696	445	747	592	badAc
41	778	631	722	454	778	616	585	645	712	459	763	607	badAc
42	791	645	735	467	791	630	599	659	727	472	779	622	badAc
43	808	659	751	480	808	644	613	675	743	485	795	636	badAc
44	821	673	765	492	821	658	627	689	758	499	810	651	badAc
45	835	685	779	505	835	672	640	704	773	513	826	666	badAc
46	850	701	794	518	850	687	654	719	789	525	842	680	badAc
47	865	714	808	530	865	700	667	733	804	539	857	694	badAc
48	879	728	823	543	879	714	681	748	819	552	872	709	badAc
49	893	741	838	555	893	728	694	762	834	565	887	723	badAc
50	908	754	850	568	908	741	707	776	848	578	902	737	badAc
51	920	767	863	580	920	754	720	789	862	590	916	750	badAc
52	934	780	877	592	934	767	733	803	876	603	930	763	badAc
53	948	793	890	604	948	780	746	816	890	615	944	777	badAc
54	962	809	903	616	959	793	758	830	903	628	958	790	badAc
55	978	819	916	628	972	806	771	843	917	640	971	803	badAc
56	990	831	929	639	984	818	783	855	930	652	984	816	badAc
57	1004	843	941	651	997	831	798	869	944	664	998	829	badAc
58	1017	855	954	663	1009	843	808	881	957	676	1011	842	badAc
59	1031	867	967	674	1021	855	820	894	970	688	1024	855	badAc
60	1044	879	979	685	1033	867	832	908	983	699	1038	867	badAc
61	1057	891	992	697	1045	879	844	918	995	711	1049	879	badAc
62	1070	903	1004	708	1057	891	856	930	1008	722	1061	892	badAc
63	1082	915	1016	719	1068	902	868	943	1020	734	1074	903	badAc

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 34 of 95

21 August 2008

Time (min)	P2 P2Max (°F)	P2 AAve (°F)	P2 Sec A-A TC #1 (°F)	P2 Sec A-A TC #2 (°F)	P2 Sec A-A TC #3 (°F)	P2 Sec A-A TC #4 (°F)	P2 Sec A-A TC #5 (°F)	P2 BBave (°F)	P2 Sec B-B TC #6 (°F)	P2 Sec B-B TC #7 (°F)	P2 Sec B-B TC #8 (°F)	P2 CCAve (°F)	P2 Sec C-C TC #9 (°F)
54	1065	929	1029	730	1080	914	879	954	1033	745	1085	916	bad/c
55	1107	938	1040	741	1091	926	891	968	1048	758	1097	927	bad/c
56	1119	949	1052	751	1102	936	903	978	1057	767	1110	939	bad/c
57	1132	960	1064	762	1113	946	914	989	1069	778	1121	951	bad/c
58	1143	971	1078	773	1124	959	925	1001	1081	789	1133	962	bad/c
59	1156	982	1089	783	1134	969	937	1012	1092	800	1144	974	bad/c
60	1167	993	1100	793	1145	980	948	1023	1104	810	1156	985	bad/c
71	1179	1004	1111	804	1155	991	959	1035	1116	821	1167	997	bad/c
72	1169	1015	1123	814	1166	1001	970	1045	1127	831	1178	1007	bad/c
73	1202	1026	1134	824	1176	1012	981	1056	1138	842	1189	1018	bad/c
74	1213	1038	1145	834	1188	1022	992	1067	1149	852	1199	1029	bad/c
75	1223	1049	1156	844	1195	1032	1003	1077	1159	862	1209	1039	bad/c
76	1234	1059	1167	854	1205	1042	1013	1087	1170	872	1220	1050	bad/c
77	1245	1069	1177	864	1214	1052	1024	1098	1180	883	1230	1061	bad/c
78	1255	1079	1188	873	1223	1061	1034	1107	1190	892	1240	1071	bad/c
79	1265	1089	1198	883	1232	1071	1044	1117	1200	902	1249	1081	bad/c
80	1275	1095	1208	892	1241	1080	1054	1127	1209	912	1259	1091	bad/c
81	1284	1105	1218	902	1250	1090	1064	1138	1219	921	1268	1100	bad/c
82	1294	1114	1228	911	1259	1098	1074	1145	1228	931	1277	1110	bad/c
83	1303	1124	1238	920	1268	1108	1084	1155	1238	940	1288	1119	bad/c
84	1312	1132	1247	929	1278	1117	1093	1164	1247	950	1295	1128	bad/c
85	1321	1141	1256	938	1285	1125	1103	1173	1256	959	1304	1138	bad/c
86	1329	1150	1266	947	1293	1134	1112	1182	1265	968	1312	1148	bad/c
87	1338	1159	1274	956	1302	1143	1121	1190	1274	977	1320	1154	bad/c
88	1343	1168	1283	965	1310	1151	1130	1198	1282	986	1328	1163	bad/c
89	1350	1177	1292	974	1319	1160	1139	1208	1291	995	1332	1171	bad/c
90	1357	1185	1301	982	1326	1168	1148	1213	1296	1004	1337	1179	bad/c
91	1365	1193	1309	991	1333	1178	1157	1221	1308	1013	1342	1187	bad/c
92	1373	1202	1318	1000	1340	1184	1166	1228	1316	1021	1348	1196	bad/c
93	1381	1209	1326	1008	1348	1192	1174	1236	1324	1030	1355	1204	bad/c
94	1389	1217	1333	1016	1352	1199	1183	1244	1331	1038	1362	1212	bad/c
95	1397	1224	1340	1025	1358	1207	1191	1252	1338	1047	1370	1221	bad/c
96	1405	1232	1347	1033	1365	1215	1199	1259	1344	1055	1377	1229	bad/c
97	1413	1239	1353	1042	1371	1222	1207	1268	1349	1064	1384	1238	bad/c
98	1421	1248	1359	1050	1377	1230	1215	1273	1355	1072	1391	1246	bad/c
99	1430	1254	1366	1058	1384	1237	1223	1280	1361	1080	1398	1255	bad/c
100	1438	1260	1372	1065	1390	1244	1230	1287	1367	1088	1406	1263	bad/c
101	1447	1268	1379	1074	1396	1251	1238	1295	1373	1097	1414	1272	bad/c
102	1455	1274	1385	1082	1403	1257	1245	1302	1379	1105	1422	1280	bad/c
103	1463	1281	1391	1090	1409	1264	1253	1309	1385	1113	1430	1289	bad/c
104	1471	1288	1398	1098	1416	1270	1259	1316	1391	1121	1437	1297	bad/c
105	1480	1296	1406	1106	1423	1277	1267	1324	1398	1129	1446	1306	bad/c
106	1488	1302	1412	1114	1429	1283	1273	1332	1405	1137	1453	1314	bad/c
107	1498	1309	1419	1122	1438	1289	1280	1339	1411	1145	1460	1322	bad/c
108	1504	1316	1426	1130	1443	1295	1287	1346	1418	1153	1468	1330	bad/c
109	1512	1322	1433	1137	1450	1300	1292	1354	1425	1161	1476	1339	bad/c
110	1520	1329	1440	1145	1457	1306	1299	1361	1432	1169	1483	1347	bad/c
111	1527	1336	1447	1153	1464	1311	1304	1368	1439	1176	1490	1354	bad/c
112	1535	1342	1454	1160	1470	1316	1310	1376	1447	1184	1498	1362	bad/c
113	1542	1348	1461	1168	1478	1321	1316	1383	1453	1191	1505	1370	bad/c
114	1550	1354	1467	1175	1483	1326	1321	1390	1460	1199	1512	1378	bad/c
115	1557	1361	1474	1183	1489	1331	1326	1397	1467	1207	1518	1385	bad/c
116	1564	1367	1481	1190	1495	1336	1331	1405	1474	1214	1526	1393	bad/c
117	1571	1372	1487	1197	1502	1340	1338	1411	1481	1221	1532	1400	bad/c
118	1578	1379	1494	1204	1508	1345	1341	1418	1487	1228	1539	1407	bad/c
119	1586	1384	1500	1211	1514	1351	1346	1425	1494	1235	1546	1415	bad/c
120	1593	1390	1506	1218	1521	1357	1350	1431	1500	1242	1552	1422	bad/c
121	1601	1397	1513	1225	1527	1364	1356	1438	1507	1249	1559	1429	bad/c
122	1608	1403	1519	1232	1533	1370	1362	1445	1513	1256	1566	1436	bad/c
123	1615	1409	1525	1239	1539	1376	1368	1452	1520	1262	1573	1443	bad/c
124	1623	1416	1531	1246	1545	1383	1375	1459	1526	1269	1581	1451	bad/c
125	1631	1422	1538	1252	1551	1390	1381	1466	1533	1276	1588	1458	bad/c
126	1640	1429	1544	1258	1557	1396	1387	1472	1539	1282	1595	1466	bad/c
127	1647	1435	1550	1264	1563	1405	1395	1479	1545	1289	1603	1473	bad/c

#### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 35 of 95

21 August 2008

Time (min)	P2 P2Max (°F)	P2 AAve (°F)	P2 TC #1 (°F)	P2 TC #2 (°F)	P2 TC #3 (°F)	P2 TC #4 (°F)	P2 TC #5 (°F)	P2 BBave (°F)	P2 TC #6 (°F)	P2 TC #7 (°F)	P2 TC #8 (°F)	P2 CCAve (°F)	P2 TC #9 (°F)	P2 Sec C-C (°F)
128	1853	1442	1556	1271	1569	1412	1401	1485	1551	1295	1810	1479	bedAc	
129	1861	1449	1562	1277	1575	1420	1409	1492	1557	1301	1817	1486	bedAc	
130	1869	1455	1568	1283	1581	1427	1416	1498	1563	1307	1824	1493	bedAc	
131	1878	1462	1574	1289	1587	1434	1424	1505	1570	1312	1832	1499	bedAc	
132	1883	1468	1580	1294	1594	1441	1431	1511	1576	1317	1839	1505	bedAc	
133	1889	1475	1587	1300	1601	1448	1438	1517	1583	1322	1846	1510	bedAc	
134	1897	1481	1593	1305	1607	1455	1445	1523	1590	1327	1853	1517	bedAc	
135	1705	1488	1600	1311	1614	1462	1452	1529	1596	1332	1860	1523	bedAc	
136	1712	1494	1607	1316	1620	1469	1459	1535	1603	1338	1866	1529	bedAc	
137	1718	1500	1613	1321	1626	1475	1466	1541	1610	1343	1873	1534	bedAc	
138	1725	1506	1620	1325	1632	1482	1473	1547	1617	1344	1879	1540	bedAc	
139	1731	1513	1626	1330	1639	1489	1479	1552	1623	1349	1885	1546	bedAc	
140	1737	1519	1633	1334	1644	1496	1486	1558	1630	1354	1891	1553	bedAc	
141	1743	1524	1639	1338	1650	1502	1492	1565	1636	1361	1897	1560	bedAc	
142	1749	1530	1644	1342	1655	1509	1499	1571	1642	1369	1902	1567	bedAc	
143	1753	1535	1650	1346	1661	1515	1505	1577	1648	1377	1907	1573	bedAc	
144	1759	1541	1655	1349	1666	1522	1511	1584	1654	1385	1912	1581	bedAc	
145	1765	1546	1661	1353	1671	1528	1518	1590	1660	1393	1918	1589	bedAc	
146	1768	1552	1667	1359	1677	1534	1524	1597	1666	1402	1923	1595	bedAc	
147	1774	1558	1672	1365	1682	1541	1530	1604	1671	1412	1928	1604	bedAc	
148	1780	1564	1677	1372	1687	1547	1537	1610	1677	1421	1933	1612	bedAc	
149	1782	1570	1683	1378	1692	1554	1543	1617	1682	1431	1938	1617	bedAc	
150	1789	1576	1688	1385	1697	1561	1550	1624	1688	1440	1943	1626	bedAc	
151	1792	1582	1694	1392	1702	1568	1556	1631	1694	1450	1948	1632	bedAc	
152	1798	1589	1699	1400	1707	1575	1563	1637	1699	1459	1953	1640	bedAc	
153	1801	1595	1704	1406	1712	1582	1571	1643	1704	1468	1957	1646	bedAc	
154	1808	1602	1710	1416	1717	1589	1578	1650	1710	1477	1962	1653	bedAc	
155	1810	1608	1714	1424	1722	1596	1585	1658	1715	1489	1967	1660	bedAc	
156	1814	1615	1719	1432	1727	1604	1593	1662	1720	1495	1971	1666	bedAc	
157	1818	1621	1724	1440	1732	1611	1600	1668	1726	1503	1976	1673	bedAc	
158	1821	1628	1729	1449	1738	1617	1607	1674	1730	1512	1980	1679	bedAc	
159	1826	1634	1734	1457	1741	1624	1615	1680	1736	1521	1984	1685	bedAc	
160	1829	1640	1738	1465	1745	1631	1622	1686	1741	1529	1988	1691	bedAc	
161	1833	1646	1743	1473	1750	1637	1629	1692	1746	1537	1992	1697	bedAc	
162	1838	1652	1748	1480	1754	1644	1636	1697	1750	1546	1996	1703	bedAc	
163	1838	1658	1752	1488	1759	1650	1643	1703	1755	1555	1999	1709	bedAc	
164	1840	1664	1757	1495	1763	1656	1650	1709	1760	1564	2004	1716	bedAc	
165	1844	1670	1761	1504	1767	1662	1656	1715	1764	1574	2008	1722	bedAc	
166	1848	1676	1765	1511	1771	1668	1663	1721	1769	1584	2011	1729	bedAc	
167	1849	1681	1769	1519	1775	1673	1669	1727	1773	1594	2014	1735	bedAc	
168	1852	1689	1773	1526	1779	1679	1675	1733	1777	1605	2018	1741	bedAc	
169	1859	1692	1778	1534	1783	1685	1681	1739	1782	1615	2021	1748	bedAc	
170	1858	1697	1782	1541	1787	1690	1687	1745	1786	1624	2024	1753	bedAc	
171	1859	1703	1785	1548	1791	1695	1694	1750	1790	1634	2027	1758	bedAc	
172	1860	1707	1788	1556	1794	1700	1699	1756	1794	1643	2030	1762	bedAc	
173	1860	1712	1791	1564	1797	1704	1705	1760	1797	1651	2031	1766	bedAc	
174	1861	1717	1794	1572	1800	1709	1710	1764	1800	1659	2034	1770	bedAc	
175	1863	1722	1796	1581	1802	1714	1715	1769	1804	1668	2035	1774	bedAc	
176	1865	1728	1799	1590	1805	1718	1720	1774	1807	1676	2038	1779	bedAc	
177	1869	1732	1802	1600	1808	1723	1726	1778	1810	1684	2040	1783	bedAc	
178	1868	1737	1805	1609	1811	1728	1731	1782	1813	1692	2042	1787	bedAc	
179	1869	1742	1807	1619	1814	1733	1735	1787	1816	1700	2044	1791	bedAc	
180	1863	1751	1803	1628	1817	1737	1740	1791	1819	1707	2046	1795	bedAc	
181	1869	1759	1809	1637	1819	1742	1746	1795	1822	1714	2048	1799	bedAc	
182	1901	1773	1801	1645	1822	1746	1750	1799	1825	1722	2051	1803	bedAc	
183	1902	1777	1802	1654	1825	1751	1755	1803	1828	1729	2052	1807	bedAc	
184	1904	1782	1804	1661	1828	1755	1760	1807	1831	1735	2055	1810	bedAc	
185	1905	1786	1806	1669	1830	1759	1765	1811	1834	1742	2057	1814	bedAc	
186	1908	1790	1806	1677	1833	1764	1769	1814	1837	1748	2058	1817	bedAc	
187	1908	1794	1808	1685	1835	1768	1774	1818	1839	1754	2060	1820	bedAc	
188	1909	1798	1809	1692	1838	1772	1778	1822	1842	1761	2062	1824	bedAc	
189	1910	1801	1810	1699	1840	1776	1782	1825	1844	1766	2064	1827	bedAc	
190	1911	1805	1811	1706	1842	1780	1786	1828	1846	1772	2065	1830	bedAc	
191	1912	1809	1812	1713	1844	1784	1790	1831	1848	1777	2067	1833	bedAc	



### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 36 of 95

21 August 2008

Time (min)	P2 P2Max (°F)	P2 AAve (°F)	P2 Sec A-A TC #1 (°F)	P2 Sec A-A TC #2 (°F)	P2 Sec A-A TC #3 (°F)	P2 Sec A-A TC #4 (°F)	P2 Sec A-A TC #5 (°F)	P2 BBave (°F)	P2 Sec B-B TC #6 (°F)	P2 Sec B-B TC #7 (°F)	P2 Sec B-B TC #8 (°F)	P2 CCAve (°F)	P2 Sec C-C TC #9 (°F)
192	1913	1612	1913	1720	1847	1788	1794	1834	1851	1781	1889	1836	bedfrc
193	1915	1616	1915	1728	1849	1792	1798	1836	1853	1786	1870	1830	bedfrc
194	1915	1619	1915	1732	1850	1796	1802	1839	1855	1790	1871	1842	bedfrc
195	1917	1623	1917	1739	1853	1799	1805	1841	1857	1794	1873	1845	bedfrc
196	1918	1626	1918	1744	1855	1803	1809	1844	1859	1797	1875	1848	bedfrc
197	1919	1629	1919	1750	1857	1807	1813	1846	1861	1800	1876	1851	bedfrc
198	1920	1632	1920	1756	1859	1810	1816	1848	1863	1803	1877	1855	bedfrc
199	1921	1635	1921	1762	1861	1813	1820	1850	1865	1806	1878	1857	bedfrc
200	1922	1639	1922	1767	1863	1817	1824	1852	1866	1809	1880	1860	bedfrc
201	1923	1642	1923	1773	1865	1820	1827	1854	1868	1812	1881	1863	bedfrc
202	1924	1644	1924	1778	1866	1823	1830	1858	1870	1815	1883	1866	bedfrc
203	1925	1647	1925	1783	1868	1825	1833	1857	1871	1817	1884	1868	bedfrc
204	1927	1650	1927	1788	1870	1829	1837	1859	1873	1820	1885	1870	bedfrc
205	1928	1653	1928	1793	1872	1833	1840	1861	1875	1823	1886	1873	bedfrc
206	1928	1656	1928	1798	1874	1836	1843	1863	1876	1825	1887	1875	bedfrc
207	1929	1658	1929	1803	1875	1839	1846	1865	1878	1828	1889	1877	bedfrc
208	1930	1661	1930	1808	1877	1841	1849	1867	1879	1831	1890	1879	bedfrc
209	1931	1664	1931	1812	1879	1844	1852	1868	1880	1833	1891	1881	bedfrc
210	1931	1666	1931	1817	1880	1847	1854	1870	1882	1835	1892	1883	bedfrc
211	1932	1669	1932	1822	1882	1850	1857	1871	1883	1838	1893	1885	bedfrc
212	1933	1671	1933	1827	1884	1853	1860	1873	1884	1840	1894	1887	bedfrc
213	1933	1674	1933	1832	1885	1855	1863	1874	1885	1842	1895	1888	bedfrc
214	1934	1676	1934	1836	1887	1856	1865	1876	1887	1845	1895	1890	bedfrc
215	1934	1678	1934	1841	1888	1860	1868	1877	1888	1847	1896	1892	bedfrc
216	1935	1681	1935	1846	1889	1863	1870	1878	1889	1849	1896	1893	bedfrc
217	1936	1683	1936	1851	1891	1866	1873	1879	1890	1851	1897	1895	bedfrc
218	1936	1685	1936	1856	1892	1868	1875	1881	1891	1853	1898	1896	bedfrc
219	1938	1689	1938	1861	1894	1872	1878	1882	1892	1855	1899	1898	bedfrc
220	1939	1691	1939	1866	1895	1874	1880	1883	1893	1857	1900	1899	bedfrc
221	1940	1693	1940	1871	1897	1877	1881	1884	1893	1859	1900	1900	bedfrc
222	1940	1695	1940	1876	1898	1879	1883	1885	1894	1861	1900	1901	bedfrc
223	1940	1697	1940	1881	1899	1882	1885	1888	1894	1864	1900	1902	bedfrc
224	1941	1699	1941	1886	1900	1885	1887	1887	1895	1866	1900	1903	bedfrc
225	1941	1702	1941	1890	1902	1887	1889	1888	1895	1868	1900	1904	bedfrc
226	1942	1704	1942	1895	1903	1890	1891	1889	1896	1870	1900	1905	bedfrc
227	1942	1706	1942	1896	1904	1892	1892	1889	1896	1872	1901	1906	bedfrc
228	1943	1708	1943	1903	1905	1894	1894	1891	1897	1874	1901	1907	bedfrc
229	1943	1709	1943	1908	1906	1896	1895	1892	1898	1877	1902	1908	bedfrc
230	1943	1710	1943	1908	1907	1897	1897	1893	1899	1879	1902	1908	bedfrc
231	1944	1712	1944	1910	1907	1899	1898	1894	1899	1881	1903	1909	bedfrc
232	1944	1713	1944	1912	1908	1900	1900	1895	1900	1883	1903	1910	bedfrc
233	1945	1714	1945	1913	1909	1901	1901	1898	1900	1884	1903	1911	bedfrc
234	1945	1715	1945	1915	1910	1902	1902	1897	1901	1886	1904	1912	bedfrc
235	1945	1715	1945	1916	1910	1903	1903	1898	1902	1887	1904	1912	bedfrc
236	1946	1716	1946	1917	1911	1904	1904	1898	1902	1888	1904	1912	bedfrc
237	1945	1717	1945	1918	1911	1905	1905	1899	1903	1890	1905	1913	bedfrc
238	1946	1718	1946	1918	1912	1905	1905	1899	1903	1891	1905	1913	bedfrc
239	1948	1718	1948	1919	1912	1907	1907	1901	1904	1892	1906	1914	bedfrc
240	1948	1719	1948	1920	1913	1907	1908	1901	1904	1893	1906	1914	bedfrc
Max T:	1948	1719	1948	1920	1913	1907	1908	1901	1904	1893	1906	1914	bedfrc
Max A:	1209	1000	1200	1200	1200	1200	1200	1009	1200	1200	1200	1000	1200



### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 37 of 95

21 August 2008

	P2	P2	P2	P2	P2	P2	P5	P5	P5	P5	P5	P5
	Sec C-C	Sec C-C	DDAve	Sec D-D	Sec D-D	Sec D-D	PSI Max	AAAve	Sec A-A	Sec A-A	Sec A-A	Sec A-A
Time	TC #10	TC #11	(°F)	TC #12	TC #13	TC #14	(°F)	(°F)	TC #1	TC #2	TC #3	TC #4
(min)	(°F)	(°F)		(°F)	(°F)	(°F)			(°F)	(°F)	(°F)	(°F)
0	82	83	83	badfic	83	83	82	81	81	81	81	81
1	82	82	83	badfic	83	83	82	81	81	81	81	81
2	83	83	83	badfic	83	83	82	81	81	81	81	81
3	83	83	83	badfic	83	83	82	81	81	81	81	81
4	85	85	84	badfic	82	85	82	81	81	81	81	81
5	83	88	85	badfic	81	89	83	81	81	81	81	81
6	84	97	88	badfic	81	95	83	82	82	81	81	82
7	84	113	98	badfic	82	110	85	82	83	81	82	82
8	85	135	105	badfic	83	129	87	84	85	81	85	84
9	87	159	117	badfic	84	150	89	86	86	82	87	85
10	89	180	128	badfic	87	169	93	87	90	81	90	89
11	93	205	139	badfic	91	187	97	89	93	82	93	89
12	98	233	152	badfic	96	207	103	91	97	83	97	90
13	104	259	169	badfic	103	228	110	94	102	83	102	92
14	111	283	180	badfic	110	249	118	96	108	84	110	96
15	119	305	194	badfic	118	269	129	104	118	86	118	100
16	128	327	208	badfic	128	288	134	110	124	87	127	105
17	137	347	221	badfic	135	307	143	116	133	89	136	110
18	147	367	235	badfic	144	325	151	123	142	92	145	117
19	157	388	249	badfic	155	343	158	126	151	94	154	123
20	168	408	263	badfic	165	361	165	130	159	95	162	130
21	180	429	278	badfic	175	379	172	142	165	101	170	136
22	192	448	293	badfic	188	398	181	149	174	105	179	142
23	204	467	309	badfic	200	417	190	157	184	110	188	149
24	218	483	323	badfic	211	435	199	163	193	114	197	155
25	229	500	339	badfic	224	453	208	171	203	119	207	161
26	242	518	354	badfic	239	471	217	179	212	124	217	168
27	258	535	370	badfic	249	490	227	186	221	129	228	176
28	269	553	385	badfic	262	508	239	194	230	135	236	183
29	282	570	401	badfic	275	526	245	202	239	141	245	191
30	298	587	418	badfic	288	544	254	210	248	147	254	199
31	310	605	432	badfic	301	562	264	218	257	153	264	206
32	323	622	447	badfic	314	579	273	226	265	159	273	214
33	337	639	462	badfic	327	597	282	234	274	166	282	221
34	351	655	478	badfic	341	614	291	242	283	172	291	229
35	365	671	492	badfic	354	630	300	250	292	179	300	237
36	379	687	507	badfic	367	646	309	258	300	186	309	244
37	393	703	522	badfic	381	663	318	266	309	193	318	253
38	407	718	537	badfic	394	679	327	274	317	200	327	260
39	421	734	551	badfic	407	695	335	282	325	207	335	268
40	434	750	569	badfic	420	711	344	290	334	214	344	275
41	448	768	581	badfic	434	727	352	298	343	221	352	283
42	462	782	595	badfic	447	744	361	306	351	228	361	291
43	475	797	610	badfic	460	760	370	314	360	235	370	298
44	489	813	628	badfic	473	776	379	322	368	243	379	306
45	502	829	639	badfic	485	791	388	330	377	250	388	314
46	515	844	653	badfic	498	807	396	338	385	258	396	322
47	528	860	667	badfic	511	823	405	347	394	265	405	330
48	541	875	682	badfic	524	839	415	355	403	273	414	338
49	554	891	698	badfic	539	854	424	363	412	280	423	345
50	567	905	709	badfic	549	869	433	371	420	287	432	354
51	580	920	722	badfic	561	883	441	379	429	295	440	362
52	592	934	735	badfic	574	897	450	388	438	302	449	370
53	605	948	749	badfic	588	911	459	396	446	310	458	377
54	617	962	762	badfic	598	925	468	404	454	317	466	386
55	629	979	775	badfic	610	939	477	412	463	325	475	394
56	641	990	787	badfic	621	952	485	420	471	332	484	401
57	654	1004	800	badfic	633	966	494	428	480	340	492	410
58	668	1017	812	badfic	645	979	503	437	489	347	501	418
59	678	1031	825	badfic	657	992	511	445	497	355	510	426
60	690	1044	837	badfic	668	1005	520	453	505	362	518	434
61	701	1057	849	badfic	679	1018	529	461	514	370	527	442
62	713	1070	861	badfic	691	1031	538	469	523	377	536	450
63	724	1082	873	badfic	702	1043	548	477	531	385	545	458

#### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 38 of 95

21 August 2008

	P2	P2	P2	P2	P2	P2	P5	P5	P5	P5	P5	P5
	Sec C-C	Sec C-C	DDAve	Sec D-D	Sec D-D	Sec D-D	P5Max	AA Ave	Sec A-A	Sec A-A	Sec A-A	Sec A-A
Time	TC #10	TC #11	(°F)	TC #12	TC #13	TC #14	(°F)	(°F)	TC #1	TC #2	TC #3	TC #4
(min)	(°F)	(°F)		(°F)	(°F)	(°F)			(°F)	(°F)	(°F)	(°F)
54	739	1095	884	bad/tc	713	1055	555	486	540	393	553	486
55	747	1107	897	bad/tc	725	1068	563	494	548	400	562	474
56	759	1119	908	bad/tc	735	1080	572	502	557	408	571	482
57	770	1132	920	bad/tc	747	1092	581	510	569	415	579	491
58	781	1143	931	bad/tc	757	1104	589	519	574	423	588	499
59	792	1156	942	bad/tc	768	1115	598	527	583	430	597	507
60	803	1167	953	bad/tc	779	1127	607	535	591	438	605	515
71	814	1179	964	bad/tc	790	1138	618	543	600	446	614	523
72	824	1190	975	bad/tc	800	1150	624	551	608	453	622	531
73	834	1202	986	bad/tc	810	1161	633	560	617	461	631	539
74	845	1213	997	bad/tc	821	1172	642	568	628	468	640	547
75	855	1223	1007	bad/tc	831	1182	650	576	634	476	648	556
76	869	1234	1017	bad/tc	841	1193	659	584	643	483	657	563
77	878	1245	1027	bad/tc	851	1203	668	592	651	491	666	572
78	889	1255	1037	bad/tc	861	1213	679	601	660	499	674	580
79	898	1265	1048	bad/tc	871	1224	684	608	668	508	682	588
80	908	1275	1058	bad/tc	881	1234	693	617	677	514	691	596
81	916	1284	1067	bad/tc	891	1243	701	625	685	521	699	604
82	925	1294	1077	bad/tc	900	1253	709	633	694	529	707	612
83	935	1303	1087	bad/tc	910	1263	718	641	702	538	716	620
84	944	1312	1096	bad/tc	919	1272	726	648	710	544	724	628
85	954	1321	1105	bad/tc	929	1281	734	657	718	551	732	636
86	963	1329	1114	bad/tc	938	1290	742	665	727	559	740	644
87	972	1338	1123	bad/tc	947	1299	750	673	736	566	749	652
88	982	1343	1133	bad/tc	957	1308	759	680	743	573	757	659
89	991	1350	1142	bad/tc	966	1317	768	688	751	580	765	667
90	1000	1357	1150	bad/tc	975	1325	775	696	760	588	773	676
91	1009	1365	1159	bad/tc	984	1333	782	704	768	595	781	683
92	1018	1373	1167	bad/tc	993	1340	791	712	776	602	789	691
93	1027	1381	1174	bad/tc	1002	1348	799	720	785	610	798	699
94	1035	1389	1181	bad/tc	1010	1352	807	728	793	617	806	706
95	1044	1397	1189	bad/tc	1019	1359	814	735	801	624	814	714
96	1053	1405	1197	bad/tc	1028	1366	823	743	810	631	822	723
97	1062	1413	1205	bad/tc	1037	1373	831	751	817	638	830	730
98	1070	1421	1213	bad/tc	1046	1380	838	758	825	645	837	737
99	1079	1430	1221	bad/tc	1055	1387	846	766	834	653	845	745
100	1088	1438	1229	bad/tc	1063	1394	854	774	841	660	853	753
101	1098	1447	1237	bad/tc	1072	1401	862	781	849	667	861	761
102	1105	1455	1244	bad/tc	1080	1408	869	789	857	674	869	768
103	1114	1463	1253	bad/tc	1089	1415	877	796	865	681	876	776
104	1122	1471	1261	bad/tc	1098	1423	884	804	873	688	884	783
105	1131	1480	1269	bad/tc	1107	1431	892	812	881	695	892	791
106	1140	1488	1277	bad/tc	1115	1439	900	819	889	702	900	799
107	1148	1498	1285	bad/tc	1124	1446	907	827	896	709	907	806
108	1156	1504	1293	bad/tc	1132	1453	915	834	904	716	914	813
109	1165	1512	1301	bad/tc	1141	1461	922	841	912	723	922	821
110	1173	1520	1309	bad/tc	1149	1469	929	848	919	730	929	828
111	1181	1527	1316	bad/tc	1157	1475	937	856	928	737	937	836
112	1189	1535	1325	bad/tc	1165	1483	944	863	934	744	944	843
113	1197	1542	1332	bad/tc	1174	1490	951	870	941	751	951	850
114	1205	1550	1340	bad/tc	1183	1497	958	878	949	758	958	857
115	1213	1557	1348	bad/tc	1191	1504	966	885	956	765	966	865
116	1221	1564	1355	bad/tc	1199	1511	973	892	964	772	973	872
117	1228	1571	1362	bad/tc	1207	1517	980	899	970	778	980	879
118	1236	1578	1370	bad/tc	1215	1525	987	906	978	785	987	886
119	1243	1586	1377	bad/tc	1222	1532	994	913	985	792	994	893
120	1250	1593	1384	bad/tc	1230	1539	1000	920	992	799	1000	900
121	1257	1601	1391	bad/tc	1237	1544	1007	927	999	806	1007	907
122	1264	1608	1398	bad/tc	1245	1551	1014	933	1008	812	1014	914
123	1271	1615	1404	bad/tc	1251	1559	1021	940	1013	819	1021	921
124	1278	1623	1410	bad/tc	1258	1562	1028	947	1020	826	1028	928
125	1284	1631	1418	bad/tc	1265	1569	1035	954	1027	833	1035	935
126	1292	1640	1426	bad/tc	1274	1578	1041	961	1034	839	1041	941
127	1299	1647	1433	bad/tc	1281	1584	1048	967	1040	846	1048	948

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 39 of 95

21 August 2008

	P2	P2	P2	P2	P2	P2	P5	P5	P5	P5	P5	P5
	Sec C-A	Sec C-C	DDave	Sec D-D	Sec D-D	Sec D-D	PSMax	AAave	Sec A-A	Sec A-A	Sec A-A	Sec A-A
Time	TC #10	TC #11	TC #12	TC #13	TC #14	TC #15	(°F)	(°F)	TC #1	TC #2	TC #3	TC #4
(min)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)			(°F)	(°F)	(°F)	(°F)
128	1304	1653	1439	bad/tc	1287	1590	1055	974	1047	853	1055	955
129	1310	1661	1448	bad/tc	1294	1608	1061	981	1053	859	1061	962
130	1318	1669	1453	bad/tc	1301	1605	1068	987	1060	866	1068	968
131	1321	1678	1461	bad/tc	1308	1613	1074	994	1067	872	1074	975
132	1327	1683	1468	bad/tc	1315	1620	1080	1000	1073	879	1080	981
133	1331	1689	1473	bad/tc	1322	1626	1087	1007	1080	886	1087	988
134	1339	1697	1480	bad/tc	1329	1634	1093	1013	1085	892	1093	994
135	1341	1705	1488	bad/tc	1333	1643	1099	1019	1092	898	1099	1001
136	1345	1712	1495	bad/tc	1339	1651	1106	1026	1099	905	1106	1007
137	1350	1718	1502	bad/tc	1346	1659	1112	1032	1105	911	1112	1014
138	1354	1725	1508	bad/tc	1350	1666	1118	1039	1111	918	1118	1020
139	1361	1731	1515	bad/tc	1355	1674	1124	1045	1117	924	1124	1026
140	1368	1737	1521	bad/tc	1361	1681	1130	1051	1124	931	1130	1032
141	1378	1743	1528	bad/tc	1367	1688	1136	1057	1130	937	1136	1039
142	1385	1748	1535	bad/tc	1375	1694	1142	1064	1136	944	1142	1046
143	1393	1753	1542	bad/tc	1383	1700	1147	1069	1141	950	1147	1051
144	1402	1759	1550	bad/tc	1382	1707	1153	1075	1147	957	1153	1057
145	1412	1765	1557	bad/tc	1400	1714	1159	1081	1153	963	1158	1063
146	1422	1788	1594	bad/tc	1409	1718	1164	1087	1158	969	1164	1069
147	1433	1774	1572	bad/tc	1419	1724	1170	1093	1164	976	1169	1075
148	1443	1782	1581	bad/tc	1429	1732	1176	1099	1170	982	1175	1081
149	1452	1782	1597	bad/tc	1439	1735	1182	1105	1175	988	1180	1087
150	1463	1789	1598	bad/tc	1449	1742	1187	1111	1181	995	1186	1093
151	1472	1792	1603	bad/tc	1459	1747	1193	1116	1187	1001	1191	1099
152	1482	1798	1612	bad/tc	1469	1754	1198	1122	1192	1007	1197	1105
153	1491	1801	1618	bad/tc	1478	1758	1204	1128	1198	1013	1202	1110
154	1500	1809	1626	bad/tc	1488	1764	1209	1134	1203	1020	1208	1116
155	1509	1810	1633	bad/tc	1497	1769	1215	1139	1209	1026	1213	1122
156	1518	1814	1640	bad/tc	1505	1773	1220	1145	1214	1032	1218	1128
157	1527	1818	1647	bad/tc	1515	1778	1226	1150	1219	1038	1223	1133
158	1538	1821	1653	bad/tc	1524	1782	1231	1156	1225	1045	1228	1139
159	1544	1829	1660	bad/tc	1533	1787	1237	1162	1230	1051	1234	1146
160	1553	1829	1666	bad/tc	1541	1791	1242	1167	1235	1057	1239	1150
161	1561	1833	1673	bad/tc	1550	1796	1248	1172	1240	1063	1243	1155
162	1570	1839	1680	bad/tc	1559	1800	1253	1178	1248	1069	1249	1161
163	1579	1838	1684	bad/tc	1566	1801	1258	1183	1251	1075	1254	1166
164	1589	1840	1690	bad/tc	1575	1804	1264	1189	1256	1081	1259	1172
165	1600	1844	1696	bad/tc	1584	1808	1269	1194	1261	1087	1264	1177
166	1610	1848	1703	bad/tc	1593	1813	1274	1199	1268	1093	1268	1182
167	1620	1849	1709	bad/tc	1603	1814	1279	1204	1271	1099	1273	1187
168	1630	1852	1715	bad/tc	1612	1817	1284	1210	1278	1105	1278	1193
169	1639	1858	1722	bad/tc	1622	1821	1289	1216	1285	1111	1283	1198
170	1648	1859	1727	bad/tc	1631	1822	1294	1220	1291	1116	1288	1203
171	1658	1859	1732	bad/tc	1640	1824	1299	1225	1290	1122	1292	1208
172	1664	1860	1738	bad/tc	1648	1824	1304	1230	1295	1128	1297	1214
173	1671	1860	1740	bad/tc	1655	1825	1309	1235	1300	1134	1301	1218
174	1678	1861	1745	bad/tc	1663	1827	1314	1240	1304	1139	1306	1223
175	1685	1863	1749	bad/tc	1670	1828	1318	1244	1308	1145	1310	1228
176	1692	1865	1754	bad/tc	1677	1830	1323	1249	1313	1151	1315	1233
177	1699	1869	1758	bad/tc	1684	1832	1327	1254	1318	1158	1319	1238
178	1705	1868	1763	bad/tc	1691	1834	1332	1259	1322	1162	1323	1243
179	1712	1869	1767	bad/tc	1698	1836	1336	1263	1326	1167	1327	1248
180	1719	1871	1771	bad/tc	1704	1838	1340	1268	1331	1173	1331	1253
181	1725	1873	1778	bad/tc	1711	1840	1344	1273	1336	1178	1336	1257
182	1731	1874	1780	bad/tc	1717	1842	1347	1277	1339	1183	1338	1262
183	1737	1879	1784	bad/tc	1723	1844	1351	1281	1343	1188	1341	1266
184	1742	1878	1787	bad/tc	1728	1846	1354	1285	1348	1193	1344	1271
185	1748	1879	1791	bad/tc	1734	1848	1358	1289	1350	1198	1348	1275
186	1753	1880	1795	bad/tc	1739	1850	1362	1294	1353	1204	1351	1280
187	1758	1881	1798	bad/tc	1744	1851	1366	1298	1358	1208	1355	1284
188	1764	1883	1802	bad/tc	1750	1853	1370	1301	1359	1213	1358	1288
189	1769	1884	1805	bad/tc	1755	1855	1374	1306	1363	1218	1362	1292
190	1774	1885	1809	bad/tc	1760	1857	1377	1310	1367	1223	1366	1297
191	1779	1887	1812	bad/tc	1765	1859	1381	1314	1370	1228	1369	1301

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 40 of 95

21 August 2008

	P2	P2	P2	P2	P2	P2	P5	P5	P5	P5	P5	P5
	Sec C-C	Sec C-C	DD Ave	Sec D-D	Sec D-D	Sec D-D	PS Max	AA Ave	Sec A-A	Sec A-A	Sec A-A	Sec A-A
Time	TC #10	TC #11	(°F)	TC #12	TC #13	TC #14	(°F)	(°F)	TC #1	TC #2	TC #3	TC #4
(min)	(°F)	(°F)		(°F)	(°F)	(°F)			(°F)	(°F)	(°F)	(°F)
192	1764	1888	1815	bad/tc	1769	1890	1385	1318	1374	1232	1373	1305
193	1789	1880	1818	bad/tc	1774	1882	1389	1321	1377	1237	1377	1308
194	1794	1890	1821	bad/tc	1778	1894	1393	1326	1381	1241	1380	1312
195	1709	1891	1824	bad/tc	1783	1895	1397	1329	1385	1246	1383	1316
196	1804	1892	1827	bad/tc	1787	1897	1401	1333	1389	1250	1387	1319
197	1809	1893	1830	bad/tc	1791	1899	1405	1336	1392	1254	1391	1323
198	1814	1895	1833	bad/tc	1795	1871	1410	1340	1396	1258	1395	1326
199	1818	1898	1838	bad/tc	1799	1872	1414	1344	1401	1263	1399	1329
200	1823	1897	1838	bad/tc	1802	1874	1418	1348	1405	1267	1403	1332
201	1828	1898	1841	bad/tc	1805	1875	1423	1351	1409	1271	1407	1336
202	1832	1899	1844	bad/tc	1810	1877	1427	1355	1413	1275	1411	1338
203	1835	1900	1846	bad/tc	1813	1879	1432	1358	1418	1279	1415	1341
204	1839	1901	1849	bad/tc	1817	1881	1438	1362	1422	1282	1419	1343
205	1843	1902	1851	bad/tc	1820	1882	1440	1365	1426	1286	1423	1346
206	1849	1903	1854	bad/tc	1823	1884	1445	1369	1431	1289	1427	1349
207	1850	1904	1858	bad/tc	1831	1885	1449	1373	1435	1293	1431	1352
208	1853	1905	1861	bad/tc	1834	1887	1454	1376	1440	1297	1435	1355
209	1856	1906	1863	bad/tc	1837	1888	1458	1380	1444	1300	1439	1359
210	1859	1907	1865	bad/tc	1840	1889	1462	1384	1448	1303	1443	1362
211	1861	1908	1867	bad/tc	1843	1891	1466	1388	1453	1307	1447	1366
212	1864	1909	1869	bad/tc	1845	1892	1471	1391	1457	1310	1451	1370
213	1865	1910	1871	bad/tc	1849	1893	1475	1395	1462	1313	1455	1374
214	1869	1911	1901	bad/tc	1857	1895	1479	1399	1466	1317	1460	1377
215	1871	1912	1911	bad/tc	1858	1896	1483	1403	1470	1320	1463	1381
216	1873	1913	1913	bad/tc	1858	1897	1488	1407	1475	1323	1467	1385
217	1875	1914	1914	bad/tc	1859	1898	1492	1411	1479	1326	1471	1389
218	1877	1915	1915	bad/tc	1860	1899	1496	1415	1483	1329	1475	1393
219	1879	1916	1916	bad/tc	1861	1900	1500	1419	1488	1332	1479	1397
220	1881	1918	1917	bad/tc	1863	1901	1504	1423	1493	1334	1484	1402
221	1883	1917	1918	bad/tc	1864	1901	1508	1427	1497	1337	1487	1406
222	1884	1917	1919	bad/tc	1865	1902	1512	1431	1502	1340	1491	1410
223	1886	1917	1919	bad/tc	1865	1902	1516	1435	1506	1342	1495	1415
224	1888	1918	1920	bad/tc	1866	1903	1520	1438	1510	1344	1499	1419
225	1890	1918	1920	bad/tc	1867	1903	1524	1442	1515	1346	1503	1424
226	1891	1919	1921	bad/tc	1867	1904	1528	1446	1519	1348	1507	1428
227	1893	1919	1921	bad/tc	1868	1904	1531	1450	1523	1350	1511	1432
228	1894	1919	1922	bad/tc	1868	1905	1535	1453	1527	1352	1515	1436
229	1898	1920	1922	bad/tc	1869	1905	1539	1457	1531	1355	1519	1441
230	1898	1920	1923	bad/tc	1869	1906	1543	1461	1536	1358	1523	1445
231	1897	1921	1923	bad/tc	1869	1907	1547	1465	1540	1361	1527	1449
232	1898	1922	1923	bad/tc	1869	1907	1551	1469	1544	1364	1531	1453
233	1899	1922	1924	bad/tc	1869	1908	1554	1473	1548	1368	1535	1457
234	1900	1923	1923	bad/tc	1869	1908	1558	1477	1552	1372	1539	1462
235	1900	1923	1924	bad/tc	1869	1909	1562	1481	1556	1375	1542	1466
236	1901	1923	1924	bad/tc	1869	1909	1566	1485	1560	1379	1546	1470
237	1901	1924	1924	bad/tc	1869	1910	1570	1489	1564	1383	1550	1474
238	1902	1924	1925	bad/tc	1869	1911	1574	1493	1568	1386	1554	1478
239	1902	1925	1925	bad/tc	1869	1911	1578	1497	1573	1390	1558	1482
240	1903	1925	1926	bad/tc	1869	1912	1582	1501	1577	1394	1562	1486
Max T:	1903	1925	1925	bad/tc	1909	1912	1582	1501	1577	1394	1562	1486
Max A:	1203	1200	1000	1200	1200	1200	1200	1000	1200	1200	1200	1200

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 41 of 95

21 August 2008

Time (min)	P5 Sec A-A TC #5 (°F)	P5 BB Ave (°F)	P5 Sec B-B TC #6 (°F)	P5 Sec B-B TC #7 (°F)	P5 Sec B-B TC #8 (°F)	P5 CCAve (°F)	P5 Sec C-C TC #9 (°F)	P5 Sec C-C TC #10 (°F)	P5 Sec C-C TC #11 (°F)	P5 DD Ave (°F)	P5 Sec D-D TC #12 (°F)	P5 Sec D-D TC #13 (°F)	P5 Sec D-D TC #14 (°F)
0	82	82	82	82	82	82	82	82	82	82	82	82	82
1	81	82	82	82	82	82	82	82	82	82	82	82	82
2	81	82	82	82	82	82	82	82	82	82	82	82	82
3	81	82	82	82	82	82	82	82	82	82	82	82	82
4	81	82	82	82	82	82	82	81	82	82	82	82	82
5	82	82	82	82	82	82	83	81	82	82	82	82	82
6	82	83	83	82	83	82	83	80	83	82	82	81	82
7	83	84	85	82	85	83	85	80	85	83	84	82	83
8	84	85	87	82	87	84	87	80	86	84	85	82	84
9	85	87	89	82	89	86	89	80	88	85	87	82	86
10	87	89	91	82	93	88	91	81	91	88	89	82	88
11	89	91	94	82	97	89	94	81	93	89	92	83	90
12	90	94	97	83	103	92	97	81	97	90	95	83	93
13	93	98	102	83	110	96	102	82	103	94	100	84	97
14	98	103	106	84	118	101	109	83	111	98	106	85	103
15	101	109	115	89	128	106	116	84	119	108	114	89	110
16	108	114	122	88	134	112	124	85	127	108	122	87	118
17	112	120	129	87	143	118	131	87	135	115	131	88	126
18	119	128	138	89	151	123	139	88	142	121	138	90	135
19	125	132	148	92	158	130	148	91	150	128	144	92	144
20	132	138	154	94	165	136	158	94	158	134	157	94	152
21	139	144	162	98	172	143	165	97	166	141	165	97	161
22	148	150	180	101	181	149	173	100	175	148	174	101	169
23	152	157	178	105	190	156	180	104	184	154	182	105	176
24	158	162	179	109	199	162	188	108	192	161	191	108	184
25	169	170	187	114	208	168	195	112	201	168	199	113	193
26	173	178	198	119	217	177	203	117	211	175	208	117	201
27	180	187	209	124	227	185	213	122	220	184	219	122	210
28	188	194	218	129	236	193	223	128	226	191	228	127	219
29	195	202	228	134	245	201	233	133	238	199	237	132	228
30	204	211	238	140	254	210	243	139	247	207	246	138	237
31	212	219	248	146	263	218	252	145	256	214	255	143	246
32	220	228	258	152	273	226	262	151	266	222	264	149	253
33	228	236	267	158	282	234	271	157	275	230	273	155	262
34	235	244	277	164	291	243	280	164	284	237	281	161	270
35	243	252	288	171	300	251	289	170	293	245	290	167	278
36	251	261	296	178	309	259	298	177	302	253	298	174	286
37	259	269	305	185	317	267	307	184	310	260	308	180	294
38	267	277	314	192	326	275	316	191	319	268	314	187	302
39	275	285	324	199	334	284	324	199	328	275	322	193	309
40	283	294	333	206	343	292	333	208	337	283	331	200	317
41	291	303	342	214	352	300	342	213	346	290	339	207	325
42	299	311	351	221	361	309	351	221	355	298	347	214	333
43	308	320	361	228	370	317	359	228	364	306	355	221	341
44	314	328	370	236	378	325	368	235	373	314	364	228	350
45	322	337	379	243	388	334	377	243	382	322	372	235	358
46	330	345	388	251	396	342	386	250	391	330	381	242	366
47	339	354	398	258	405	351	395	258	400	338	390	249	374
48	348	363	407	266	415	360	404	266	406	348	398	256	383
49	355	371	417	273	424	368	413	273	419	354	407	263	391
50	363	380	426	281	433	377	422	281	428	361	415	270	399
51	371	388	436	288	441	386	431	289	437	370	424	278	407
52	379	397	445	296	450	394	440	296	446	378	432	285	416
53	387	405	454	303	459	403	449	304	455	385	440	292	424
54	395	414	463	311	468	411	458	312	464	393	449	299	432
55	403	423	472	319	477	419	466	319	473	401	457	306	440
56	411	431	481	328	485	428	475	327	482	409	466	313	449
57	420	439	490	334	494	437	484	335	491	417	474	320	457
58	428	448	499	341	503	445	492	342	500	425	483	328	466
59	438	458	507	349	511	453	501	350	509	433	491	335	473
60	444	464	516	356	520	462	510	357	516	441	499	342	481
61	452	473	525	364	529	470	518	365	527	449	508	349	490
62	460	481	534	372	538	479	527	373	536	457	516	356	498
63	468	489	542	379	546	487	535	380	545	465	524	364	506



### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 42 of 95

21 August 2008

Time (min)	P5 Sec A-A TC #5 (°F)	P5 BB Ave (°F)	P5 Sec B-B TC #6 (°F)	P5 Sec B-B TC #7 (°F)	P5 Sec B-B TC #8 (°F)	P5 CCAve (°F)	P5 Sec C-C TC #9 (°F)	P5 Sec C-C TC #10 (°F)	P5 Sec C-C TC #11 (°F)	P5 DD Ave (°F)	P5 Sec D-D TC #12 (°F)	P5 Sec D-D TC #13 (°F)	P5 Sec D-D TC #14 (°F)
54	477	498	551	387	555	495	544	388	554	473	533	371	514
55	485	508	580	304	583	504	583	308	583	480	541	378	522
56	403	514	589	402	572	512	501	403	572	488	549	385	530
57	501	523	577	410	581	520	570	411	580	496	557	392	538
58	509	531	588	417	589	529	578	419	589	504	566	399	547
59	517	539	595	425	588	537	567	426	598	512	574	407	555
60	525	547	603	432	607	545	595	434	607	520	582	414	563
71	534	556	612	440	616	554	604	441	616	528	591	421	571
72	542	564	621	447	624	562	612	449	624	535	599	428	579
73	550	572	629	455	633	570	621	457	633	543	607	435	587
74	558	580	638	462	641	578	629	464	642	551	615	442	595
75	565	589	646	470	650	586	637	471	650	559	623	450	603
76	574	598	654	477	658	595	646	479	659	568	631	457	611
77	582	605	663	485	667	603	654	486	668	574	639	464	619
78	590	613	671	492	675	611	662	494	676	582	648	471	627
79	598	620	679	499	683	619	671	501	684	589	655	478	635
80	608	629	688	507	692	627	679	509	693	597	663	485	643
81	614	637	696	514	700	635	687	516	701	604	671	492	650
82	622	644	704	521	708	642	695	523	709	612	679	499	658
83	630	652	712	528	716	651	703	531	718	620	687	507	666
84	638	660	720	535	725	658	711	538	726	627	695	513	674
85	646	668	728	543	733	666	719	545	734	635	703	521	681
86	654	676	737	550	741	674	727	552	742	642	710	528	689
87	661	683	744	557	749	682	735	560	750	650	718	535	697
88	669	691	752	565	757	690	743	567	759	657	726	541	704
89	677	699	760	572	765	697	751	574	767	665	734	548	712
90	685	707	768	579	773	705	758	581	775	672	741	555	720
91	693	714	776	586	781	712	766	588	782	679	749	562	727
92	700	722	784	593	789	720	774	595	791	687	757	569	735
93	708	730	792	600	797	728	782	602	799	694	764	576	742
94	716	737	800	607	805	735	790	609	807	702	772	583	750
95	724	745	808	614	813	742	797	616	814	709	779	590	757
96	731	753	816	621	821	750	805	622	825	716	787	596	765
97	738	760	824	628	829	758	813	629	831	723	794	603	772
98	746	767	831	634	836	765	821	636	838	731	802	610	780
99	754	775	839	642	844	772	828	642	846	738	809	617	787
100	761	782	847	648	852	780	836	649	854	746	817	624	794
101	769	790	855	655	860	787	843	655	862	752	824	630	801
102	776	797	862	662	867	794	850	662	869	759	831	637	809
103	784	805	870	669	875	801	858	669	877	766	839	644	816
104	792	812	878	676	883	808	865	676	884	773	846	651	823
105	800	819	885	683	890	816	873	682	892	780	853	657	831
106	807	827	893	690	898	823	880	689	899	788	861	664	838
107	815	834	900	697	906	830	888	696	907	795	868	671	845
108	822	841	908	703	913	837	894	702	915	801	874	677	852
109	829	849	915	710	921	844	902	709	922	808	882	684	859
110	837	859	922	717	928	851	909	716	929	815	889	690	866
111	844	863	930	724	935	858	916	722	937	822	896	697	873
112	851	870	937	730	942	865	923	729	944	828	902	703	880
113	858	877	944	737	950	872	930	735	951	835	909	709	886
114	865	884	951	744	957	879	937	742	958	842	916	716	893
115	873	891	958	751	964	886	944	749	965	848	923	722	900
116	880	898	965	757	971	893	951	755	972	855	930	729	907
117	887	905	972	764	978	899	957	761	979	861	938	735	913
118	894	911	979	770	985	906	964	768	986	868	943	741	920
119	901	918	985	777	992	913	971	775	993	874	949	748	926
120	908	925	992	784	999	920	978	781	1000	881	956	754	933
121	915	932	999	790	1006	926	984	788	1007	887	962	760	939
122	921	938	1005	797	1013	933	991	794	1014	894	969	766	946
123	928	945	1012	803	1019	939	997	800	1020	900	976	773	952
124	935	952	1019	810	1026	946	1004	807	1027	907	982	779	959
125	942	958	1025	816	1033	953	1011	813	1034	913	989	785	965
126	948	965	1032	823	1039	959	1017	820	1040	919	995	791	972
127	955	971	1039	829	1045	966	1024	826	1047	925	1001	797	978



### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 43 of 95

21 August 2008

Time (min)	Sec A-A TC #5 (°F)	P5 BAve (°F)	P5 TC #6 (°F)	P5 TC #7 (°F)	P5 TC #8 (°F)	P5 CC Ave (°F)	P5 TC #9 (°F)	P5 TC #10 (°F)	P5 TC #11 (°F)	P5 DD Ave (°F)	P5 TC #12 (°F)	P5 TC #13 (°F)	P5 TC #14 (°F)
128	962	978	1045	836	1053	972	1030	832	1054	932	1008	803	984
129	969	984	1052	842	1060	978	1036	839	1060	938	1014	810	991
130	975	991	1058	849	1066	986	1043	845	1067	944	1020	816	997
131	982	997	1065	855	1072	991	1049	851	1073	951	1027	822	1003
132	988	1004	1071	862	1079	996	1055	858	1080	957	1033	828	1009
133	995	1010	1078	868	1085	1004	1061	864	1086	963	1039	834	1015
134	1001	1016	1084	874	1091	1010	1068	870	1092	969	1045	840	1021
135	1007	1023	1090	881	1098	1016	1074	878	1099	975	1051	846	1028
136	1014	1029	1096	887	1104	1023	1080	883	1105	981	1057	853	1033
137	1020	1035	1103	894	1110	1029	1086	889	1111	987	1063	859	1040
138	1028	1042	1109	900	1118	1035	1092	895	1118	993	1069	865	1046
139	1033	1048	1115	906	1122	1041	1098	901	1124	999	1075	871	1051
140	1039	1054	1121	912	1128	1047	1104	908	1130	1005	1081	877	1057
141	1045	1060	1127	919	1134	1053	1110	914	1135	1011	1087	883	1063
142	1051	1066	1133	925	1140	1059	1116	920	1142	1017	1092	889	1069
143	1057	1072	1138	931	1146	1065	1121	926	1147	1022	1098	895	1074
144	1063	1078	1144	938	1152	1071	1127	933	1153	1028	1103	901	1080
145	1069	1084	1150	944	1157	1077	1132	939	1159	1034	1109	907	1085
146	1075	1089	1156	950	1163	1082	1138	945	1164	1039	1114	913	1091
147	1081	1095	1161	957	1168	1088	1143	951	1170	1045	1119	919	1096
148	1087	1101	1167	963	1174	1094	1148	957	1175	1051	1125	925	1102
149	1092	1107	1172	969	1179	1100	1154	963	1182	1056	1130	931	1107
150	1098	1113	1178	975	1185	1106	1160	970	1187	1062	1136	937	1113
151	1104	1118	1183	982	1190	1111	1165	976	1193	1067	1141	943	1118
152	1110	1124	1189	988	1196	1117	1170	982	1198	1073	1147	949	1123
153	1115	1130	1194	994	1201	1123	1176	988	1204	1078	1152	954	1129
154	1121	1136	1200	1001	1207	1128	1181	994	1209	1084	1157	960	1134
155	1128	1141	1206	1006	1212	1134	1188	1000	1215	1089	1162	966	1139
156	1132	1147	1210	1013	1217	1139	1191	1006	1220	1095	1168	972	1144
157	1137	1152	1216	1019	1222	1145	1197	1012	1226	1100	1173	978	1150
158	1143	1158	1221	1025	1228	1150	1202	1018	1231	1106	1178	984	1156
159	1148	1163	1226	1031	1233	1156	1207	1024	1237	1111	1183	990	1160
160	1154	1169	1231	1037	1238	1161	1212	1030	1242	1116	1188	995	1165
161	1159	1174	1236	1043	1243	1167	1217	1036	1246	1121	1193	1001	1170
162	1164	1180	1242	1049	1248	1172	1222	1042	1253	1127	1198	1007	1175
163	1170	1185	1247	1055	1253	1178	1227	1048	1258	1132	1203	1013	1180
164	1175	1190	1252	1061	1258	1183	1232	1054	1264	1138	1209	1019	1186
165	1180	1196	1257	1068	1263	1189	1237	1060	1269	1143	1214	1024	1190
166	1185	1201	1262	1074	1268	1194	1242	1066	1274	1148	1219	1030	1196
167	1191	1206	1267	1079	1273	1199	1247	1071	1279	1153	1224	1036	1200
168	1196	1211	1272	1085	1277	1204	1252	1077	1284	1158	1228	1041	1206
169	1201	1217	1277	1091	1283	1210	1257	1083	1289	1163	1233	1047	1212
170	1208	1222	1282	1097	1287	1215	1262	1089	1294	1169	1238	1053	1215
171	1211	1227	1287	1103	1292	1220	1268	1095	1299	1174	1243	1059	1220
172	1216	1232	1291	1109	1297	1225	1271	1100	1304	1179	1248	1064	1225
173	1221	1237	1296	1114	1301	1230	1276	1106	1309	1184	1252	1070	1230
174	1228	1242	1301	1120	1306	1236	1281	1112	1314	1189	1257	1076	1235
175	1233	1247	1305	1126	1310	1240	1286	1118	1318	1194	1262	1081	1239
176	1238	1252	1310	1132	1315	1245	1290	1123	1323	1199	1268	1087	1244
177	1240	1257	1314	1137	1319	1250	1294	1129	1327	1204	1271	1092	1248
178	1245	1261	1318	1143	1323	1255	1299	1134	1332	1209	1275	1098	1253
179	1249	1265	1323	1148	1328	1260	1303	1140	1336	1213	1279	1103	1257
180	1254	1271	1327	1154	1332	1264	1307	1145	1340	1218	1284	1109	1262
181	1258	1275	1332	1159	1338	1269	1312	1150	1344	1223	1288	1114	1266
182	1263	1280	1336	1164	1343	1273	1316	1156	1347	1228	1292	1120	1271
183	1267	1284	1340	1170	1347	1277	1320	1161	1351	1232	1297	1125	1275
184	1272	1288	1343	1175	1348	1282	1325	1166	1354	1237	1301	1130	1279
185	1276	1292	1347	1180	1349	1286	1329	1171	1358	1241	1305	1135	1284
186	1281	1299	1350	1185	1353	1290	1333	1176	1362	1246	1310	1141	1288
187	1285	1300	1353	1190	1356	1294	1336	1181	1366	1251	1314	1146	1292
188	1289	1304	1357	1195	1360	1299	1340	1186	1370	1255	1318	1151	1297
189	1293	1308	1360	1200	1363	1303	1343	1191	1374	1260	1322	1156	1301
190	1297	1312	1364	1205	1367	1308	1346	1196	1377	1264	1326	1161	1305
191	1301	1316	1367	1209	1371	1311	1350	1201	1381	1269	1330	1166	1309

Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 44 of 95

21 August 2008

	P5 Sec A-A TC #5 (°F)	P5 BB Ave (°F)	P5 Sec B-B TC #6 (°F)	P5 Sec B-B TC #7 (°F)	P5 Sec B-B TC #8 (°F)	P5 CC Ave (°F)	P5 Sec C-C TC #9 (°F)	P5 Sec C-C TC #10 (°F)	P5 Sec C-C TC #11 (°F)	P5 DD Ave (°F)	P5 Sec D-D TC #12 (°F)	P5 Sec D-D TC #13 (°F)	P5 Sec D-D TC #14 (°F)
192	1305	1320	1371	1214	1374	1314	1353	1205	1385	1273	1335	1171	1313
193	1308	1324	1378	1210	1378	1318	1358	1210	1380	1277	1338	1178	1317
194	1312	1328	1379	1223	1381	1323	1360	1215	1393	1281	1342	1181	1321
195	1315	1332	1383	1226	1385	1327	1364	1219	1397	1285	1345	1185	1325
196	1319	1336	1386	1232	1389	1331	1368	1224	1401	1289	1348	1190	1329
197	1322	1340	1390	1237	1393	1335	1371	1228	1405	1293	1351	1195	1332
198	1325	1344	1393	1241	1397	1339	1375	1232	1410	1296	1354	1199	1335
199	1328	1348	1397	1245	1401	1343	1379	1237	1414	1300	1358	1204	1339
200	1331	1352	1401	1250	1405	1347	1382	1241	1418	1304	1362	1208	1342
201	1334	1355	1405	1254	1409	1351	1386	1245	1423	1308	1365	1213	1346
202	1338	1360	1409	1258	1413	1355	1390	1250	1427	1311	1369	1217	1348
203	1339	1364	1413	1262	1417	1359	1394	1254	1432	1315	1373	1222	1352
204	1342	1368	1417	1266	1421	1364	1398	1257	1436	1319	1377	1226	1355
205	1345	1372	1421	1270	1425	1368	1402	1261	1440	1323	1380	1230	1358
206	1348	1376	1425	1273	1429	1372	1405	1265	1445	1327	1384	1234	1362
207	1352	1380	1429	1277	1434	1376	1410	1269	1449	1331	1388	1238	1366
208	1355	1384	1433	1280	1438	1380	1413	1273	1454	1335	1392	1243	1369
209	1358	1388	1437	1284	1442	1384	1418	1276	1458	1338	1395	1247	1373
210	1362	1391	1441	1287	1446	1388	1422	1280	1462	1342	1400	1251	1376
211	1365	1395	1445	1291	1450	1392	1426	1284	1466	1346	1404	1255	1380
212	1369	1399	1449	1294	1455	1396	1430	1287	1471	1350	1408	1259	1383
213	1373	1403	1453	1298	1459	1400	1434	1290	1475	1354	1412	1262	1387
214	1377	1407	1457	1301	1463	1403	1437	1293	1479	1357	1416	1266	1390
215	1381	1411	1461	1304	1467	1407	1442	1297	1483	1361	1420	1270	1394
216	1385	1414	1465	1307	1471	1411	1445	1300	1488	1365	1424	1273	1398
217	1389	1418	1469	1310	1475	1415	1449	1304	1492	1369	1428	1277	1402
218	1393	1422	1473	1313	1479	1419	1453	1307	1496	1373	1433	1280	1406
219	1397	1426	1477	1316	1484	1422	1457	1310	1500	1377	1437	1284	1410
220	1402	1430	1481	1320	1488	1426	1461	1313	1504	1381	1441	1287	1414
221	1408	1433	1485	1322	1492	1430	1465	1316	1508	1385	1445	1291	1418
222	1411	1437	1489	1325	1496	1433	1469	1319	1512	1389	1449	1294	1421
223	1415	1440	1492	1328	1500	1437	1473	1322	1516	1392	1453	1297	1425
224	1420	1444	1496	1331	1504	1440	1476	1325	1520	1395	1457	1300	1429
225	1424	1447	1500	1333	1508	1444	1480	1327	1524	1399	1461	1303	1432
226	1428	1450	1504	1335	1512	1447	1484	1330	1528	1402	1465	1306	1436
227	1432	1453	1507	1337	1516	1450	1487	1332	1531	1406	1469	1309	1440
228	1436	1457	1511	1339	1520	1454	1491	1335	1535	1409	1472	1312	1444
229	1441	1460	1515	1341	1524	1457	1495	1337	1539	1413	1476	1315	1447
230	1445	1463	1518	1343	1527	1460	1499	1339	1543	1416	1480	1318	1451
231	1449	1465	1522	1346	1531	1463	1502	1341	1547	1420	1484	1321	1455
232	1453	1470	1526	1349	1535	1467	1506	1343	1551	1424	1488	1324	1459
233	1457	1474	1530	1352	1539	1470	1510	1346	1554	1427	1492	1328	1463
234	1461	1477	1533	1355	1543	1474	1514	1349	1558	1431	1496	1330	1467
235	1465	1481	1537	1358	1547	1477	1517	1351	1562	1434	1499	1332	1470
236	1469	1484	1541	1362	1550	1481	1521	1355	1566	1437	1503	1335	1474
237	1473	1488	1544	1366	1554	1484	1524	1358	1570	1441	1507	1337	1478
238	1477	1492	1548	1369	1558	1488	1528	1361	1574	1443	1510	1339	1481
239	1481	1495	1551	1373	1562	1492	1532	1365	1578	1447	1514	1341	1485
240	1485	1499	1555	1377	1566	1495	1535	1368	1582	1450	1518	1343	1489
Max T:	1485	1499	1555	1377	1566	1495	1535	1368	1582	1450	1518	1343	1489
Max A:	1203	1000	1200	1200	1200	1600	1200	1200	1200	1000	1200	1200	1200

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 45 of 95

21 August 2008

Time (min)	PSA PSA#1 (°F)	PSA AAAve (°F)	PSA Sec A-A TC #1 (°F)	PSA Sec A-A TC #2 (°F)	PSA Sec A-A TC #3 (°F)	PSA Sec A-A TC #4 (°F)	PSA Sec A-A TC #5 (°F)	PSA BBave (°F)	PSA Sec B-B TC #6 (°F)	PSA Sec B-B TC #7 (°F)	PSA Sec B-B TC #8 (°F)	PSA CCAve (°F)
0	83	82	83	82	82	82	82	82	82	82	83	83
1	83	82	83	82	82	82	82	82	82	82	83	83
2	83	82	83	82	82	82	82	83	83	83	82	83
3	83	82	83	83	83	82	82	83	83	83	83	83
4	83	83	83	83	83	82	82	83	83	82	83	83
5	83	83	83	83	83	82	82	83	83	83	83	83
6	84	83	83	83	83	82	83	83	83	83	83	83
7	84	83	83	83	83	82	83	83	83	83	83	83
8	84	83	83	82	83	83	83	83	83	84	83	83
9	84	83	84	82	84	83	84	83	84	83	83	83
10	85	84	85	82	85	84	85	84	85	83	84	84
11	87	85	87	82	86	85	85	85	85	83	85	85
12	88	86	88	83	87	85	86	85	87	83	86	85
13	90	87	90	83	88	86	87	86	88	83	87	86
14	92	88	92	84	90	87	88	87	90	83	88	87
15	93	89	93	84	91	87	89	89	92	84	90	88
16	95	90	95	84	92	88	90	90	93	84	92	89
17	96	91	96	85	94	89	91	90	94	84	93	90
18	98	92	98	86	95	90	92	91	96	84	94	91
19	100	93	100	89	97	91	93	93	98	85	95	92
20	102	95	102	87	96	93	95	95	100	86	96	94
21	104	96	104	88	100	94	96	96	102	86	98	95
22	107	98	107	89	102	95	98	98	104	87	102	97
23	110	100	110	89	104	97	99	100	107	88	104	99
24	113	102	113	91	106	98	101	102	110	89	107	101
25	117	104	117	92	108	100	104	105	114	90	110	103
26	122	107	122	93	112	102	105	107	118	91	113	106
27	129	110	128	94	116	104	109	111	123	92	117	108
28	131	113	131	95	120	107	113	114	128	94	121	112
29	135	117	135	98	124	110	116	117	132	95	125	115
30	142	121	142	99	128	113	121	121	137	97	130	119
31	147	126	147	102	133	116	124	125	142	99	134	123
32	153	129	153	104	136	120	129	129	148	101	138	127
33	158	132	158	109	142	123	133	133	153	103	144	131
34	163	137	163	109	147	127	138	138	158	106	149	135
35	169	141	169	112	152	131	142	142	163	108	154	139
36	175	145	175	115	157	135	147	146	168	111	159	144
37	181	150	181	118	162	139	151	150	174	114	163	148
38	188	155	188	121	166	144	158	155	180	118	168	152
39	194	159	194	124	171	147	160	160	185	121	173	157
40	201	164	201	128	175	152	165	165	192	124	179	162
41	207	169	207	131	180	156	170	170	199	128	184	167
42	213	174	213	135	186	160	174	175	205	131	190	172
43	220	179	220	139	193	165	179	180	211	135	195	177
44	225	185	225	143	199	170	185	186	218	139	201	182
45	233	190	233	147	205	175	191	191	224	143	207	188
46	239	195	239	151	211	180	198	197	230	147	213	193
47	245	201	245	155	218	185	202	202	237	151	219	199
48	252	207	252	160	224	191	208	208	243	158	224	204
49	259	213	259	165	230	196	214	213	250	160	230	210
50	265	218	265	169	236	201	220	219	256	165	236	216
51	272	224	272	174	242	207	226	225	263	169	242	221
52	279	230	279	179	248	212	232	230	269	174	248	227
53	285	236	285	184	254	218	238	236	275	179	254	233
54	292	242	292	189	260	223	244	242	282	184	260	238
55	299	247	299	194	266	229	249	248	288	189	266	244
56	305	253	305	199	272	234	255	253	294	194	271	250
57	312	259	312	204	278	240	262	260	301	199	277	256
58	318	265	318	210	284	245	268	265	307	204	283	261
59	325	271	325	215	290	251	274	270	313	209	289	267
60	332	277	332	220	295	256	280	276	319	214	295	273
61	338	283	338	225	301	262	286	282	325	219	301	279
62	345	288	345	231	307	267	292	288	332	225	306	285
63	352	295	352	237	313	273	298	293	338	230	312	290

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 46 of 95

21 August 2008

Time (min)	PSA PSA Max (°F)	PSA AA Ave (°F)	PSA Sec A-A TC #1 (°F)	PSA Sec A-A TC #2 (°F)	PSA Sec A-A TC #3 (°F)	PSA Sec A-A TC #4 (°F)	PSA Sec A-A TC #5 (°F)	PSA BBA Ave (°F)	PSA Sec B-B TC #6 (°F)	PSA Sec B-B TC #7 (°F)	PSA Sec B-B TC #8 (°F)	PSA CCA Ave (°F)
54	358	300	358	242	319	279	304	299	344	235	318	296
55	365	308	365	248	325	284	310	305	350	240	324	302
56	371	312	371	253	331	290	316	311	358	248	330	306
57	378	318	378	259	337	295	322	316	363	251	335	313
58	385	324	385	264	343	301	329	322	369	259	341	319
59	391	330	391	270	349	307	335	328	375	252	347	325
60	398	336	398	275	355	312	341	333	381	257	352	331
71	404	342	404	281	361	318	347	339	387	273	358	337
72	411	348	411	286	367	324	353	345	393	278	364	342
73	418	354	418	292	373	329	359	351	400	283	370	348
74	424	360	424	298	379	335	365	357	406	289	376	354
75	431	366	431	303	385	341	371	363	412	294	382	360
76	437	372	437	309	392	348	377	368	418	300	387	366
77	444	378	444	314	398	352	383	374	424	305	393	372
78	450	384	450	320	404	358	389	380	430	310	399	378
79	457	390	457	325	410	364	395	386	437	316	405	383
80	463	396	463	331	416	369	402	392	443	321	411	389
81	470	402	470	337	422	375	408	397	449	326	417	395
82	476	408	476	342	428	381	414	403	455	332	422	401
83	483	414	483	348	433	386	420	409	461	337	428	407
84	489	420	489	353	439	392	426	415	467	343	434	413
85	495	426	495	359	445	398	432	420	473	348	440	418
86	502	432	502	364	451	403	438	426	479	353	445	424
87	508	438	508	370	457	409	444	432	485	359	451	430
88	515	444	515	375	463	415	450	437	491	364	457	436
89	521	449	521	381	468	420	456	443	497	369	463	441
90	528	455	528	387	474	426	462	449	503	375	469	447
91	534	461	534	392	480	432	468	454	509	380	474	453
92	541	467	541	398	486	437	474	460	515	385	480	459
93	547	473	547	403	492	443	480	466	521	391	486	464
94	553	479	553	409	498	449	486	472	527	396	492	470
95	559	484	559	414	503	454	491	477	533	401	498	476
96	565	490	565	420	509	460	497	483	539	407	504	482
97	572	496	572	425	515	466	503	489	545	412	510	488
98	579	502	579	431	521	471	509	494	551	417	515	493
99	585	508	585	436	527	477	515	500	557	423	521	499
100	591	514	591	441	532	483	521	506	563	428	527	505
101	598	520	598	447	538	488	527	512	569	433	533	511
102	604	526	604	453	544	494	533	518	575	439	539	516
103	610	531	610	458	550	500	539	523	581	444	544	522
104	617	537	617	464	556	505	545	529	587	449	550	528
105	623	543	623	469	562	511	551	535	593	455	556	534
106	630	549	630	475	568	517	557	541	599	460	562	540
107	636	555	636	480	573	522	563	546	605	466	568	545
108	642	560	642	485	579	528	568	552	611	470	574	551
109	648	566	648	491	585	534	574	557	617	476	579	557
110	655	572	655	496	591	539	580	563	623	481	585	563
111	661	578	661	502	596	545	586	569	629	486	591	568
112	667	584	667	507	602	551	592	575	635	492	597	574
113	674	590	674	513	608	556	598	580	641	497	603	580
114	680	596	680	518	614	562	604	586	647	503	609	587
115	686	601	686	524	620	567	610	592	653	508	615	592
116	693	607	693	529	625	573	616	597	659	513	620	598
117	699	613	699	535	631	579	621	603	665	518	626	604
118	705	619	705	540	637	584	627	609	671	524	632	610
119	711	625	711	546	643	590	633	615	677	529	638	615
120	717	630	717	551	648	595	639	620	682	534	644	621
121	724	636	724	556	654	601	644	626	688	540	649	627
122	730	642	730	562	660	606	650	631	694	545	655	632
123	736	647	736	567	666	612	656	637	700	550	661	638
124	742	653	742	573	671	617	662	642	706	555	666	643
125	748	659	748	578	677	623	667	648	712	561	672	649
126	754	664	754	583	683	629	673	654	718	566	678	655
127	761	670	761	589	689	634	679	660	724	571	684	661

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 47 of 95

21 August 2008

Time (min)	PSA PSAMax (°F)	PSA AA Ave (°F)	PSA Sec A-A TC #1 (°F)	PSA Sec A-A TC #2 (°F)	PSA Sec A-A TC #3 (°F)	PSA Sec A-A TC #4 (°F)	PSA Sec A-A TC #5 (°F)	PSA BB Ave (°F)	PSA Sec B-B TC #6 (°F)	PSA Sec B-B TC #7 (°F)	PSA Sec B-B TC #8 (°F)	PSA CC Ave (°F)
128	787	878	767	594	694	840	885	685	730	578	689	657
129	773	882	773	600	700	848	891	671	738	582	695	672
130	779	888	779	605	706	851	897	676	741	587	701	679
131	785	893	785	610	712	856	902	682	747	592	707	686
132	791	898	791	616	717	862	908	688	753	597	713	690
133	797	904	797	621	723	867	913	693	759	602	718	695
134	803	910	803	626	729	873	919	699	765	608	724	701
135	810	916	810	632	735	879	925	705	771	613	730	707
136	816	922	816	638	740	884	931	710	777	618	736	714
137	822	928	822	643	746	890	937	716	783	624	742	720
138	829	934	829	649	752	895	943	722	789	629	748	726
139	835	940	835	655	758	901	949	728	795	634	754	733
140	841	946	841	660	764	907	955	734	802	640	760	739
141	847	951	847	666	769	912	961	740	808	645	766	746
142	853	957	853	672	775	918	967	746	814	651	772	752
143	859	963	859	678	781	924	972	751	820	656	778	758
144	865	969	865	683	787	930	978	757	826	661	784	764
145	871	974	871	689	793	935	984	763	832	667	790	770
146	877	980	877	695	798	941	990	769	838	672	796	776
147	883	986	883	700	804	946	995	775	844	678	802	782
148	889	991	889	706	809	952	1001	780	849	683	807	788
149	895	997	895	711	815	957	1007	786	855	689	814	795
150	901	1003	901	717	821	963	1012	791	861	694	819	800
151	908	1008	908	723	826	968	1018	797	867	699	825	807
152	912	1014	912	728	831	974	1024	803	873	704	831	812
153	918	1019	918	734	837	979	1029	809	879	710	837	818
154	923	1025	923	739	843	985	1035	814	884	715	842	824
155	929	1030	929	745	848	990	1040	820	890	721	848	830
156	935	1036	935	750	853	996	1046	825	896	726	854	836
157	940	1041	940	756	859	1001	1051	830	901	731	859	842
158	946	1047	946	761	864	1006	1057	836	907	737	865	848
159	951	1052	951	767	870	1012	1062	842	912	742	871	854
160	957	1058	957	772	875	1017	1067	847	918	747	876	860
161	962	1063	962	778	880	1023	1073	853	923	753	882	866
162	968	1069	968	783	886	1028	1078	858	929	758	888	872
163	974	1074	974	789	891	1033	1084	864	935	763	894	878
164	980	1080	980	795	897	1039	1089	870	941	769	899	884
165	985	1085	985	800	902	1044	1094	875	946	774	905	890
166	990	1090	990	805	907	1049	1099	880	951	779	910	895
167	995	1096	995	811	913	1055	1105	886	957	784	916	901
168	1001	1101	1001	816	918	1060	1110	891	962	790	921	906
169	1006	1106	1006	821	923	1066	1116	896	967	796	926	912
170	1011	1111	1011	826	928	1071	1121	901	972	801	931	917
171	1017	1117	1017	832	934	1076	1126	907	978	806	936	924
172	1023	1122	1023	838	939	1081	1131	913	984	811	944	931
173	1029	1128	1029	845	945	1087	1137	919	990	817	950	938
174	1035	1133	1035	850	950	1092	1142	925	996	823	956	944
175	1040	1139	1040	856	956	1098	1148	930	1002	828	961	950
176	1046	1144	1046	862	961	1103	1153	936	1007	833	967	956
177	1051	1150	1051	867	966	1108	1159	941	1013	839	972	962
178	1056	1155	1056	872	971	1113	1164	946	1018	844	977	967
179	1062	1161	1062	878	976	1118	1169	952	1023	849	983	973
180	1068	1166	1068	883	981	1123	1174	957	1029	854	988	978
181	1071	1170	1071	888	986	1128	1179	962	1034	859	993	984
182	1077	1176	1077	893	991	1133	1184	968	1039	865	999	989
183	1082	1181	1082	899	996	1139	1189	972	1044	870	1003	995
184	1090	1188	1090	905	1001	1144	1194	978	1050	876	1009	1001
185	1093	1191	1093	909	1006	1149	1199	983	1054	880	1014	1006
186	1099	1197	1099	915	1011	1154	1204	988	1059	886	1020	1011
187	1106	1204	1106	921	1016	1159	1209	994	1065	892	1025	1018
188	1113	1210	1113	927	1021	1164	1214	999	1070	897	1031	1025
189	1119	1216	1119	933	1026	1169	1219	1005	1076	903	1036	1031
190	1122	1217	1122	938	1031	1174	1224	1008	1081	908	1041	1035
191	1126	1222	1126	942	1036	1179	1229	1015	1088	913	1045	1040



## Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 48 of 95

21 August 2008

	P8A	P8A	P8A	P8A	P8A	P8A	P8A	P8A	P8A	P8A	P8A	P8A	P8A	P8A
Time (min)	P8A/M (°F)	AAAF (°F)	Sec A-A TC #1 (°F)	TC #2 (°F)	Sec A-A TC #1 (°F)	TC #2 (°F)	Sec A-A TC #1 (°F)	TC #2 (°F)	BBAA (°F)	Sec B-B TC #1 (°F)	TC #2 (°F)	Sec B-B TC #1 (°F)	TC #2 (°F)	CCAAE (°F)
192	1133	1027	1127	948	1041	964	1035	1020	1092	918	1051	1046		
193	1143	1033	1133	986	1046	960	1041	1026	1098	924	1057	1058		
194	1145	1038	1138	980	1051	965	1045	1031	1103	928	1062	1058		
195	1150	1043	1143	993	1056	966	1050	1037	1108	935	1065	1060		
196	1156	1046	1146	971	1061	1005	1055	1042	1113	940	1072	1070		
197	1161	1052	1152	976	1065	1009	1060	1047	1118	945	1077	1074		
198	1169	1058	1157	982	1070	1014	1065	1052	1123	950	1083	1081		
199	1174	1063	1163	988	1075	1020	1071	1058	1129	958	1088	1087		
200	1180	1068	1167	993	1080	1025	1075	1063	1134	961	1093	1093		
201	1184	1073	1172	998	1088	1030	1080	1068	1138	966	1098	1098		
202	1188	1077	1176	1003	1089	1034	1084	1072	1143	971	1101	1102		
203	1191	1081	1180	1007	1090	1038	1089	1076	1147	976	1106	1106		
204	1199	1087	1185	1014	1098	1044	1094	1082	1153	982	1111	1113		
205	1200	1091	1188	1018	1102	1048	1098	1086	1157	988	1114	1115		
206	1208	1096	1194	1024	1107	1053	1103	1091	1162	992	1120	1122		
207	1210	1100	1197	1028	1112	1102	1107	1096	1166	996	1124	1126		
208	1217	1105	1202	1034	1116	1062	1112	1101	1172	1002	1126	1128		
209	1220	1110	1206	1039	1121	1066	1117	1105	1176	1007	1133	1136		
210	1228	1114	1211	1044	1125	1071	1121	1110	1181	1012	1137	1142		
211	1233	1120	1216	1050	1130	1076	1127	1116	1186	1017	1142	1148		
212	1234	1124	1219	1054	1134	1081	1131	1120	1190	1022	1147	1151		
213	1242	1128	1225	1060	1139	1085	1136	1125	1196	1027	1151	1158		
214	1248	1133	1229	1065	1143	1090	1140	1129	1200	1032	1156	1162		
215	1252	1138	1233	1071	1148	1095	1145	1134	1208	1037	1160	1168		
216	1256	1143	1238	1076	1152	1099	1149	1138	1209	1042	1164	1172		
217	1259	1147	1241	1080	1156	1103	1153	1143	1213	1047	1168	1176		
218	1261	1151	1245	1085	1160	1107	1157	1146	1216	1051	1171	1179		
219	1269	1156	1250	1090	1164	1112	1162	1152	1223	1056	1177	1186		
220	1272	1160	1253	1094	1168	1117	1168	1156	1227	1061	1180	1190		
221	1273	1163	1255	1097	1173	1121	1169	1159	1230	1065	1183	1192		
222	1278	1168	1257	1099	1178	1125	1172	1162	1232	1068	1186	1190		
223	1277	1170	1261	1103	1180	1129	1176	1166	1238	1073	1190	1197		
224	1284	1174	1264	1108	1184	1132	1182	1170	1239	1077	1193	1201		
225	1283	1177	1267	1111	1187	1136	1184	1174	1242	1082	1197	1204		
226	1287	1181	1271	1116	1191	1140	1187	1177	1245	1086	1200	1208		
227	1292	1185	1275	1121	1195	1144	1192	1182	1250	1091	1204	1213		
228	1296	1190	1279	1126	1199	1148	1196	1186	1254	1096	1208	1217		
229	1299	1198	1282	1129	1200	1152	1199	1190	1258	1100	1212	1221		
230	1302	1197	1285	1134	1204	1156	1203	1194	1261	1104	1215	1224		
231	1304	1200	1288	1137	1210	1160	1207	1197	1264	1108	1216	1227		
232	1307	1204	1291	1141	1214	1164	1210	1200	1267	1112	1222	1231		
233	1308	1207	1293	1143	1217	1168	1213	1204	1270	1116	1226	1233		
234	1311	1210	1296	1147	1221	1171	1216	1207	1273	1120	1226	1236		
235	1315	1214	1300	1151	1224	1175	1220	1211	1277	1125	1232	1240		
236	1318	1219	1303	1155	1227	1179	1224	1215	1280	1129	1236	1243		
237	1322	1222	1306	1160	1232	1183	1228	1219	1285	1133	1240	1248		
238	1324	1225	1309	1163	1235	1186	1231	1223	1288	1137	1243	1251		
239	1327	1228	1312	1167	1239	1190	1234	1227	1291	1142	1247	1255		
240	1331	1232	1316	1171	1242	1194	1238	1230	1294	1146	1250	1258		
Max T	1331	1232	1316	1171	1242	1194	1238	1230	1294	1146	1250	1258		
Max A	1200	1090	1200	1200	1200	1200	1200	1200	1200	1200	1200	1200	1200	1200

**Intertek**



#### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 49 of 95

21 August 2008

Time (min)	P8A Sec C-C TC #9 (°F)	P8A Sec C-C TC #10 (°F)	P8A Sec C-C TC #11 (°F)	P8A DBAve (°F)	P8A Sec D-D TC #12 (°F)	P8A Sec D-D TC #13 (°F)	P8A Sec D-D TC #14 (°F)	P8B P8BMax	P8B AAAVE	P8B Sec A-A TC #1 (°F)	P8B Sec A-A TC #2 (°F)	P8B Sec A-A TC #3 (°F)
0	83	83	82	82	82	82	82	83	82	83	83	82
1	83	83	82	82	82	82	82	83	82	83	83	82
2	83	83	83	83	83	82	83	83	82	83	83	82
3	83	83	82	82	82	82	83	84	82	83	83	82
4	83	83	82	82	82	82	82	84	82	83	83	82
5	83	83	82	82	82	82	83	84	82	82	82	82
6	83	84	83	83	83	82	83	84	83	83	82	82
7	83	84	83	82	82	82	83	85	83	83	82	82
8	83	83	83	82	82	82	83	86	84	84	83	83
9	84	83	83	83	83	82	83	87	84	85	83	83
10	85	83	84	83	83	82	84	88	85	86	83	84
11	85	83	85	83	84	82	84	89	85	86	83	85
12	87	83	86	84	85	82	86	90	87	90	84	86
13	88	84	87	85	86	82	87	92	88	92	84	88
14	89	84	88	86	87	82	88	93	89	93	84	89
15	91	84	89	87	88	83	89	96	91	96	85	91
16	92	84	91	88	90	83	90	98	92	98	86	92
17	93	85	92	89	91	84	92	100	94	100	86	94
18	94	85	94	90	92	84	93	102	95	102	87	96
19	98	89	95	91	94	84	94	105	97	105	88	98
20	98	95	97	92	95	85	95	106	99	108	89	100
21	103	87	98	93	97	85	97	110	101	110	90	103
22	102	88	100	95	99	86	99	113	104	113	92	106
23	105	89	102	97	102	87	101	116	106	116	93	108
24	108	89	105	98	104	87	103	119	108	119	94	113
25	111	90	107	100	107	88	108	123	112	123	96	117
26	115	91	111	103	111	89	109	127	115	127	97	122
27	119	92	114	106	115	90	112	132	119	132	99	128
28	124	94	118	109	119	92	116	137	122	137	101	133
29	129	95	122	112	123	93	120	142	126	142	103	138
30	134	97	126	115	128	94	124	147	130	147	105	144
31	139	98	131	119	133	96	128	152	134	152	108	149
32	144	100	136	123	138	96	133	156	136	156	110	155
33	150	102	140	127	143	100	137	160	142	160	113	160
34	155	105	145	131	149	103	142	166	147	165	116	166
35	160	107	150	135	154	105	147	172	151	170	119	172
36	169	110	155	140	159	108	152	178	156	176	122	178
37	171	113	159	144	165	111	157	182	161	180	125	182
38	177	116	164	149	171	113	162	190	165	182	130	190
39	183	119	169	153	176	116	166	197	171	188	135	197
40	189	122	174	158	182	120	171	204	177	197	139	204
41	199	126	179	163	188	123	177	210	182	205	141	210
42	202	129	184	168	194	127	182	217	186	212	145	217
43	209	133	190	173	201	131	188	224	194	219	149	224
44	215	137	195	178	207	134	193	230	199	226	153	230
45	222	141	201	183	213	138	199	237	217	233	bad/fc	237
46	228	145	207	188	219	142	204	243	224	240	bad/fc	243
47	235	149	213	194	225	147	210	250	230	248	bad/fc	250
48	242	153	218	199	232	151	215	256	238	253	bad/fc	256
49	248	158	224	205	238	156	221	263	242	260	bad/fc	263
50	255	163	230	210	244	160	227	269	248	267	bad/fc	269
51	261	167	235	216	250	165	232	276	254	274	bad/fc	276
52	268	172	241	221	255	169	238	283	261	280	bad/fc	283
53	274	178	247	227	262	174	244	289	267	287	bad/fc	289
54	281	181	253	232	268	178	249	296	273	294	bad/fc	296
55	287	186	259	237	274	183	255	302	279	300	bad/fc	302
56	294	191	264	243	280	188	260	309	285	307	bad/fc	309
57	301	196	270	248	286	193	266	315	292	314	bad/fc	315
58	307	201	275	254	292	198	272	322	298	320	bad/fc	322
59	313	206	282	260	298	203	278	329	304	327	bad/fc	329
60	320	211	287	265	304	208	283	335	311	334	bad/fc	335
61	326	217	293	271	310	213	289	341	317	341	bad/fc	341
62	333	222	299	276	316	218	294	348	323	347	bad/fc	348
63	339	227	305	282	322	223	300	355	329	354	bad/fc	355

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 50 of 95

21 August 2008

Time (min)	Sec C-C TC #9 (°F)	Sec C-C TC #10 (°F)	Sec C-C TC #11 (°F)	P8A DAAve (°F)	Sec D-D TC #12 (°F)	Sec D-D TC #13 (°F)	Sec D-D TC #14 (°F)	P8B P8BMax	P8B AAVAve	Sec A-A TC #1 (°F)	Sec A-A TC #2 (°F)	Sec A-A TC #3 (°F)
54	345	232	310	267	328	228	305	361	335	380	bad/fc	361
55	362	237	318	263	334	233	311	368	342	387	bad/fc	368
56	358	243	322	268	340	238	317	374	348	374	bad/fc	374
57	364	248	327	304	349	243	322	381	355	381	bad/fc	381
58	371	253	333	309	351	248	328	388	362	388	bad/fc	388
59	377	259	339	314	357	253	333	395	368	394	bad/fc	395
60	384	264	345	321	364	259	339	401	374	401	bad/fc	401
71	390	269	351	328	370	264	345	408	381	408	bad/fc	408
72	397	274	356	331	375	269	350	415	387	415	bad/fc	415
73	403	280	362	337	382	274	356	421	393	421	bad/fc	421
74	409	285	368	343	388	280	362	428	400	428	bad/fc	428
75	415	291	374	349	394	285	368	435	406	435	bad/fc	435
76	422	296	380	354	400	290	373	441	412	441	bad/fc	441
77	429	301	385	360	406	296	379	448	419	448	bad/fc	448
78	435	307	391	366	412	301	385	455	426	455	bad/fc	454
79	441	312	397	372	418	306	391	462	432	462	bad/fc	461
80	448	317	403	377	424	311	397	468	438	468	bad/fc	468
81	454	323	408	383	430	316	402	475	445	475	bad/fc	474
82	460	328	414	389	436	322	408	482	452	482	bad/fc	481
83	467	333	420	394	442	327	414	488	458	488	bad/fc	487
84	473	338	425	400	448	332	420	495	464	495	bad/fc	494
85	479	344	431	405	454	338	426	501	471	501	bad/fc	501
86	485	350	437	411	460	343	431	508	477	508	bad/fc	507
87	492	355	443	417	466	348	437	515	483	515	bad/fc	514
88	498	360	449	423	472	354	443	521	490	521	bad/fc	520
89	504	366	454	429	478	359	449	527	496	527	bad/fc	527
90	510	371	460	434	484	364	454	534	502	534	bad/fc	533
91	516	376	466	440	490	370	460	541	508	541	bad/fc	540
92	523	382	471	446	496	375	466	547	515	547	bad/fc	546
93	529	387	477	451	502	380	472	554	521	554	bad/fc	553
94	535	393	483	457	508	386	478	560	527	560	bad/fc	559
95	541	398	489	463	514	391	483	567	534	567	bad/fc	566
96	548	403	494	468	520	396	489	573	541	573	bad/fc	573
97	554	409	500	474	526	402	495	580	547	580	bad/fc	579
98	560	414	506	480	532	407	501	586	553	586	bad/fc	586
99	566	420	511	486	538	412	507	593	560	593	bad/fc	592
100	572	425	517	492	544	418	513	599	566	599	bad/fc	599
101	579	430	523	497	550	423	519	605	572	605	bad/fc	606
102	585	436	528	504	557	429	525	612	579	612	bad/fc	612
103	591	441	534	509	563	434	531	618	585	618	bad/fc	618
104	597	447	540	515	569	439	536	625	591	625	bad/fc	625
105	604	452	546	521	575	445	543	632	598	632	bad/fc	632
106	610	458	552	527	582	451	549	638	604	638	bad/fc	638
107	616	463	557	533	588	457	555	645	610	645	bad/fc	645
108	622	469	563	538	594	461	560	651	617	651	bad/fc	651
109	628	474	569	544	599	467	566	658	623	657	bad/fc	658
110	634	479	575	550	605	473	572	664	629	664	bad/fc	664
111	640	484	580	556	612	478	578	670	635	670	bad/fc	670
112	647	490	586	562	618	483	584	677	641	678	bad/fc	677
113	653	496	592	568	625	489	590	683	647	682	bad/fc	683
114	660	502	598	574	631	495	596	690	654	689	bad/fc	690
115	666	507	603	580	637	501	602	696	660	695	bad/fc	696
116	672	513	609	586	643	506	608	702	666	701	bad/fc	702
117	678	518	615	591	649	511	613	709	673	708	bad/fc	709
118	684	524	621	597	655	517	620	715	679	714	bad/fc	715
119	690	529	626	603	661	523	625	721	685	720	bad/fc	721
120	696	534	632	609	667	528	631	728	691	726	bad/fc	728
121	702	540	638	614	673	533	637	734	697	732	bad/fc	734
122	708	545	643	620	679	539	643	740	703	739	bad/fc	740
123	714	550	649	626	685	544	648	746	709	745	bad/fc	746
124	720	555	654	631	691	549	654	753	715	751	bad/fc	753
125	726	560	660	637	696	554	660	759	722	757	bad/fc	759
126	733	567	666	643	703	561	666	765	728	763	bad/fc	765
127	739	573	672	650	710	567	672	771	734	769	bad/fc	771

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 51 of 95

21 August 2008

Time (min)	P8A Sec C-C TC #9 (°F)	P8A Sec C-C TC #10 (°F)	P8A Sec C-C TC #11 (°F)	P8A D8Ave (°F)	P8A Sec D-D TC #12 (°F)	P8A Sec D-D TC #13 (°F)	P8A Sec D-D TC #14 (°F)	P8B P8BMax	P8B AAAve	P8B Sec A-A TC #1 (°F)	P8B Sec A-A TC #2 (°F)	P8B Sec A-A TC #3 (°F)
128	745	578	577	655	719	572	678	778	740	775	bad/tc	778
129	761	683	683	661	722	577	684	784	746	781	bad/tc	784
130	759	689	689	667	728	683	690	790	752	787	bad/tc	790
131	764	695	695	673	734	688	696	796	758	793	bad/tc	796
132	769	699	700	678	740	593	701	802	794	799	bad/tc	802
133	775	694	705	664	746	598	707	808	769	805	bad/tc	808
134	782	610	712	690	752	604	713	814	775	811	bad/tc	814
135	788	616	718	696	759	610	719	820	781	817	bad/tc	820
136	795	622	724	703	766	617	726	826	787	823	bad/tc	826
137	802	628	730	709	773	623	732	832	793	828	bad/tc	832
138	808	635	736	716	780	629	738	838	799	834	bad/tc	838
139	815	641	742	722	786	635	745	844	804	840	bad/tc	844
140	822	647	748	729	793	642	751	850	810	845	bad/tc	850
141	829	654	754	736	801	649	758	856	816	851	bad/tc	856
142	835	660	760	742	807	655	764	861	822	857	bad/tc	861
143	841	666	766	748	814	661	770	867	827	862	bad/tc	867
144	848	672	772	755	821	667	777	873	833	868	bad/tc	873
145	854	678	778	761	827	673	783	879	839	873	bad/tc	879
146	860	684	784	767	833	679	789	884	844	878	bad/tc	884
147	867	690	790	774	840	686	796	890	850	884	bad/tc	890
148	873	696	796	780	846	692	802	896	856	890	bad/tc	896
149	880	703	801	786	853	698	808	901	861	895	bad/tc	901
150	885	709	807	792	859	704	814	907	866	900	bad/tc	907
151	892	715	813	798	865	710	820	912	871	905	bad/tc	912
152	898	721	819	805	872	716	826	918	877	910	bad/tc	918
153	904	727	824	811	878	722	833	923	882	916	bad/tc	923
154	910	733	830	817	884	728	839	929	888	921	bad/tc	929
155	919	739	838	823	891	734	844	934	893	926	bad/tc	934
156	922	745	841	829	897	740	851	939	898	931	bad/tc	939
157	928	751	847	835	903	746	857	945	904	936	bad/tc	945
158	934	757	853	842	910	753	863	950	909	942	bad/tc	950
159	940	763	859	848	916	759	869	956	914	947	bad/tc	956
160	946	769	864	854	922	764	875	961	919	952	bad/tc	961
161	952	775	870	860	928	771	881	966	925	957	bad/tc	966
162	958	781	876	865	933	776	886	972	930	962	bad/tc	972
163	965	787	882	872	941	783	893	977	935	967	bad/tc	977
164	971	794	888	878	947	790	900	982	940	972	bad/tc	982
165	977	800	893	885	953	796	905	988	946	978	bad/tc	988
166	982	805	898	889	958	800	910	993	951	982	bad/tc	993
167	988	811	904	895	965	807	917	998	956	988	bad/tc	998
168	993	817	909	902	970	813	922	1003	961	992	bad/tc	1003
169	998	822	915	907	976	818	928	1009	966	997	bad/tc	1009
170	1004	827	920	912	981	823	933	1014	972	1003	bad/tc	1014
171	1012	834	927	919	988	830	940	1019	976	1007	bad/tc	1019
172	1018	841	933	927	995	836	947	1024	982	1013	bad/tc	1024
173	1026	849	939	934	1003	845	954	1029	987	1017	bad/tc	1029
174	1032	855	945	941	1010	852	960	1034	992	1022	bad/tc	1034
175	1038	862	950	947	1017	859	966	1039	997	1027	bad/tc	1039
176	1045	868	956	953	1023	865	972	1044	1002	1032	bad/tc	1044
177	1050	875	962	960	1029	872	978	1049	1007	1037	bad/tc	1049
178	1055	880	967	965	1035	878	983	1054	1011	1041	bad/tc	1054
179	1062	885	972	971	1040	883	989	1059	1016	1046	bad/tc	1059
180	1068	892	977	976	1046	889	994	1064	1021	1051	bad/tc	1064
181	1071	898	983	982	1051	895	1000	1069	1026	1056	bad/tc	1069
182	1077	903	988	987	1056	900	1005	1074	1031	1061	bad/tc	1074
183	1082	909	993	993	1063	906	1011	1079	1036	1065	bad/tc	1079
184	1090	915	999	999	1069	912	1017	1084	1041	1070	bad/tc	1084
185	1093	920	1004	1008	1074	918	1022	1088	1046	1075	bad/tc	1088
186	1099	929	1009	1010	1079	923	1027	1093	1051	1079	bad/tc	1093
187	1108	933	1015	1017	1086	931	1034	1098	1055	1084	bad/tc	1098
188	1113	941	1021	1024	1093	936	1040	1103	1060	1089	bad/tc	1103
189	1119	947	1027	1030	1100	945	1046	1108	1065	1093	bad/tc	1108
190	1122	952	1031	1035	1104	950	1051	1112	1070	1098	bad/tc	1112
191	1128	957	1036	1040	1109	955	1055	1117	1075	1103	bad/tc	1117

Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 52 of 95

21 August 2008

	Time (min)	PSA Sec C-C TC #9 (°F)	PSA Sec C-C TC #10 (°F)	PSA Sec C-C TC #11 (°F)	PSA DAAve (°F)	PSA Sec D-D TC #12 (°F)	PSA Sec D-D TC #13 (°F)	PSA Sec D-D TC #14 (°F)	P8B P8BMax	P8B AAAVE	P8B Sec A-A TC #1 (°F)	P8B Sec A-A TC #2 (°F)	P8B Sec A-A TC #3 (°F)
	192	1133	984	1042	1048	1115	991	1062	1122	1079	1107	bad/flc	1122
	193	1143	972	1040	1055	1124	970	1070	1127	1084	1112	bad/flc	1127
	194	1145	977	1053	1060	1129	976	1074	1131	1089	1116	bad/flc	1131
	195	1150	983	1058	1065	1134	981	1079	1136	1093	1121	bad/flc	1136
	196	1156	989	1064	1070	1140	987	1084	1141	1099	1126	bad/flc	1141
	197	1161	994	1068	1075	1144	992	1089	1145	1103	1130	bad/flc	1145
	198	1169	1001	1074	1082	1151	999	1095	1150	1108	1135	bad/flc	1150
	199	1174	1008	1080	1089	1158	1006	1102	1154	1112	1139	bad/flc	1154
	200	1180	1014	1085	1094	1164	1012	1108	1159	1117	1144	bad/flc	1159
	201	1184	1019	1089	1098	1168	1016	1110	1163	1121	1148	bad/flc	1163
	202	1188	1023	1094	1103	1173	1021	1115	1167	1126	1153	bad/flc	1167
	203	1191	1028	1098	1107	1177	1026	1119	1172	1130	1157	bad/flc	1172
	204	1199	1035	1105	1114	1184	1033	1125	1176	1135	1161	bad/flc	1176
	205	1209	1038	1108	1117	1187	1036	1128	1181	1139	1166	bad/flc	1181
	206	1208	1045	1114	1124	1194	1043	1134	1185	1144	1170	bad/flc	1185
	207	1209	1049	1118	1127	1199	1047	1137	1189	1148	1174	bad/flc	1189
	208	1217	1058	1123	1133	1203	1054	1143	1193	1152	1178	bad/flc	1193
	209	1220	1061	1128	1138	1208	1056	1147	1196	1157	1183	bad/flc	1196
	210	1228	1069	1133	1143	1213	1063	1152	1202	1161	1187	bad/flc	1202
	211	1233	1072	1139	1150	1220	1071	1159	1206	1165	1191	bad/flc	1206
	212	1236	1078	1143	1155	1225	1076	1163	1210	1170	1196	bad/flc	1210
	213	1242	1084	1148	1160	1232	1082	1169	1214	1174	1200	bad/flc	1214
	214	1248	1088	1153	1165	1235	1087	1172	1219	1179	1204	bad/flc	1219
	215	1252	1094	1158	1171	1241	1093	1178	1222	1182	1208	bad/flc	1222
	216	1258	1099	1162	1175	1245	1098	1182	1226	1187	1213	bad/flc	1226
	217	1259	1104	1165	1179	1249	1102	1185	1230	1191	1217	bad/flc	1230
	218	1264	1108	1171	1183	1253	1107	1190	1235	1195	1221	bad/flc	1235
	219	1269	1114	1175	1189	1259	1113	1195	1238	1199	1225	bad/flc	1238
	220	1272	1117	1180	1194	1263	1117	1201	1242	1203	1229	bad/flc	1242
	221	1273	1120	1183	1197	1266	1120	1204	1246	1207	1233	bad/flc	1246
	222	1273	1120	1183	1197	1266	1121	1207	1250	1211	1237	bad/flc	1250
	223	1277	1125	1190	1202	1270	1125	1210	1254	1215	1241	bad/flc	1254
	224	1281	1129	1194	1205	1273	1129	1214	1258	1220	1245	bad/flc	1258
	225	1283	1132	1197	1209	1279	1133	1217	1291	1223	1248	bad/flc	1261
	226	1287	1136	1201	1212	1279	1136	1220	1295	1227	1252	bad/flc	1295
	227	1292	1142	1205	1216	1284	1141	1224	1299	1231	1256	bad/flc	1299
	228	1298	1147	1209	1221	1288	1147	1228	1273	1235	1260	bad/flc	1273
	229	1299	1150	1213	1224	1291	1150	1232	1276	1239	1264	bad/flc	1276
	230	1302	1155	1217	1229	1295	1155	1236	1280	1243	1267	bad/flc	1280
	231	1304	1158	1220	1231	1297	1156	1239	1283	1247	1271	bad/flc	1283
	232	1307	1161	1224	1234	1300	1161	1242	1287	1251	1275	bad/flc	1287
	233	1308	1163	1227	1237	1301	1163	1246	1290	1254	1278	bad/flc	1290
	234	1311	1167	1231	1239	1304	1166	1249	1294	1258	1282	bad/flc	1294
	235	1315	1171	1235	1244	1308	1171	1252	1297	1261	1286	bad/flc	1297
	236	1317	1174	1238	1247	1311	1174	1256	1301	1265	1289	bad/flc	1301
	237	1322	1180	1242	1252	1316	1180	1260	1305	1269	1293	bad/flc	1305
	238	1324	1183	1245	1255	1318	1183	1263	1308	1272	1296	bad/flc	1308
	239	1327	1187	1250	1258	1321	1186	1267	1311	1275	1300	bad/flc	1311
	240	1331	1191	1253	1262	1325	1190	1270	1315	1280	1304	bad/flc	1315
	Max T:	1331	1191	1253	1262	1325	1190	1270	1315	1280	1304	bad/flc	1315
	Max A:	1209	1200	1200	1000	1200	1200	1200	1290	1000	1200	1200	1200

Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 53 of 95

21 August 2008

Time (min)	P88 Sec A-A TC #4 (°F)	P88 Sec A-A TC #5 (°F)	P88 BBAve	P88 Sec B-B TC #6 (°F)	P88 Sec B-B TC #7 (°F)	P88 Sec B-B TC #8 (°F)	P88 CCAve	P88 Sec C-C TC #9 (°F)	P88 Sec C-C TC #10 (°F)	P88 Sec C-C TC #11 (°F)	P88 DDAve	P88 Sec D-D TC #12 (°F)	P88 Sec D-D TC #13 (°F)
0	82	82	82	82	82	82	83	82	83	83	82	83	82
1	82	82	82	82	82	82	83	82	83	83	82	83	82
2	82	82	82	82	82	82	83	83	83	83	82	83	82
3	82	82	82	82	82	82	83	83	83	83	83	83	84
4	82	82	82	82	82	82	83	83	83	83	83	83	84
5	82	83	82	81	82	82	83	82	83	83	82	84	81
6	82	84	82	81	82	82	83	81	84	83	82	84	81
7	82	85	81	80	82	82	83	81	84	83	82	84	81
8	83	86	82	81	82	83	83	82	85	83	82	85	82
9	83	87	82	81	82	83	84	83	86	84	83	86	82
10	84	88	83	82	82	84	84	84	86	84	83	86	81
11	84	89	83	83	82	84	85	85	86	85	83	86	82
12	85	90	84	84	82	86	86	86	86	86	84	87	82
13	88	91	85	86	82	87	87	86	87	86	85	89	82
14	87	93	86	87	82	88	87	88	88	88	86	90	82
15	88	94	88	88	82	89	88	89	89	89	87	92	82
16	89	96	88	90	82	91	90	92	87	91	88	94	82
17	91	98	89	91	83	93	91	93	87	92	89	95	83
18	92	100	90	93	83	95	92	95	88	93	90	97	83
19	94	102	92	94	84	97	93	98	89	95	92	98	84
20	98	104	93	96	84	98	96	98	90	96	93	100	84
21	98	106	95	98	85	101	95	100	90	96	94	102	85
22	100	108	98	100	86	103	98	102	91	100	98	104	86
23	103	110	98	102	87	106	100	105	92	102	97	108	86
24	105	112	100	105	87	109	102	108	92	105	99	109	87
25	108	114	103	108	89	113	104	111	93	106	102	112	88
26	111	117	106	112	90	116	108	114	94	111	104	115	89
27	115	120	109	118	91	121	109	118	95	115	107	119	90
28	118	123	113	121	92	126	113	122	97	119	110	123	91
29	122	126	117	126	94	131	116	126	98	123	113	128	92
30	128	129	121	131	96	136	119	131	99	127	117	133	94
31	130	133	125	137	98	141	123	138	101	132	120	138	95
32	134	137	129	142	100	146	127	141	103	137	124	143	97
33	139	140	133	146	103	150	131	148	105	141	129	149	99
34	143	144	137	150	105	155	135	151	107	148	133	154	101
35	148	148	141	154	108	161	139	158	109	151	138	160	104
36	153	153	145	159	111	166	143	161	112	156	141	165	106
37	159	158	150	165	114	172	148	167	115	161	147	171	110
38	163	162	155	170	117	177	152	172	118	165	151	177	112
39	169	167	160	175	120	184	156	178	121	170	155	183	116
40	174	172	165	181	124	189	162	185	124	179	160	190	119
41	179	177	170	187	127	196	167	191	127	182	166	197	122
42	184	182	175	194	131	201	172	198	131	188	171	204	126
43	189	188	181	201	135	208	178	204	134	195	176	210	130
44	195	193	187	207	139	214	183	211	138	201	182	217	134
45	201	199	192	214	143	220	189	217	142	207	187	223	138
46	207	204	199	221	148	227	194	224	146	213	193	230	142
47	212	209	204	227	152	233	200	230	150	219	196	237	146
48	218	215	210	234	157	239	206	237	155	228	204	243	150
49	224	221	218	240	162	246	211	243	160	231	210	249	155
50	230	226	222	247	167	252	217	250	164	238	216	256	159
51	235	232	228	254	172	259	223	256	169	244	222	262	164
52	241	238	234	260	177	265	229	263	174	250	227	268	169
53	247	244	240	267	182	272	235	269	179	256	233	275	173
54	253	249	246	273	188	278	240	275	184	262	239	281	178
55	259	255	253	280	193	285	246	282	189	268	245	287	183
56	265	261	259	286	198	292	252	288	194	274	250	293	188
57	271	267	265	293	204	298	258	295	199	280	256	299	193
58	277	273	271	299	209	305	264	301	204	287	262	305	198
59	282	279	277	306	215	311	270	307	210	293	267	311	203
60	288	285	283	312	220	318	276	314	215	299	273	317	208
61	294	290	290	319	226	324	282	320	220	305	279	323	213
62	301	297	296	325	231	331	288	327	226	311	285	330	219
63	308	302	302	332	237	337	294	333	231	317	291	336	224



Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 54 of 95

21 August 2008

Time (min)	P8B Sec A-A TC #4 (°F)	P8B Sec A-A TC #5 (°F)	P8B BB-Ave	P8B Sec B-B TC #6 (°F)	P8B Sec B-B TC #7 (°F)	P8B Sec B-B TC #8 (°F)	P8B CCAve	P8B Sec C-C TC #9 (°F)	P8B Sec C-C TC #10 (°F)	P8B Sec C-C TC #11 (°F)	P8B DDAve	P8B Sec D-D TC #12 (°F)	P8B Sec D-D TC #13 (°F)
54	312	308	308	338	242	344	299	339	236	323	296	342	229
55	319	314	315	345	248	351	308	348	242	330	302	348	234
56	325	320	321	351	254	357	311	351	247	335	308	354	240
57	331	327	327	358	259	363	316	358	253	342	314	360	246
58	337	333	333	365	265	370	323	364	258	348	319	366	250
59	343	339	339	371	271	376	329	370	263	354	325	372	256
70	349	345	340	378	277	383	335	377	269	360	332	379	261
71	355	351	352	385	282	389	341	383	274	366	337	385	266
72	362	357	358	391	288	396	346	390	280	373	343	391	271
73	368	353	354	398	293	402	353	396	285	379	349	397	277
74	374	359	370	404	299	408	359	402	291	385	355	403	282
75	380	375	377	411	304	415	366	409	296	392	361	410	287
76	386	381	383	417	310	421	371	415	301	398	367	416	293
77	393	388	380	424	316	427	377	421	307	404	373	423	298
78	399	394	395	431	321	433	383	427	312	410	379	429	303
79	405	400	401	437	327	439	389	433	318	416	385	435	309
80	411	406	407	444	332	446	395	440	323	423	391	441	314
81	418	412	414	451	338	452	401	446	329	429	397	447	320
82	424	419	419	457	343	458	407	452	335	435	403	454	325
83	430	425	426	464	349	464	413	458	340	441	409	460	331
84	436	431	432	470	355	471	420	465	346	448	415	466	336
85	443	437	438	476	360	477	425	471	351	454	421	472	342
86	449	443	444	483	365	483	431	477	356	460	427	479	347
87	455	449	450	489	371	489	437	483	362	466	433	485	353
88	461	455	456	496	377	496	443	490	367	472	438	491	358
89	467	462	462	502	382	501	449	495	373	478	444	497	363
90	474	468	468	509	388	507	455	502	378	484	451	504	369
91	480	474	474	515	393	513	461	508	384	491	457	510	375
92	486	480	480	521	399	520	467	514	389	497	463	517	380
93	492	486	486	528	405	526	473	521	395	503	469	523	386
94	498	492	492	534	410	532	478	528	400	509	475	529	391
95	505	499	498	540	416	538	485	533	406	515	481	536	397
96	511	505	504	547	421	544	490	539	411	521	487	542	403
97	517	511	510	553	426	550	496	545	417	527	493	548	408
98	523	517	518	559	432	556	502	552	422	533	499	555	413
99	529	524	522	566	437	562	508	558	428	539	505	561	419
100	535	530	528	572	443	568	514	564	433	545	511	567	425
101	542	536	534	578	449	575	520	570	439	551	517	574	430
102	548	542	539	584	454	580	526	577	444	557	523	580	436
103	554	548	546	591	459	587	532	583	450	563	529	586	441
104	560	554	552	597	465	593	538	589	455	569	535	593	447
105	567	560	558	604	470	599	544	595	461	575	541	599	453
106	573	567	564	610	476	605	550	602	466	581	547	605	458
107	579	573	569	616	481	611	555	608	471	587	554	612	464
108	585	579	575	622	487	617	561	614	477	593	560	618	470
109	591	585	581	629	492	623	567	620	482	599	566	625	475
110	597	591	588	635	498	630	573	626	488	605	572	631	481
111	603	597	593	641	503	636	579	632	493	611	578	637	486
112	609	603	599	647	509	642	584	638	498	617	584	644	492
113	615	609	605	653	514	648	590	644	504	622	590	650	497
114	622	616	611	659	520	654	596	651	509	628	596	656	503
115	628	622	617	666	525	660	602	657	515	634	602	662	508
116	634	628	623	672	531	666	608	663	520	640	608	669	514
117	640	634	629	678	536	672	613	669	525	648	614	675	520
118	646	640	634	684	541	678	619	675	530	652	620	681	525
119	652	646	640	690	547	684	625	681	536	658	627	687	531
120	658	652	646	696	552	690	630	687	541	663	633	694	536
121	664	658	652	702	557	696	636	693	546	669	639	700	542
122	670	664	658	708	563	702	642	699	552	675	645	706	547
123	676	670	663	714	568	708	648	705	557	681	651	712	553
124	682	676	669	720	573	714	653	711	563	688	657	719	558
125	688	682	675	726	579	719	659	717	568	692	663	725	564
126	694	688	680	732	584	725	665	723	573	698	669	731	569
127	700	694	686	738	589	731	670	729	578	704	674	737	574



### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 55 of 95

21 August 2008

Time (min)	P8B Sec A-A TC #4 (°F)	P8B Sec A-A TC #5 (°F)	P8B BB Ave	P8B Sec B-B TC #6 (°F)	P8B Sec B-B TC #7 (°F)	P8B Sec B-B TC #8 (°F)	P8B CC Ave	P8B Sec C-C TC #9 (°F)	P8B Sec C-C TC #10 (°F)	P8B Sec C-C TC #11 (°F)	P8B DD Ave	P8B Sec D-D TC #12 (°F)	P8B Sec D-D TC #13 (°F)
128	708	700	692	744	595	737	676	735	583	709	680	743	580
129	712	705	696	750	600	743	682	741	580	715	686	740	585
130	718	711	703	756	605	746	687	747	594	721	692	756	591
131	724	717	709	762	610	755	693	753	596	727	698	762	596
132	730	723	715	768	615	761	698	759	604	732	704	768	602
133	735	729	721	774	621	767	704	765	609	738	710	774	607
134	741	735	726	779	626	773	709	770	615	743	715	780	612
135	747	741	732	785	632	778	715	776	620	749	721	786	618
136	753	746	737	791	637	784	721	782	625	755	727	792	623
137	759	752	743	797	642	790	726	788	630	760	732	798	628
138	764	758	749	803	647	796	731	793	635	766	738	804	633
139	770	763	754	808	653	802	737	799	640	771	744	810	639
140	776	769	760	814	658	807	742	805	645	777	750	816	644
141	782	775	766	820	663	813	748	811	651	782	756	822	650
142	788	780	771	825	669	819	753	819	656	788	761	828	655
143	793	786	778	831	674	824	759	822	661	793	767	834	660
144	799	792	782	837	679	830	764	828	666	799	773	840	666
145	805	797	787	842	684	835	769	833	671	804	778	845	671
146	810	803	793	848	690	841	775	839	677	809	783	851	676
147	816	808	798	853	695	846	780	844	682	815	789	857	682
148	821	814	804	859	700	852	786	850	687	821	795	863	687
149	827	819	809	864	705	857	791	855	692	826	800	868	692
150	833	825	814	869	711	863	796	861	697	831	806	874	698
151	838	830	820	875	716	868	801	866	702	836	811	880	703
152	843	836	825	880	721	873	807	871	708	841	816	885	708
153	849	841	830	885	727	878	812	877	713	847	822	891	714
154	854	847	836	891	732	884	817	882	718	852	827	897	719
155	859	852	841	896	737	889	822	887	723	857	833	902	724
156	865	857	846	901	742	895	828	893	728	862	838	907	729
157	871	862	852	907	748	900	833	898	734	868	844	913	735
158	876	868	857	912	753	906	839	904	739	873	849	919	740
159	881	873	862	917	758	911	844	909	744	879	854	924	745
160	886	878	867	922	763	916	849	914	749	883	859	930	751
161	892	883	872	928	768	921	854	919	754	889	865	935	756
162	897	889	878	933	774	926	859	925	759	894	870	941	761
163	902	894	883	938	779	932	864	930	764	899	875	946	766
164	908	899	888	943	784	937	869	935	769	904	881	952	772
165	913	904	893	948	789	942	875	941	774	909	886	957	777
166	918	910	898	953	794	947	880	946	779	914	891	962	782
167	924	915	904	959	799	953	885	951	785	919	897	968	787
168	929	920	909	964	805	958	890	956	790	924	902	973	792
169	934	925	914	969	810	963	895	961	794	929	908	979	796
170	939	930	919	974	815	968	900	967	800	934	913	984	802
171	944	935	924	979	820	973	905	972	804	939	918	989	806
172	950	941	929	984	825	979	910	977	810	944	923	995	813
173	955	945	934	989	830	984	915	982	814	949	928	1000	818
174	960	950	939	994	835	989	920	987	819	954	933	1005	824
175	965	955	945	999	840	994	925	992	824	959	938	1010	829
176	970	960	950	1004	845	999	930	997	829	964	943	1015	834
177	975	965	955	1009	851	1004	935	1002	835	969	949	1021	839
178	980	970	960	1014	855	1009	940	1007	839	973	954	1026	844
179	985	975	965	1019	861	1014	945	1012	845	978	959	1031	849
180	990	980	970	1024	865	1019	950	1017	850	983	964	1036	854
181	995	985	974	1028	871	1024	955	1022	854	988	969	1041	859
182	1000	990	980	1033	877	1029	960	1027	860	993	974	1046	865
183	1005	995	985	1038	882	1034	965	1031	865	998	979	1051	870
184	1010	1000	990	1043	887	1039	970	1037	870	1002	984	1056	875
185	1015	1005	995	1048	892	1044	974	1041	875	1007	989	1061	880
186	1020	1010	1000	1053	897	1049	979	1046	880	1012	994	1066	886
187	1025	1014	1004	1057	902	1053	984	1051	885	1017	999	1071	891
188	1030	1019	1009	1062	907	1058	989	1056	890	1021	1004	1076	896
189	1035	1024	1014	1067	912	1063	994	1061	895	1026	1009	1081	901
190	1040	1029	1019	1072	917	1068	999	1066	900	1031	1014	1086	906
191	1045	1034	1024	1076	922	1073	1004	1070	905	1036	1019	1090	911

Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 56 of 95

21 August 2008

Time (min)	P8B Sec A-A TC #4 (°F)	P8B Sec A-A TC #5 (°F)	P8B BBave	P8B Sec B-B TC #6 (°F)	P8B Sec B-B TC #7 (°F)	P8B Sec B-B TC #8 (°F)	P8B CCave	P8B Sec C-C TC #9 (°F)	P8B Sec C-C TC #10 (°F)	P8B Sec C-C TC #11 (°F)	P8B DDave	P8B Sec D-D TC #12 (°F)	P8B Sec D-D TC #13 (°F)
192	1049	1039	1029	1081	927	1078	1008	1075	910	1040	1024	1085	916
193	1054	1043	1034	1088	933	1082	1013	1080	915	1045	1029	1100	921
194	1059	1048	1038	1090	938	1087	1018	1085	920	1050	1033	1105	926
195	1064	1052	1043	1095	943	1092	1023	1089	925	1054	1038	1110	931
196	1069	1058	1048	1100	948	1097	1028	1094	930	1059	1044	1115	937
197	1073	1052	1052	1104	952	1101	1032	1099	934	1064	1048	1119	942
198	1078	1057	1057	1109	957	1106	1037	1103	939	1068	1053	1124	947
199	1083	1072	1062	1114	962	1111	1042	1108	944	1073	1058	1129	952
200	1087	1078	1067	1118	968	1115	1047	1113	949	1078	1063	1133	957
201	1092	1081	1072	1123	973	1120	1051	1117	954	1082	1068	1138	962
202	1097	1085	1078	1127	977	1125	1056	1122	959	1087	1072	1143	967
203	1101	1090	1081	1132	982	1129	1061	1126	964	1092	1077	1147	972
204	1108	1095	1086	1138	987	1134	1065	1131	969	1098	1082	1152	977
205	1111	1099	1090	1141	992	1138	1070	1135	974	1101	1087	1157	982
206	1115	1104	1095	1145	997	1143	1075	1140	979	1105	1091	1161	987
207	1120	1108	1100	1150	1002	1148	1079	1144	984	1110	1096	1166	992
208	1124	1113	1104	1154	1007	1152	1084	1149	989	1114	1100	1170	997
209	1129	1118	1109	1159	1012	1157	1088	1153	993	1118	1105	1174	1002
210	1133	1122	1114	1163	1017	1161	1093	1157	998	1123	1109	1179	1006
211	1137	1128	1118	1167	1022	1165	1097	1161	1003	1127	1114	1183	1011
212	1142	1131	1123	1172	1027	1170	1102	1166	1008	1132	1119	1188	1016
213	1146	1135	1127	1176	1032	1174	1106	1170	1013	1136	1124	1192	1022
214	1151	1140	1132	1181	1037	1178	1111	1174	1018	1141	1128	1197	1028
215	1155	1144	1136	1185	1041	1183	1115	1178	1022	1145	1132	1201	1031
216	1159	1148	1141	1189	1046	1187	1120	1183	1027	1149	1137	1205	1036
217	1164	1153	1145	1193	1051	1191	1124	1187	1032	1153	1141	1209	1041
218	1168	1157	1150	1197	1055	1195	1129	1191	1037	1158	1145	1214	1046
219	1172	1161	1154	1201	1061	1200	1133	1195	1041	1162	1150	1218	1051
220	1176	1166	1159	1206	1066	1204	1137	1199	1046	1166	1155	1222	1055
221	1180	1170	1163	1210	1070	1208	1141	1203	1051	1170	1159	1226	1060
222	1184	1174	1167	1214	1075	1212	1145	1207	1056	1174	1163	1230	1065
223	1189	1178	1172	1218	1080	1217	1150	1211	1060	1179	1168	1234	1070
224	1193	1182	1175	1222	1084	1221	1154	1215	1065	1183	1172	1238	1074
225	1197	1187	1180	1226	1089	1225	1159	1219	1070	1187	1176	1242	1079
226	1201	1191	1184	1230	1094	1229	1163	1223	1074	1191	1180	1246	1084
227	1205	1195	1188	1234	1098	1233	1167	1227	1079	1195	1185	1250	1089
228	1209	1199	1192	1237	1103	1236	1171	1231	1083	1199	1189	1254	1093
229	1213	1203	1196	1241	1107	1240	1175	1235	1088	1203	1193	1258	1098
230	1217	1207	1200	1245	1112	1244	1179	1238	1092	1207	1197	1261	1102
231	1221	1211	1204	1249	1116	1248	1183	1242	1097	1211	1201	1265	1107
232	1225	1215	1208	1253	1121	1252	1188	1246	1102	1215	1205	1269	1111
233	1228	1219	1213	1257	1125	1256	1191	1250	1106	1218	1209	1273	1116
234	1232	1222	1215	1260	1129	1260	1195	1254	1110	1222	1213	1277	1120
235	1236	1226	1220	1264	1134	1263	1199	1257	1115	1226	1217	1280	1124
236	1240	1230	1224	1268	1138	1267	1203	1261	1119	1230	1221	1284	1129
237	1243	1234	1228	1272	1142	1271	1207	1264	1124	1234	1225	1288	1133
238	1247	1238	1232	1275	1147	1275	1211	1268	1128	1238	1228	1291	1137
239	1251	1241	1235	1279	1151	1278	1215	1272	1132	1242	1233	1295	1142
240	1255	1245	1240	1283	1155	1283	1219	1276	1136	1246	1237	1299	1146
Max T:	1255	1245	1240	1283	1155	1283	1219	1276	1136	1246	1237	1299	1146
Max A:	1200	1200	1000	1200	1200	1200	1000	1200	1200	1200	1000	1200	1200

## Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 57 of 95

21 August 2008

[illegible]

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 58 of 95

21 August 2008

Time (min)	P88 Sec D-D TC #14 (°F)	P11 P11Max	P11 AA Ave	P11 Sec A-A TC #1 (°F)	P11 Sec A-A TC #2 (°F)	P11 Sec A-A TC #3 (°F)	P11 Sec A-A TC #4 (°F)	P11 Sec A-A TC #5 (°F)	P11 BB Ave	P11 Sec B-B TC #6 (°F)	P11 Sec B-B TC #7 (°F)	P11 Sec B-B TC #8 (°F)
54	318	202	178	199	149	198	173	173	171	185	138	190
55	324	208	182	204	152	200	177	177	178	189	141	194
56	330	210	188	209	155	205	180	180	179	194	144	198
57	338	214	190	214	159	210	184	185	182	198	147	202
58	342	219	195	219	162	215	188	189	187	203	150	207
59	348	224	199	224	166	220	192	193	191	208	154	211
60	355	229	203	229	169	224	197	197	195	212	157	216
61	361	234	208	234	173	229	201	202	199	217	160	220
62	367	239	212	239	177	234	205	206	203	221	164	224
63	373	244	216	244	181	238	209	210	207	225	168	228
64	379	248	221	248	185	243	214	215	211	230	171	233
65	385	253	225	253	189	248	219	219	216	235	175	237
66	392	258	230	258	193	252	222	223	220	239	179	241
67	398	263	234	263	197	257	227	228	224	244	182	245
68	404	267	239	267	201	262	231	232	229	248	186	250
69	410	272	243	272	205	266	235	237	232	253	190	254
70	417	277	247	277	209	271	239	241	238	257	194	258
71	423	282	252	282	213	276	244	246	241	262	197	263
72	429	286	256	286	217	281	248	250	245	266	201	267
73	436	291	261	291	221	286	253	254	249	271	205	271
74	442	296	265	296	225	290	257	258	253	275	208	276
75	448	301	270	301	229	295	262	263	257	279	213	280
76	454	305	275	305	234	300	266	268	262	284	217	285
77	460	310	279	310	238	305	271	272	266	288	221	289
78	466	315	284	315	242	309	275	277	270	293	225	293
79	473	320	288	320	246	314	280	281	275	297	229	298
80	479	324	293	324	251	319	284	286	279	301	233	302
81	485	329	297	329	255	323	288	290	283	306	237	307
82	491	334	302	334	259	328	293	294	287	310	241	311
83	498	338	306	338	264	333	297	299	292	315	245	315
84	504	343	311	343	268	338	302	303	296	319	249	320
85	510	348	315	348	272	343	306	307	300	323	253	324
86	516	353	320	353	276	347	311	312	305	328	257	329
87	523	357	324	357	281	352	316	316	309	332	261	333
88	529	362	329	362	285	357	320	321	313	336	265	338
89	535	367	334	367	289	362	325	325	317	341	269	342
90	541	372	338	372	294	367	329	330	322	345	273	347
91	548	378	343	378	298	371	334	334	328	349	277	351
92	554	381	347	381	302	376	338	339	330	354	281	356
93	560	385	352	385	307	381	343	343	334	358	285	360
94	566	391	357	391	311	386	348	347	339	363	289	365
95	573	396	361	396	316	391	352	352	343	367	293	369
96	579	401	366	401	319	396	357	356	348	372	297	374
97	585	406	371	406	324	401	362	361	352	376	301	379
98	591	410	375	410	328	405	366	365	356	380	305	383
99	598	415	380	415	332	410	371	370	361	385	309	388
100	604	420	384	420	337	415	375	374	365	389	313	392
101	610	424	389	424	341	420	380	379	369	394	317	396
102	617	429	393	429	345	425	385	383	373	398	321	401
103	623	434	398	434	350	430	389	388	378	403	325	406
104	629	439	403	439	354	435	394	393	382	407	329	410
105	635	444	407	444	358	439	399	397	387	412	333	415
106	641	448	412	448	362	444	403	401	391	416	337	419
107	647	453	417	453	367	449	408	408	395	420	341	424
108	654	458	421	458	371	454	412	410	399	425	345	428
109	662	463	426	463	376	458	417	415	404	429	349	433
110	668	467	430	467	380	463	422	419	408	434	353	437
111	675	472	435	472	384	468	426	424	413	438	358	442
112	681	477	439	477	388	473	431	428	417	443	362	447
113	687	481	444	481	393	478	436	433	421	447	366	451
114	694	486	448	486	397	482	440	437	425	452	370	456
115	700	491	453	491	402	487	445	442	430	456	374	460
116	708	496	458	496	406	492	450	448	434	460	378	465
117	712	500	462	500	410	497	454	451	439	465	382	469

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 59 of 95

21 August 2008

Time (min)	P8B Sec D-D TC #14 (°F)	P11 P11Max	P11 AA Ave	P11 Sec A-A TC #1 (°F)	P11 Sec A-A TC #2 (°F)	P11 Sec A-A TC #3 (°F)	P11 Sec A-A TC #4 (°F)	P11 Sec A-A TC #5 (°F)	P11 BB Ave	P11 Sec B-B TC #6 (°F)	P11 Sec B-B TC #7 (°F)	P11 Sec B-B TC #8 (°F)
128	718	505	467	505	415	501	459	455	443	489	386	474
129	724	510	472	510	410	508	483	480	447	474	390	478
130	730	514	478	514	423	511	488	484	452	478	394	483
131	738	519	481	519	427	516	472	480	458	483	398	487
132	742	524	485	524	432	520	477	473	461	487	403	492
133	748	528	489	528	436	525	481	477	464	491	406	496
134	754	533	494	533	440	530	489	482	469	496	411	501
135	760	538	499	538	445	535	491	486	473	500	415	505
136	765	542	503	542	449	539	495	491	478	505	419	510
137	771	547	508	547	453	544	500	495	482	509	423	515
138	777	552	512	552	457	549	504	500	487	514	427	519
139	783	556	517	556	462	553	509	504	491	518	431	523
140	789	561	521	561	468	558	513	509	495	522	435	528
141	795	565	526	565	470	563	518	513	499	527	439	532
142	800	570	531	570	475	568	522	518	504	531	443	537
143	808	575	536	575	479	572	527	522	508	536	447	542
144	812	579	539	579	483	577	531	526	512	540	451	546
145	817	584	544	584	487	581	536	531	516	544	455	550
146	823	588	548	588	491	586	540	535	521	549	459	555
147	828	593	553	593	496	590	545	540	525	553	463	559
148	834	598	557	598	500	595	549	544	529	557	467	564
149	839	602	562	602	504	600	554	548	534	562	472	568
150	845	607	566	607	508	604	558	553	538	566	475	572
151	850	611	571	611	513	609	563	557	542	570	480	577
152	855	616	575	616	517	613	567	561	547	575	484	581
153	861	620	579	620	521	618	571	566	551	579	488	586
154	868	624	583	624	525	622	576	570	555	583	492	590
155	872	629	588	629	529	627	580	574	559	588	496	594
156	877	633	592	633	534	631	584	579	564	592	500	598
157	883	638	597	638	538	636	589	583	568	596	504	603
158	888	642	601	642	542	640	593	587	572	601	508	607
159	893	647	605	647	546	645	597	591	576	605	512	611
160	899	651	610	651	550	649	602	596	580	609	516	616
161	904	655	614	655	555	653	608	600	584	613	520	620
162	909	660	618	660	559	658	610	604	589	618	524	624
163	914	664	622	664	563	662	615	608	593	622	528	629
164	920	669	627	669	567	667	619	613	597	626	532	633
165	925	673	631	673	571	671	623	617	601	630	536	637
166	930	677	635	677	575	676	628	621	605	634	540	642
167	935	682	640	682	579	680	632	625	610	639	544	646
168	940	686	644	686	583	684	636	629	613	643	547	650
169	946	690	648	690	587	689	641	634	618	647	552	654
170	951	695	652	695	591	693	645	638	622	651	556	659
171	958	699	656	699	595	697	649	642	626	655	559	663
172	961	703	661	703	599	702	653	646	630	660	563	667
173	969	708	665	708	603	706	658	650	634	664	567	671
174	971	712	670	712	608	711	662	655	638	668	571	676
175	978	716	673	716	611	715	666	659	643	673	575	680
176	981	721	678	721	616	719	670	663	647	677	579	684
177	989	725	682	725	620	724	675	667	650	681	582	688
178	991	729	686	729	624	728	679	671	655	685	586	693
179	999	733	690	733	628	732	683	676	659	689	590	697
180	1001	738	695	738	632	736	687	680	663	693	594	701
181	1008	742	699	742	636	741	691	684	667	697	598	706
182	1011	746	703	746	640	745	695	688	671	701	602	709
183	1018	751	707	751	644	749	700	692	675	706	605	713
184	1021	755	711	755	648	753	704	696	679	710	609	717
185	1028	760	715	760	652	758	708	700	683	714	613	722
186	1031	763	719	763	656	762	712	704	687	718	617	726
187	1035	767	724	767	660	766	716	709	691	722	621	730
188	1041	771	728	771	664	770	721	713	695	726	625	734
189	1045	775	732	775	668	775	725	717	699	730	629	738
190	1050	780	736	780	672	779	729	721	703	734	633	742
191	1055	784	740	784	676	783	733	725	707	738	637	746



## Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 60 of 95

21 August 2008

[illegible]

**Intertek**



Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 61 of 95

21 August 2008

Time (min)	P11 CCAve	P11 Sec C-C TC #10 (°F)	P11 Sec C-C TC #10 (°F)	P11 Sec C-C TC #11 (°F)	P11 Sec C-C TC #11 (°F)	P11 DDAve	P11 Sec D-D TC #12 (°F)	P11 Sec D-D TC #13 (°F)	P11 Sec D-D TC #14 (°F)	P14 P14 Max	P14 AAAve	P14 Sec A-A TC #1 (°F)	P14 Sec A-A TC #2 (°F)
0	85	85	85	85	85	85	85	85	88	84	82	82	82
1	85	85	85	85	85	85	85	85	88	83	82	82	82
2	85	85	85	85	85	85	85	85	88	83	82	82	82
3	85	85	85	85	85	85	85	85	88	84	82	82	82
4	85	85	85	85	85	85	85	85	88	84	82	82	82
5	85	85	85	85	85	85	84	85	85	85	82	82	82
6	85	84	85	85	85	84	83	85	85	87	82	82	82
7	84	83	84	84	84	84	83	85	85	87	82	82	82
8	84	83	84	84	84	84	83	85	84	88	82	82	82
9	84	83	84	84	84	84	83	85	84	88	82	82	81
10	84	83	84	84	84	84	83	85	84	88	82	82	81
11	84	83	84	84	84	84	83	85	84	88	82	82	81
12	84	83	84	84	84	84	83	85	84	88	82	82	81
13	84	83	84	85	84	84	83	85	84	88	82	82	81
14	84	83	84	85	84	84	83	85	84	88	81	82	81
15	85	84	84	86	85	84	83	85	85	88	81	82	81
16	85	84	84	86	85	84	83	85	85	88	81	82	81
17	85	84	84	87	85	85	85	85	86	88	81	82	81
18	85	85	84	87	85	85	85	85	88	88	81	82	81
19	88	88	84	88	88	88	85	87	88	88	82	83	82
20	88	88	84	88	87	87	85	88	88	88	82	83	82
21	87	87	84	90	87	86	85	89	88	88	82	83	82
22	88	88	85	91	88	88	86	89	88	88	83	84	82
23	89	89	85	92	88	88	86	89	88	88	83	84	82
24	89	90	85	93	89	90	86	91	88	88	83	85	82
25	90	91	85	93	90	91	86	92	88	88	84	85	82
26	91	92	88	95	91	92	87	93	88	88	84	85	82
27	92	93	88	96	91	92	87	93	88	89	85	86	83
28	92	93	88	97	92	94	88	94	88	89	85	87	83
29	93	94	87	98	93	95	88	95	88	90	86	88	83
30	94	95	87	98	94	96	89	96	88	91	86	88	83
31	95	96	88	100	94	97	89	97	88	92	87	89	84
32	96	97	89	101	95	98	90	98	88	92	87	90	84
33	98	98	89	102	96	99	91	99	88	93	88	91	84
34	97	99	90	103	97	100	91	100	88	94	88	92	85
35	99	101	90	105	99	102	92	102	88	95	88	92	85
36	100	102	91	107	100	103	93	103	88	96	89	93	85
37	101	103	92	108	101	105	93	105	88	97	90	94	86
38	103	105	93	111	102	107	94	108	88	98	91	94	86
39	104	105	93	113	104	108	95	108	88	101	92	95	87
40	108	108	94	115	105	110	96	110	88	102	92	96	87
41	108	110	95	118	108	113	97	113	88	107	93	97	88
42	109	112	96	120	109	115	98	115	88	111	94	98	88
43	112	115	97	123	111	117	99	117	88	118	95	99	89
44	114	117	98	126	113	120	100	120	88	123	95	100	89
45	116	120	99	129	115	123	102	123	88	130	96	100	90
46	118	122	100	132	119	126	103	127	88	135	97	101	91
47	121	125	102	135	121	129	105	130	88	145	98	102	91
48	123	128	103	139	124	133	107	133	88	155	99	103	92
49	126	131	105	142	127	137	108	137	88	162	100	104	93
50	129	134	107	146	130	140	110	140	88	168	101	105	94
51	131	137	108	149	133	144	112	144	88	175	102	107	94
52	134	140	110	153	137	147	115	148	88	180	103	108	95
53	137	143	112	156	140	151	117	151	88	183	104	109	96
54	140	147	114	160	143	155	120	155	88	189	105	110	97
55	143	150	116	164	147	158	122	159	88	189	106	112	98
56	147	153	119	168	150	163	125	162	88	192	107	113	99
57	150	157	121	171	153	167	127	166	88	194	108	115	100
58	153	160	123	176	157	170	130	170	88	196	110	117	101
59	158	163	126	180	161	174	133	177	88	197	111	118	101
60	160	167	129	184	165	178	136	181	88	198	113	120	103
61	164	171	131	189	169	182	139	186	88	198	114	122	104
62	168	176	134	193	173	187	142	190	88	198	116	124	105
63	171	180	137	197	177	191	145	195	88	198	118	127	106

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 62 of 95

21 August 2008

Time (min)	P11 C-Ave	P11 Sec C-C TC #9 (°F)	P11 Sec C-C TC #10 (°F)	P11 Sec C-C TC #11 (°F)	P11 DD Ave	P11 Sec D-D TC #12 (°F)	P11 Sec D-D TC #13 (°F)	P11 Sec D-D TC #14 (°F)	P14 P14 Max	P14 AAAve	P14 Sec A-A TC #1 (°F)	P14 Sec A-A TC #2 (°F)
54	175	184	139	202	181	195	148	199	168	120	129	107
55	179	189	142	208	185	199	151	204	167	122	131	109
56	183	193	148	210	189	203	155	208	167	124	134	110
57	187	197	140	214	193	207	158	213	168	126	138	111
58	191	202	152	219	197	212	162	217	168	128	138	113
59	195	205	155	223	201	216	165	222	168	130	141	115
70	199	211	158	227	205	220	168	226	165	132	144	116
71	203	215	162	232	209	224	172	230	165	134	148	118
72	207	219	165	236	213	228	175	235	168	137	149	120
73	211	224	169	240	217	233	179	239	168	139	152	121
74	215	228	172	245	221	237	183	243	169	141	155	123
75	219	232	175	249	225	241	186	248	201	143	157	125
76	223	237	179	253	229	245	190	252	203	146	160	127
77	227	241	183	258	233	249	194	256	205	148	163	129
78	231	245	187	262	237	254	197	261	205	151	166	131
79	235	250	190	266	241	258	201	265	210	153	168	133
80	240	254	194	271	245	262	205	269	213	156	171	135
81	244	259	198	275	250	266	209	274	215	158	174	138
82	248	263	202	279	254	271	212	278	217	160	178	140
83	252	267	206	284	258	275	216	282	219	163	179	142
84	256	271	209	288	262	279	220	286	221	165	182	144
85	260	275	213	292	266	283	224	291	224	168	185	146
86	264	280	217	296	270	287	228	295	227	171	189	149
87	269	284	221	301	274	292	231	300	230	174	193	151
88	273	289	224	305	278	296	235	304	233	177	197	154
89	277	293	228	309	282	300	239	308	235	180	200	156
90	281	297	232	314	287	305	243	313	239	184	204	159
91	285	301	236	318	291	309	247	317	242	188	208	162
92	289	306	240	322	295	313	251	322	245	191	212	164
93	294	310	244	327	299	318	254	326	248	194	215	167
94	298	314	248	331	303	322	258	330	251	198	219	170
95	302	319	251	335	308	326	262	335	254	201	223	173
96	306	323	255	340	312	331	266	339	257	204	226	176
97	310	327	259	344	316	335	270	344	260	208	230	178
98	315	332	263	349	320	339	274	348	264	211	234	182
99	319	336	267	353	325	344	278	353	267	214	237	184
100	323	340	271	358	329	348	282	357	270	218	241	187
101	327	344	274	362	333	352	286	362	273	221	244	190
102	331	349	278	367	337	357	289	366	276	225	248	194
103	335	353	282	371	342	361	293	371	280	228	252	197
104	340	358	286	376	346	366	297	375	283	232	256	200
105	344	362	290	380	350	370	301	380	285	236	260	203
106	349	367	294	385	355	375	305	385	289	239	263	206
107	353	371	298	389	359	379	309	389	293	242	266	209
108	357	375	302	394	363	383	313	393	296	246	270	213
109	362	380	306	399	368	388	317	398	299	249	273	216
110	366	384	310	403	372	392	321	403	303	252	277	219
111	370	389	313	407	376	397	325	407	306	256	281	222
112	374	393	317	412	381	401	329	412	310	260	284	226
113	379	398	322	417	385	406	333	417	313	263	288	229
114	383	402	325	421	389	410	337	421	316	266	291	232
115	387	406	329	426	394	415	341	426	320	270	295	235
116	391	411	333	430	398	419	345	430	323	273	299	238
117	396	416	337	434	403	424	349	435	327	277	302	242
118	400	420	341	439	407	428	353	439	330	280	306	245
119	404	424	345	444	411	433	357	444	334	284	310	248
120	408	428	349	448	415	437	361	448	337	288	313	252
121	413	433	353	453	420	442	365	453	341	291	317	255
122	417	437	357	457	425	446	370	458	344	295	321	258
123	421	441	361	462	429	451	374	462	348	298	324	262
124	426	446	365	466	433	455	378	467	351	302	328	265
125	430	450	369	471	437	459	382	471	355	305	332	268
126	434	455	373	475	442	464	386	475	359	309	335	271
127	439	459	377	480	446	468	390	481	362	313	339	275

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 63 of 95

21 August 2008

Time (min)	P11 CCAve	P11 Sec C-C TC #9 (°F)	P11 Sec C-C TC #10 (°F)	P11 Sec C-C TC #11 (°F)	P11 DDAve	P11 Sec D-D TC #12 (°F)	P11 Sec D-D TC #13 (°F)	P11 Sec D-D TC #14 (°F)	P14 P14 Max	P14 AAAve	P14 Sec A-A TC #1 (°F)	P14 Sec A-A TC #2 (°F)
128	443	484	381	484	451	473	394	485	368	316	343	278
129	447	488	385	489	455	478	399	490	380	320	348	281
130	451	472	389	493	460	482	403	494	373	323	350	285
131	458	477	393	498	464	486	407	499	377	327	354	288
132	460	481	397	502	468	491	411	503	380	330	357	291
133	464	485	401	507	473	495	415	508	384	334	361	295
134	469	490	405	511	477	500	419	512	388	338	365	298
135	473	494	409	516	481	504	423	517	391	341	369	301
136	477	499	413	520	485	509	427	522	395	345	372	305
137	482	503	417	525	490	513	432	526	399	349	375	308
138	486	507	421	529	495	518	436	531	402	352	380	311
139	490	512	425	533	499	522	440	535	406	356	384	315
140	494	516	429	538	503	526	444	540	409	359	387	318
141	498	520	433	542	508	531	448	544	413	363	391	322
142	503	525	437	547	512	535	452	549	417	367	395	325
143	507	529	441	551	516	540	456	553	421	371	399	329
144	512	534	445	556	521	544	460	558	424	375	403	332
145	516	538	450	560	525	548	465	562	428	378	406	336
146	520	542	454	564	530	553	469	567	432	382	410	339
147	525	547	458	569	534	557	473	571	436	386	414	342
148	529	551	462	573	538	561	477	575	439	390	418	346
149	533	555	466	577	542	566	481	580	443	393	422	349
150	537	560	470	582	546	570	485	584	447	397	425	353
151	541	564	473	586	551	574	489	589	450	401	429	356
152	545	568	478	590	555	578	493	593	454	404	433	360
153	549	572	481	595	559	583	497	597	458	408	437	364
154	554	577	485	599	563	587	501	602	462	412	441	367
155	558	581	489	603	568	591	505	606	465	415	444	370
156	562	585	493	607	572	596	510	610	469	419	448	374
157	566	589	497	612	576	600	514	615	473	423	452	377
158	570	594	501	616	580	604	518	619	476	427	456	381
159	574	598	505	620	585	608	522	624	480	430	459	385
160	578	602	509	624	589	612	526	628	484	434	463	388
161	583	607	513	629	593	617	530	632	488	438	467	392
162	587	611	517	633	597	621	534	636	491	442	471	395
163	591	615	521	637	601	625	538	640	495	445	474	399
164	595	619	525	641	605	629	542	645	499	449	478	402
165	599	623	529	645	609	633	546	649	502	453	482	406
166	603	627	533	650	613	637	550	653	506	457	486	409
167	607	632	536	654	618	642	554	658	510	460	489	413
168	611	636	540	658	622	646	557	662	514	464	493	417
169	615	640	544	662	626	650	561	666	517	467	497	420
170	619	644	548	666	630	654	565	670	521	472	501	424
171	624	648	552	671	634	658	569	674	525	475	504	427
172	628	653	556	675	638	662	573	679	529	479	508	431
173	632	657	560	679	642	666	577	683	532	482	512	434
174	635	661	564	683	646	671	581	687	535	486	516	438
175	640	665	567	687	650	675	585	691	540	490	519	441
176	644	669	571	691	654	679	589	695	543	493	523	445
177	648	673	575	695	658	683	593	699	547	497	527	448
178	652	677	579	700	662	687	596	704	551	501	530	452
179	655	681	582	704	666	691	600	708	555	504	534	455
180	659	685	586	708	670	695	604	712	558	508	538	459
181	664	690	590	712	674	699	608	716	562	512	542	463
182	668	694	594	716	678	703	612	720	565	516	545	466
183	672	698	597	720	682	707	616	724	569	519	549	470
184	676	702	601	724	686	711	619	728	573	523	553	473
185	680	706	605	728	690	715	623	732	577	527	556	477
186	684	710	609	732	694	719	627	736	580	530	560	480
187	688	714	613	736	698	723	631	740	584	534	564	484
188	692	718	617	740	702	727	635	744	588	538	567	487
189	696	722	621	744	706	731	639	748	592	541	571	491
190	699	726	624	748	710	735	642	752	595	545	575	494
191	703	730	628	752	714	739	646	756	599	549	579	498

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 64 of 95

21 August 2008

	P11	P11	P11	P11	P11	P11	P11	P11	P14	P14	P14	P14
	Sec C-C	Sec C-C	Sec C-C	Sec C-C	Sec D-D	Sec D-D	Sec D-D	Sec D-D	AAAve	Sec A-A	Sec A-A	Sec A-A
Time	TC #9	TC #10	TC #11	DOAve	TC #12	TC #13	TC #14	TC #15	Max	TC #1	TC #2	TC #3
(min)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)
192	707	734	832	758	718	743	850	760	802	552	582	502
193	711	738	838	760	722	747	854	764	808	556	586	506
194	715	742	840	764	726	751	858	768	810	558	588	508
195	719	746	844	768	730	755	861	772	813	560	590	512
196	723	750	847	772	733	759	865	776	817	563	593	515
197	727	754	851	776	737	762	869	780	821	571	601	519
198	731	758	855	780	741	766	873	784	824	574	604	522
199	735	762	859	784	745	770	877	788	828	578	608	526
200	739	766	863	788	749	774	881	792	832	581	611	529
201	743	770	866	792	753	778	884	796	836	585	615	533
202	747	774	870	796	757	782	888	800	839	589	619	536
203	751	778	874	800	761	786	892	804	843	592	622	540
204	755	782	878	804	765	790	896	808	848	596	626	543
205	758	785	882	808	769	794	900	812	850	598	630	547
206	762	789	885	812	772	797	903	816	854	603	633	550
207	766	793	889	816	776	801	907	820	857	607	637	554
208	770	797	893	820	780	805	911	824	861	610	641	557
209	774	801	897	823	784	809	915	828	864	614	644	560
210	778	805	901	827	788	813	918	832	868	617	648	564
211	781	809	904	831	792	817	922	836	872	621	651	567
212	785	813	908	835	796	821	926	840	875	625	655	571
213	789	817	912	839	799	824	930	844	879	628	658	574
214	793	820	916	843	803	828	933	848	882	632	662	578
215	797	824	920	847	807	832	937	852	886	635	665	581
216	801	828	923	851	811	836	941	856	890	639	669	585
217	805	832	927	855	815	840	945	860	893	642	673	588
218	809	836	931	859	819	843	949	864	897	646	676	592
219	813	840	935	863	822	847	952	868	900	650	680	595
220	817	844	939	867	826	851	956	872	904	653	684	598
221	821	848	943	871	830	855	960	876	907	657	687	602
222	824	852	946	875	834	859	964	880	911	660	691	605
223	828	855	950	879	838	863	968	884	915	664	694	608
224	832	859	954	882	842	866	971	888	918	667	698	612
225	836	863	958	886	846	870	975	892	922	671	701	615
226	840	867	962	890	850	874	979	896	925	674	705	619
227	843	871	965	894	853	877	983	899	928	678	708	622
228	847	874	969	898	857	881	987	903	932	681	712	626
229	851	878	973	901	861	885	990	907	935	685	716	629
230	855	882	977	905	864	888	994	911	939	688	719	633
231	859	886	980	909	868	892	998	915	943	692	722	636
232	862	889	984	913	871	895	1001	918	946	696	726	640
233	866	893	988	917	875	899	1005	922	950	699	730	643
234	870	897	992	920	879	903	1009	926	954	702	733	646
235	873	900	996	924	882	906	1012	929	957	706	737	650
236	877	904	999	927	886	910	1016	933	960	709	740	653
237	881	908	1003	931	890	913	1020	937	964	713	743	657
238	884	911	1007	935	894	917	1024	941	967	716	747	660
239	888	915	1011	939	897	920	1027	944	971	720	751	664
240	892	919	1015	942	901	924	1031	948	974	723	754	667
Max T:	892	919	1015	942	901	924	1031	948	774	723	754	667
Max A:	1009	1200	1200	1200	1000	1200	1200	1200	1200	1000	1200	1200

Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 65 of 95

21 August 2008

Time (min)	P14 Sec A-A TC #3		P14 Sec A-A TC #4		P14 Sec A-A TC #5		P14 Sec A-A TC #6		P14 Sec A-A TC #7		P14 Sec A-A TC #8	
	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)
0	82	82	82	82	82	82	82	82	82	82	82	82
1	82	82	82	82	82	82	82	82	82	82	82	82
2	82	82	82	82	82	82	82	82	82	82	82	82
3	82	82	82	82	82	82	82	82	82	82	82	82
4	83	82	82	82	82	82	82	82	82	82	82	82
5	83	82	82	82	82	82	82	82	82	82	82	82
6	82	82	82	82	82	82	82	82	82	82	82	82
7	81	82	82	82	82	82	82	82	82	82	82	82
8	81	82	82	82	82	82	82	82	82	82	82	82
9	81	82	82	82	82	82	82	82	82	82	82	82
10	81	82	82	82	82	82	82	82	82	82	82	82
11	81	82	82	82	82	82	82	82	82	82	82	82
12	81	82	82	82	82	82	82	82	82	82	82	82
13	81	82	82	82	82	82	82	82	82	82	82	82
14	80	82	82	82	82	82	82	82	82	82	82	82
15	80	82	82	82	82	82	82	82	82	82	82	82
16	80	82	82	82	82	82	82	82	82	82	82	82
17	80	82	82	82	82	82	82	82	82	82	82	82
18	80	82	82	82	82	82	82	82	82	82	82	82
19	81	82	82	82	82	82	82	82	82	82	82	82
20	81	82	82	82	82	82	82	82	82	82	82	82
21	81	82	82	82	82	82	82	82	82	82	82	82
22	82	83	83	83	83	82	82	82	82	82	82	82
23	82	83	83	83	83	83	83	83	83	83	83	83
24	82	83	83	83	84	83	83	83	83	83	83	83
25	83	84	84	84	84	84	84	84	84	84	84	84
26	84	84	84	84	85	85	85	85	85	85	85	85
27	85	85	85	85	85	85	85	85	85	85	85	85
28	85	85	85	85	85	85	85	85	85	85	85	85
29	86	86	86	86	86	86	86	86	86	86	86	86
30	87	86	86	86	86	86	86	86	86	86	86	86
31	87	87	86	86	87	86	86	86	86	86	86	86
32	88	87	87	87	87	86	86	86	86	86	86	86
33	89	88	87	87	88	89	89	89	89	89	89	89
34	90	88	88	88	88	90	90	90	90	90	90	90
35	90	89	89	89	89	91	91	91	91	91	91	91
36	91	89	89	89	90	92	92	92	92	92	92	92
37	92	90	90	90	90	92	92	92	92	92	92	92
38	93	91	90	90	90	93	93	93	93	93	93	93
39	94	92	91	91	91	94	94	94	94	94	94	94
40	95	92	92	92	92	95	95	95	95	95	95	95
41	96	93	93	93	93	96	96	96	96	96	96	96
42	96	94	93	93	93	96	96	96	96	96	96	96
43	97	94	94	94	94	97	97	97	97	97	97	97
44	98	95	95	95	94	98	98	98	98	98	98	98
45	99	95	95	95	95	99	99	99	99	99	99	99
46	100	97	96	95	95	99	99	99	99	99	99	99
47	101	98	97	96	96	100	100	100	100	100	100	100
48	102	99	98	97	97	101	101	101	101	101	101	101
49	103	100	99	98	98	102	102	102	102	102	102	102
50	104	101	100	98	98	103	103	103	103	103	103	103
51	105	102	101	99	99	104	104	104	104	104	104	104
52	106	103	102	100	100	105	105	105	105	105	105	105
53	108	104	103	101	101	107	107	107	107	107	107	107
54	109	105	104	102	102	108	108	108	108	108	108	108
55	110	106	105	103	103	109	109	109	109	109	109	109
56	111	107	106	105	105	111	111	111	111	111	111	111
57	113	108	107	106	106	113	113	113	113	113	113	113
58	114	109	109	107	107	114	114	114	114	114	114	114
59	116	111	110	108	108	116	116	116	116	116	116	116
60	118	112	112	110	110	118	118	118	118	118	118	118
61	119	113	113	111	111	120	120	120	120	120	120	120
62	121	115	115	113	113	122	122	122	122	122	122	122
63	123	117	117	114	114	124	124	124	124	124	124	124

**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 66 of 95

21 August 2008

Time (min)	P14 Sec A-A TC #3 (°F)	P14 Sec A-A TC #4 (°F)	P14 Sec A-A TC #5 (°F)	P14 BBAs	P14 Sec B-B TC #6 (°F)	P14 Sec B-B TC #7 (°F)	P14 Sec B-B TC #8 (°F)
64	125	118	119	116	126	105	badf/c
65	127	120	121	117	128	106	badf/c
66	129	122	123	119	130	107	badf/c
67	132	124	125	121	133	109	badf/c
68	134	126	127	123	135	110	badf/c
69	137	128	129	125	138	112	badf/c
70	139	130	131	127	140	113	badf/c
71	142	132	134	129	143	115	badf/c
72	144	134	136	131	145	117	badf/c
73	147	136	138	133	148	118	badf/c
74	149	138	141	136	151	120	badf/c
75	152	140	143	138	153	122	badf/c
76	155	143	146	140	156	124	badf/c
77	157	145	148	143	159	126	badf/c
78	160	147	150	145	161	128	badf/c
79	162	150	153	147	164	130	badf/c
80	165	152	155	149	166	132	badf/c
81	167	155	158	152	169	134	badf/c
82	169	158	161	154	172	136	badf/c
83	171	158	163	156	173	137	badf/c
84	173	161	165	158	176	140	badf/c
85	175	164	168	160	178	142	badf/c
86	179	167	171	164	182	145	badf/c
87	183	169	174	167	186	147	badf/c
88	187	172	177	170	188	150	badf/c
89	191	175	180	173	193	152	badf/c
90	196	178	183	176	196	155	badf/c
91	200	182	189	179	200	157	badf/c
92	204	185	190	182	204	160	badf/c
93	208	188	193	185	208	162	badf/c
94	212	191	196	188	211	165	badf/c
95	216	195	199	192	215	168	badf/c
96	220	198	202	195	218	171	badf/c
97	223	201	206	198	222	173	badf/c
98	227	205	209	201	226	176	badf/c
99	231	208	212	204	229	179	badf/c
100	235	212	215	208	233	182	badf/c
101	238	215	218	211	236	185	badf/c
102	242	219	222	214	240	188	badf/c
103	246	222	225	218	244	191	badf/c
104	250	225	228	221	247	194	badf/c
106	254	229	232	224	251	197	badf/c
106	257	232	235	227	254	200	badf/c
107	261	236	238	231	258	203	badf/c
108	265	239	241	234	261	206	badf/c
109	269	243	245	237	265	209	badf/c
110	272	246	248	241	268	213	badf/c
111	276	250	251	244	272	216	badf/c
112	280	253	255	247	276	219	badf/c
113	284	257	258	251	279	222	badf/c
114	287	260	261	254	282	225	badf/c
115	291	264	265	257	286	228	badf/c
116	295	267	268	261	290	232	badf/c
117	299	271	271	264	293	236	badf/c
118	302	274	274	268	297	238	badf/c
119	306	278	278	271	300	241	badf/c
120	310	282	281	274	304	244	badf/c
121	314	285	285	278	307	248	badf/c
122	318	289	288	281	311	251	badf/c
123	322	292	291	284	314	254	badf/c
124	325	295	295	288	318	257	badf/c
125	329	299	298	291	321	260	badf/c
126	333	303	302	295	325	264	badf/c
127	337	307	305	298	329	267	badf/c



### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 67 of 95

21 August 2008

Time (min)	P14 Sec A-A TC #3 (°F)	P14 Sec A-A TC #4 (°F)	P14 Sec A-A TC #5 (°F)	P14 BB Ave (°F)	P14 Sec B-B TC #6 (°F)	P14 Sec B-B TC #7 (°F)	P14 Sec B-B TC #8 (°F)
128	341	310	308	301	332	270	badf/c
129	345	314	312	305	336	274	badf/c
130	348	318	315	308	339	277	badf/c
131	352	321	319	312	343	280	badf/c
132	356	325	322	315	346	284	badf/c
133	359	329	325	319	350	287	badf/c
134	364	332	329	322	353	290	badf/c
135	368	336	333	325	357	293	badf/c
136	372	339	336	328	360	296	badf/c
137	376	343	340	332	364	300	badf/c
138	380	347	343	336	368	303	badf/c
139	384	351	346	339	371	306	badf/c
140	388	354	350	343	375	310	badf/c
141	392	358	354	346	379	313	badf/c
142	396	362	357	350	382	317	badf/c
143	400	366	361	353	386	320	badf/c
144	404	370	364	357	390	323	badf/c
145	408	373	368	360	393	326	badf/c
146	412	377	372	364	397	330	badf/c
147	416	381	376	367	400	333	badf/c
148	420	385	379	370	404	336	badf/c
149	424	388	382	374	407	340	badf/c
150	428	392	385	377	411	343	badf/c
151	432	396	389	381	415	346	badf/c
152	436	400	393	384	418	350	badf/c
153	440	404	397	388	422	353	badf/c
154	444	407	400	391	425	356	badf/c
155	448	411	404	395	429	360	badf/c
156	452	415	407	398	433	363	badf/c
157	455	419	411	402	436	367	badf/c
158	459	422	415	405	440	370	badf/c
159	463	426	418	408	443	373	badf/c
160	467	430	422	412	447	377	badf/c
161	471	434	426	415	450	380	badf/c
162	475	438	429	419	454	383	badf/c
163	479	441	433	422	457	387	badf/c
164	483	445	436	426	461	390	badf/c
165	487	449	440	429	465	393	badf/c
166	491	453	444	433	468	397	badf/c
167	495	457	447	436	472	400	badf/c
168	499	460	451	439	476	403	badf/c
169	502	464	454	443	479	407	badf/c
170	507	468	458	446	482	410	badf/c
171	510	472	462	450	486	414	badf/c
172	514	476	465	454	490	417	badf/c
173	518	479	469	457	493	420	badf/c
174	522	483	472	461	497	424	badf/c
175	526	487	476	464	500	427	badf/c
176	530	490	479	467	503	430	badf/c
177	534	494	483	471	507	434	badf/c
178	537	498	487	474	511	437	badf/c
179	541	501	490	477	514	440	badf/c
180	545	505	494	481	518	444	badf/c
181	549	509	498	484	521	447	badf/c
182	553	513	501	488	525	451	badf/c
183	557	516	505	491	528	454	badf/c
184	560	520	508	495	532	457	badf/c
185	564	524	512	498	536	461	badf/c
186	568	528	516	502	539	464	badf/c
187	572	532	519	505	542	467	badf/c
188	576	535	523	509	546	471	badf/c
189	580	539	526	512	549	474	badf/c
190	583	542	530	515	553	477	badf/c
191	587	546	534	519	556	481	badf/c

Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 68 of 95

21 August 2008

Time (min)	P14 Sec A-A TC #3 (°F)	P14 Sec A-A TC #4 (°F)	P14 Sec A-A TC #5 (°F)	P14 BB Ave	P14 Sec B-B TC #6 (°F)	P14 Sec B-B TC #7 (°F)	P14 Sec B-B TC #8 (°F)
192	591	550	537	522	560	484	badfrc
193	596	554	541	525	563	487	badfrc
194	599	557	544	529	567	490	badfrc
195	602	561	548	532	570	494	badfrc
196	606	565	551	536	574	497	badfrc
197	610	568	555	539	577	500	badfrc
198	614	572	559	543	581	504	badfrc
199	617	576	562	546	584	507	badfrc
200	621	579	566	549	588	510	badfrc
201	625	583	569	553	591	514	badfrc
202	629	587	573	556	595	517	badfrc
203	632	590	576	559	598	520	badfrc
204	636	594	580	563	602	523	badfrc
205	640	597	583	566	605	527	badfrc
206	644	601	587	569	608	530	badfrc
207	647	605	590	573	612	533	badfrc
208	651	608	594	576	615	536	badfrc
209	655	612	597	580	619	540	badfrc
210	658	616	601	583	622	543	badfrc
211	662	619	605	586	625	546	badfrc
212	666	623	608	590	629	550	badfrc
213	670	627	612	593	632	553	badfrc
214	673	630	615	596	636	556	badfrc
215	677	634	619	599	639	559	badfrc
216	681	637	622	603	643	562	badfrc
217	684	641	625	606	646	565	badfrc
218	688	645	629	609	649	569	badfrc
219	692	648	633	613	653	572	badfrc
220	695	652	636	616	656	575	badfrc
221	699	655	640	620	660	579	badfrc
222	702	659	643	623	663	582	badfrc
223	706	663	647	626	666	585	badfrc
224	710	666	650	629	670	588	badfrc
225	713	670	654	633	673	592	badfrc
226	717	673	657	636	676	595	badfrc
227	721	677	661	639	680	598	badfrc
228	724	680	664	642	683	601	badfrc
229	728	684	668	645	686	604	badfrc
230	731	687	671	649	690	608	badfrc
231	735	691	674	652	693	611	badfrc
232	739	695	678	655	696	614	badfrc
233	742	698	681	659	700	617	badfrc
234	746	702	685	662	703	621	badfrc
235	749	705	689	665	706	624	badfrc
236	753	709	692	669	710	627	badfrc
237	756	712	695	672	713	630	badfrc
238	760	716	699	675	716	633	badfrc
239	764	719	702	679	720	637	badfrc
240	767	723	706	682	723	640	badfrc
Max T:	767	723	706	682	723	640	badfrc
Max A:	1200	1200	1200	1000	1200	1200	

**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 69 of 95


APPENDIX C  
Photographs

Intertek

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 70 of 95



**Intertek**

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 71 of 95



Intertek

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 72 of 95



Intertek



**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 73 of 95



Intertek

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 74 of 95




Intertek

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 75 of 95



Intertek

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 76 of 95



**Intertek**

**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 77 of 95



Intertek



**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 78 of 95



Intertek



### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 79 of 95



Intertek

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 80 of 95



**Intertek**

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 81 of 95



Intertek

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 82 of 95



Intertek

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 83 of 95




**Intertek**



### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 84 of 95



Intertek



### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 85 of 95



Intertek

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 86 of 95



Intertek

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 87 of 95



**Intertek**

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 88 of 95



**Intertek**

**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 89 of 95



Intertek



**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 90 of 95




Intertek



### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 91 of 95




Intertek

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 92 of 95



Intertek

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 93 of 95



Intertek

### Appendix F UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 94 of 95



**Intertek**



**Appendix F** UL 1709 – RAPID RISE FIRE TESTS OF PROTECTION MATERIALS FOR STRUCTURAL STEEL

Aspen Aerogels, Inc.  
Project No. 3159033

28 August, 2008  
Page 95 of 95

REVISION SUMMARY

DATE	SUMMARY
<Insert date of revision>	<Insert Summary of revision>

Intertek

**Appendix G** ASTM C 411/C 447 – HOT SURFACE PERFORMANCE

**TUTCO SCIENTIFIC CORPORATION**

**714 East Aspen Ave.**

**Fruita CO 81521**

p&f 970 858 3584; e-mail: tutco@bresnan.net

REPORT ON

96 HOUR

HOT SURFACE PERFORMANCE

DETERMINED USING ASTM C411 AND C447

AT 1200 °F (650 °C)

FOR

ASPEN AEROGELS

PYROGEL XT

(SAMPLE ID - ENG921)

PREPARED FOR

ASPEN AEROGELS


30 FORBES RD BLDG B

NORTHBOROUGH, MA 01532

TUTCO SCIENTIFIC REPORT NO. AERO\411&447(306138).308

March 10, 2008

Reported by

  
Kenneth Whorlow  
President



## Appendix G ASTM C 411/C 447 – HOT SURFACE PERFORMANCE

AERO\411&447(306138).308  
PAGE 2

**Project:** Determine the hot surface performance and the interior temperature rise of one sample of Flexible Insulation Blanket received from Aspen Aerogels. The testing was conducted by request of Cindy MacLaurin by letter for purchase order 306138.

**Samples:** The sample was identified as Pyrogel XT, Sample ID ENG921

**Test Method:** ASTM C 411 (Hot Surface Performance of High-Temperature Thermal Insulation - Pipe Insulation Method) continuing the test for 4 days as required by C 411. The test was conducted at 1200 °F (650 °C) hot surface temperature. In addition, during the heat up, the interior temperature rise at layers 2, 4, 6, 8, and 10 were recorded in accord with C447 section 8.1.6. Shrinkage across the 36" length and around the first and part of the second wrap was determined as described in the procedure section.

**Procedure:** The temperature was targeted to be 1200 °F (650 °C) and the temperature of the hot pipe surface was within +/- 25 °F as required by ASTM C411. The material was installed on the pipe as a continuous 11 ply installation with 4 inches overlapping the outside seam. Sheathed thermocouples were placed between layers 2-3, 4-5, 6-7, 8-9, 10-11. The data was recorded by a data logger 4 times a minute during the heating of the pipe (approximately 400 minutes). An aluminum jacket was installed over the insulation. The hot surface temperature of the pipe was controlled to a maximum of 1200 °F (650 °C) and monitored with thermocouples on the surface of the hot pipe and guards. The test was continued for 96 hours at the 1200 °F (650 °C) hot surface temperature.

The leading edge of the insulation material was started on the pipe using wire. A 0.06 inch wire was wrapped around the pipe and twisted tight. One lead was clipped and the other formed into a small hook. The wires were used in the center and 2 inches from each end. The leading edge of the material was pushed onto the hook, and then the wire hook was tapped flat. The insulation material was then wrapped around the affixed leading edge. The 11 layers of material were wrapped tight and were held in place on the pipe using fiberglass reinforced tape wrapped around the outer layer of insulation. The tape was positioned approximately 2 inches from each end and at 10 inch intervals. The aluminum jacket was installed on the test pipe using wire at the center and 6 inches in from each end. The circumference of the insulation was 30.75 inches and the circumference with the aluminum jacket installed was 31 inches.

Shrinkage across the 36" length of the leading edge and 10 cm back from the leading edge was measured. Circumferential shrinkage around the first wrap and part of the second wrap were determined at 10 cm intervals. The shrinkage was determined by imbedding small staples along the edges and up the center of the blanket. The distance between the staples was measured to 0.1 cm accuracy using a tape measure before and after exposure. The percentage changes for the measurements are provided.

**Observations and Results:** After 4-days exposure at 1200 °F (650 °C)

**Figure 1** is a graph of the thermocouple temperatures at the layers and cold surface during heat-up and continuing for the first 400 minutes of the test. None of the layers indicated an exothermic heat rise.

**Appendix G** ASTM C 411/C 447 – HOT SURFACE PERFORMANCE

AERO\411&447(306138).308  
PAGE 3

**Observations and Results:** (continued)


There were no observed changes of the installed material during the test or at the conclusion of the 96 hour heating period. After the test equipment had cooled, the material was removed from the pipe and remained intact.

1. Visual examination during the test period was limited because of the exterior metal jacket.
2. There was no apparent flaming, glowing, smoldering, or smoking at any time during the test that could be seen at the exposed ends of the jacketed material.
3. There was some odor during the heating.
4. None of the layers indicated an exothermic heat rise.
5. Visual examination of the exterior of the installed material at the conclusion of the test, after the pipe had cooled and the jacket was removed, showed no apparent sagging, surface cracking, warpage, de-lamination or shrinkage.
6. After disassembly, all layers of the 11 ply pipe insulation showed no apparent sagging, surface cracking, warpage, de-lamination or shrinkage. The material remained flexible.
7. There was no evidence of flaming, glowing, smoldering, or smoking on the inner layers.

**Results of the Shrinkage Measurements during C411 Hot Surface Performance test**

1. Across the 36 inch length of the leading edge the percentage shrinkage was 0.9%.
2. Across the 36 inch length approximately 10 cm back from the leading edge the percentage shrinkage was 0.8%.
3. The circumferential shrinkage was measured along both sides and in the center of the blanket, along the leading edge and at approximately 10 cm positions back from the leading edge. The average percentage shrinkage at the leading edge was 1.77%. The average percentage shrinkage at the next four positions were: 1.65%, 2.66%, 2.02%, 2.65%.
4. The measured circumferential shrinkage around the sample was greater than across the width. This is probably due to the added condition of permanent wrinkles caused by compression of the measured surface of the blanket as it is wrapped around the pipe. The wrinkles are not an indication of shrinkage of the blanket fibers.

Appendix G    ASTM C 411/C 447 – HOT SURFACE PERFORMANCE



**Appendix H** ASTM C 356 & C 411 – LINEAR SHRINKAGE AND HOT SURFACE PERFORMANCE

100 MILVAN DRIVE, WESTON, ONTARIO, CANADA M9L 1Z6

TEL: (416) 746-8989

FAX: (416) 746-4829

**REPORT**

Subject: **DETERMINATION OF SHRINKAGE AND HOT SURFACE PERFORMANCE OF  
PYROGEL XT AT 650°C**

Report No.: U08-795  
March 14, 2007

Ms. Cindy McLaurin  
Aspen Aerogels  
30 Forbes Road  
Northborough, MA 01532  
USA



INSULTECH INC.





**Appendix H** ASTM C 356 & C 411 – LINEAR SHRINKAGE AND HOT SURFACE PERFORMANCE

INSULTECH INC.

**TEST REPORT**

<p><b>Firm:</b> Aspen Aerogel 30 Forbes Road Northborough, MA 0153 USA</p>	<p><b>Report No.:</b> U08-795 <b>Date:</b> March 14, 2007 <b>Ref. No.:</b> 27.48</p>
--	--

**Page:** 1 of 4

<p><b>Tested:</b>  Robert Hall</p>	<p><b>Approved:</b>  Leslie K. Truksa, Ph.D.</p>
---	---


---

**Material:** One sample of Pyrogel XT

**Tests Requested:** Shrinkage C356 and hot surface performance C411 on 12 layer stack at 650°C.

THIS REPORT WAS NOT IN PROGRESS AS PART OF AN ORDER WITHOUT CONSENT OF INSULTECH INC., 100 MILLIKEN DRIVE, TAYLOR, ONTARIO CANADA M0L 1Z0

### Appendix H ASTM C 356 & C 411 – LINEAR SHRINKAGE AND HOT SURFACE PERFORMANCE



**Pyrogel XT: C356, C411 @ 650 C**

Aspen Aerogels.
TR: U08-795
Page 2 of 4  
March 14, 2008

---

ACCREDITATION: INSULTECH INC. IS ACCREDITED BY THE STANDARDS COUNCIL OF CANADA (SCC) IN CANADA AND BY THE NATIONAL VOLUNTARY LABORATORY ACCREDITATION PROGRAM (NVLAP) IN THE USA.

**1.0 SAMPLE IDENTIFICATION**

The sample was assigned Insultech reference number 27.48.

**2.0 SAMPLE DESCRIPTION**

The sample consisted of two pieces 152x152 mm (6x6 in.) plus 96 pieces 152x457 mm (6x18 in.). The material was identified as Pyrogel XT, of 5 mm (0.2 in.) stated thickness .

**3.0 TEST**


Linear shrinkage was tested at 650°C (1200° F) in accordance with ASTM C356-03 *TEST METHOD FOR LINEAR SHRINKAGE OF PREFORMED HIGH-TEMPERATURE THERMAL INSULATION SUBJECTED TO SOAKING HEAT*. Four specimens 152x64 mm (6x2.5 in.) were conditioned at 120°C (248°F) for two hours. The test was performed at single thickness. The specimens were placed in the furnace at room temperature and this was gradually raised to 650°C (1200°F) where it was stabilized. After 24 hours the furnace was allowed to cool to room temperature and the specimens reweighed and remeasured at the test loci. The measurements together with visual observations were recorded.

Hot surface performance was established at 650°C (1200°F) in accordance with ASTM C411-05 *STANDARD TEST METHOD FOR HOT-SURFACE PERFORMANCE OF HIGH-TEMPERATURE THERMAL INSULATION*.

100 Milvar Drive, Weston, Ontario, Canada M9L 1Z6
Phone: (416) 746-8989 Fax: (416) 746-4829



### Appendix H ASTM C 356 & C 411 – LINEAR SHRINKAGE AND HOT SURFACE PERFORMANCE

 **INSULTECH Inc.**

Pyrogel XT: C356, C411 @ 650 C
Page 3 of 4


Aspen Aerogels.
TR: U08-795
March 14, 2008

Stacks of 12 units 152x457 mm (6x18 in.), for a total of 60 mm (2.4 in.) were applied to the plate of the apparatus at room temperature. This was gradually brought up to 650°C (1200°F) where it was maintained for 96 hours. The temperature was monitored with thermocouples calibrated against a standard traceable to NRC. The cooled specimens were checked for final warpage and examined for presence of cracking, delamination and any visual physical changes which could have been attributed to the exposure. Throughout the exposure observations were maintained for signs of flaming, glowing, smoking and smouldering.

The results are presented as arithmetic mean value of the measurement ( $\bar{x}$ ) while the variability, as standard deviation ( $\sigma$ ) and percent coefficient of variation ( $v$ ).

100 Milvar Drive, Weston, Ontario, Canada M9L 1Z6
Phone: (416) 746-8989 Fax: (416) 746-4829

### Appendix H ASTM C 356 & C 411 – LINEAR SHRINKAGE AND HOT SURFACE PERFORMANCE



Pyrogel XT: C356, C411 @ 650 C

Aspen Aerogels.
TR: U08-795
Page 4 of 4  
March 14, 2008

#### 4.0 RESULTS

##### 4.1 Linear shrinkage

	$\bar{x}$	(n=4) $\sigma/\bar{x}$
Mass loss on drying, %	0.26	0.087/32.97
Mass loss on test, %	1.05	0.185/17.61
Shrinkage, %	1.28	0.307/24.00

*Visual observations:* No significant change from the original.

##### 4.2 Hot surface performance

Initial warpage: zero

Final warpage: zero

No cracking, delamination or change of state were observed.

All specimens appeared unchanged and retained good structural integrity.

Mid point maximum temperature was 463°C (865°F)

Maximum surface temperature recorded was 65.6 °C (150 °F).

There was no indication of glowing, smoking, smouldering or flaming.

There was no evidence of sustained exotherm.

100 Milvan Drive, Weston, Ontario, Canada M9L 1Z6
Phone: (416) 746-8989 Fax: (416) 746-4829

#### Appendix I MECHANICAL RESILIENCE AND WATER RESISTANCE



**TESTING GROUP**  
www.bodycote.com  
www.bodycotetesting.com

---

#### EVALUATION OF THE PHYSICAL PROPERTIES OF PYROGEL XT BLANKET THERMAL INSULATION

---

<b>Report to:</b>	<b>Aspen Aerogels Inc.</b> 30 Forbes Road Northborough, MA 01532
<b>Attention:</b>	Cindy MacLaurin
<b>Telephone:</b>	508-691-1132
<b>Fax:</b>	508-691-1114
<b>E-mail:</b>	cmaclaurin@aerogel.com
<b>Report No.:</b>	08-06-M0061 5 Pages
<b>Proposal No.:</b>	08-006-0200
<b>Date:</b>	April 28, 2008

Bodycote Testing Group  
2395 Speakman Drive • Mississauga • Ontario • Canada • L5K 1B3 • Tel: +1 (905) 822-4111 • Fax: +1 (905) 823-1446

**Appendix I** MECHANICAL RESILIENCE AND WATER RESISTANCE

Bodycote Testing Group \_\_\_\_\_

*Evaluation of Physical Properties of Pyrogel XT  
for Aspen Aerogels Inc.*

*Page 2 of 5  
Report No. 08-06-M0061*

**1.0 INTRODUCTION**

At the request of Aspen Aerogels Inc., Bodycote Testing Group was retained to evaluate several physical properties of a sample of thermal insulation material.

Upon receipt, the sample was assigned the following Bodycote Sample No.

Client Sample Description	Bodycote Sample No.
PYROGEL XT	08-06-M0061

**2.0 PROCEDURE**

The sample was evaluated according to the following standard test methods:

Test Description	Test Method
Standard Test Method for Determining the Water Vapor Sorption of Unfaced Mineral Fibre Insulation	ASTM C 1104 - 00
Standard Test Method for Determining the Water Retention (Repellency) Characteristics of Glass Fibre Insulation	ASTM C 1511 - 04
Standard Test Method for Measuring Compressive Properties of Thermal Insulation	ASTM C 165 - 07
Standard Test Method for Determining Wicking of Glass Fibre Blanket Insulation	ASTM C 1559
Standard Test Method for Breaking Strength and Elongation of Textile Fabrics (Grab Test)	ASTM D 5034 -95(2001)

**Appendix I** MECHANICAL RESILIENCE AND WATER RESISTANCE

Bodycote Testing Group

*Evaluation of Physical Properties of Pyrogel XT  
for Aspen Aerogels Inc.*

*Page 3 of 5  
Report No. 08-06-M0061*

**3.0 RESULTS**

A summary of all data is provided in table 1. Detailed results are provided in tables 2 through 6.

<b>Table 1 – Summary of Results</b> Bodycote Sample No. 08-06-M0061	
Description	Result
<b>Water Vapor Sorption (ASTM C 1104)</b> Mass Gain, %	2.25
<b>Water Retention (Repellency) (ASTM C 1511)</b> Water Repellency, g Mass Gain, % Volume of Water, %	16.3 16.4 4.2
<b>Compressive Properties (ASTM C 165)</b> 5 layers, 30.2mm thickness Compressive Stress @ 10% Compression, kPa Compressive Stress @ 25% Compression, kPa	103.1 217.4
<b>Wicking (ASTM C 1559)</b> As Received; 20°C; 168 hours, mm As Received; 50°C; 168 hours, mm 336 hr Aged; 20°C; 168 hours, mm 336 hr Aged; 50°C; 168 hours, mm Leached; 20°C; 168 hours, mm Leached; 50°C; 168 hours, mm	0 0 0 2 0 1
<b>Grab Test (ASTM D 5034)</b> Maximum Load, Machine Direction, N Maximum Load, Cross Direction, N	490 370

<b>Table 2 – Water Vapor Sorption (ASTM C 1104)</b> Bodycote Sample No. 08-06-M0061		
Specimen	Initial Mass, g	Final Mass, g
1	24.73	25.28
2	24.07	24.65
3	25.07	25.60
<b>Average</b>	<b>24.62</b>	<b>25.18</b>
<b>Mass Gain:</b>		<b>2.25%</b>



**Appendix I** MECHANICAL RESILIENCE AND WATER RESISTANCE

Bodycote Testing Group \_\_\_\_\_

*Evaluation of Physical Properties of Pyrogel XT  
for Aspen Aerogels Inc.*

*Page 4 of 5  
Report No. 08-06-M0061*

Table 3 – Water Retention (ASTM C 1511) Bodycote Sample No. 08-06-M0061		
Specimen	Initial Mass, g	Final Mass, g
1	101.43	118.70
2	100.08	114.34
3	96.83	114.32
Average	99.44	115.78
Water Repellency:		16.3 g
Mass Gain:		16.4 %
Volume of Water:		4.2 %

Table 4 – Compressive Strength (ASTM C 165) Bodycote Sample No. 08-06-M0061		
Specimen	Stress at 10% Compression, kPa	Stress at 25% Compression, kPa
1	103.1	214.4
2	108.1	217.4
3	112.7	172.1
Average	108.0	201.3

Table 5 – Wicking (ASTM C 1559) Bodycote Sample No. 08-06-M0061						
Duration, hrs	Max Height, mm		Max Height, mm		Max Height, mm	
	As Received		Heat Aged		Leached	
	20°C	50°C	20°C	50°C	20°C	50°C
24	0	0	0	1	0	0
48	0	0	0	1	0	0
72	0	0	0	1	0	1
96	0	0	0	1	0	1
168	0	0	0	2	0	1



### Appendix I MECHANICAL RESILIENCE AND WATER RESISTANCE


Bodycote Testing Group

Evaluation of Physical Properties of Pyrogel XT  
for Aspen Aerogels Inc.


Page 5 of 5  
Report No. 08-06-M0061

Table 6 – Grab Test (ASTM D 5034) Bodycote Sample No. 08-06-M0061		
Specimen	Maximum Load	Maximum Load
	Machine Direction, N	Cross Direction, N
1	420	340
2	340	380
3	550	400
4	530	390
5	610	330
Average	490	370

Reported by:

  
David Beauchamp, B.Sc., Ext. 228  
Scientist, Building Performance Centre  
Product Testing Group

Reviewed by:

  
Franz C. Bauer, Ext. 403  
Manager, Building Performance Centre  
Product Testing Group

#### REGISTRATION

ISO 9001:2000 registered by QMI, Registration #001109

*This report refers only to the particular samples, units, material, instrument, or other subject used and referred to in it, and is limited by the tests and/or analyses performed. Similar articles may not be of like quality, and other testing and/or analysis programs might be desirable and might give different results.*

*Please note that unless otherwise notified by the Client, the sample(s) will be disposed of 30 days following issue of the final report. The Client is responsible for any costs associated with returning the sample.*

**Appendix J** ASTM C 795 – CORROSION TEST

10-29-2008 22:53 KENNETH WHORLOW PAGE2


**TUTCO SCIENTIFIC CORPORATION**  
714 East Aspen Ave  
Fruita, CO 81521  
phone and Fax 970-858-3584 email: tutco@bresnan.net

28-DAY CORROSION TEST  
AND CHEMICAL TESTS OF  
PYROGEL XT BLKT 1205  
(SAMPLE ID 08090168)

IN ACCORD WITH  
ASTM C 795  
USING THE TEST METHODS OF  
ASTM C 692 AND ASTM C 871

PREPARED FOR  
ASPEN AEROGELS  
30 FORBES RD BLDG B  
NORTHBOROUGH, MA 01532

TUTCO SCIENTIFIC REPORT NO. AERO\692(307922).008  
October 29, 2008

Reported by   
Kenneth Whorlow  
President

### Appendix J ASTM C 795 – CORROSION TEST

10-29-2008 22:53 KENNETH WHORLOW

PAGE3

AERO\692(307922).008

Page 2

**Subject:** This report covers ASTM C871 Chemical Tests (Standard Test Method for Chemical Analysis of Thermal Insulation Materials for Leachable Chloride, Fluoride, Silicate, and Sodium Ions) and ASTM C 692 28-Day (Pre-Production) Corrosion Tests (Standard Test Method for Evaluating the Influence of Thermal Insulations on the External Stress Corrosion Cracking Tendency of Stainless Austenitic Steel). The material tested was Pyrogel XT Blkt 1205, Sample ID 08090168 received from Aspen Aerogels on PO # 307922, dated 23-Sep-08.

The results may be used to determine the qualification of the insulation to the requirements of ASTM C 795 (Standard Specification for Thermal Insulation for Use in Contact with Austenitic Stainless Steel).

**Samples:** The samples were identified as  
#1 Name: Pyrogel XT Blkt 1205, Sample ID, 8090168

#### CHEMICAL TESTS

**Sample Preparation:** Samples were cut from the submitted specimen such that the test samples were representative of the entire cross section of the material. Samples weighing 20.0 grams were prepared for the duplicate extractions.

Each weighed sample was put in a blender jar containing 500 ml of demineralized water, ground and crushed into small pieces and quantitatively transferred to a one-liter stainless steel beaker. The sample slurry was heated to boiling and maintained at temperature for 30 minutes. The liquid was cooled, the weight was brought to 500 grams, and then strained and then filtered to produce the extraction solution for chemical tests.

**Chemical Test Procedures:** All test procedures were conducted in accord with ASTM C871. The tests used were as follows: Chloride - Amperometric-coulometric titrator; Silicate - Molydisilicic acid; Sodium - Ion Selective Electrode; Fluoride - Ion Selective Electrode; pH - Standard pH probe and meter.

**Test Results:** Given in parts per million (mg/kg).

Sample	Sodium	Silicate	Chloride	Fluoride	pH
1A	41	7349	33	9	8.8
1B	40	7230	32	9	8.8

**Chemical Test Conclusions:** The sample identified as Pyrogel XT Blkt 1205, Sample ID 08090168 met the chemical requirements of ASTM C 795, falling within the "acceptable" range of the "acceptability curve".

### Appendix J ASTM C 795 – CORROSION TEST

10-29-2008 22:54 KENNETH WHORLOW

PAGE4

AERO\692(307922).008

Page 3

#### 28-DAY CORROSION TEST

Corrosion Test Procedures: The 28-Day Corrosion Test was run in accord with ASTM C692, using the Drip Test Procedure. The metal used to fabricate the test coupons had a 0.051 carbon content. The coupons were sensitized by heating at 1200°F in an air atmosphere for 3 hours. They were then prepared in accord with ASTM C692. The lot of sensitized steel was qualified by three-day exposure to a 1500 ppm chloride solution - all specimens cracked, and 28-day exposure to de-ionized water - none cracked.

Sample Preparation: Test samples were fabricated from the blanket insulation to form approximately 1.5" thick, 4" wide, 3.5" tall sections using 4 layers of the material held together with rubber bands.

Four specimens were prepared and each fitted with a u-bend coupon. The test coupons and specimens were set up on the C692 drip test apparatus, which was brought to operating temperature and the flow of de-ionized water from the peristaltic pump was started. The material is hydrophobic and does not readily wet, therefore 1/4 inch channels were cut in the center pieces of the insulation. Water dripped into the channel percolated down to the coupon surface. The flow rate was set at 250 ml/day on each test specimen.

After 28-days the coupons and contact area of the materials were examined and the materials were wet at the contact surface of the coupons. All of samples was slightly adhered to the coupons in small spots.

Corrosion Test Results: At the conclusion of 28-days from the start of the test the coupons were removed, flattened, cleaned, re-bent, and inspected. No obvious cracks were found. The required inspection using dye penetrant and developer was done to add greater confidence that all cracks are found. No cracks were found on any of the coupons. The coupons were determined to be free of cracks.

# of Coupons tested

4

# of Coupons Cracked

0

#### Corrosion Test Conclusion:

The sample identified as Pyrogel XT Blkt 1205, Sample ID 08090168, produced none of the four coupons tested having any cracks.



### Appendix K ASTM C 592-04 – HEAT AND VIBRATION AGING



**TESTING GROUP**  
www.bodycote.com  
www.bodycotetesting.com

#### EVALUATION OF THE EFFECT OF HEAT AND VIBRATION AGING OF PYROGEL XT AND MINERAL WOOL THERMAL INSULATION MATERIAL

<b>Report to:</b>	Aspen Aerogels Inc. 30 Forbes Road Northborough, MA 01532
<b>Attention:</b>	Cindy MacLaurin
<b>Telephone:</b>	508-691-1132
<b>Fax:</b>	508-691-1114
<b>E-mail:</b>	cmaclaurin@aerogel.com
<b>Report No.:</b>	08-06-M0171, Revision 2 3 Pages
<b>Proposal No.:</b>	08-006-5335
<b>Date:</b>	December 8, 2008

Bodycote Testing Group - Americas - Head Office  
2395 Speakman Drive • Mississauga • Ontario • Canada • L5K 1B3 • Tel: +1 (905) 822-4111 • Fax: +1 (905) 823-1446



### Appendix K ASTM C 592-04 – HEAT AND VIBRATION AGING

Bodycote Testing Group

*Evaluation of the Effect of Heat and Vibration Aging on Thermal Insulation  
for Aspen Aerogels Inc.*

*Page 2 of 3  
Report No. 08-06-M0171, Revision 2*

#### 1.0 INTRODUCTION

At the request of Aspen Aerogels Inc., Bodycote Testing Group was retained to evaluate the mass and physical appearance effects of heat and vibration aging of two samples of thermal insulation material.

Upon receipt, the sample was assigned the following Bodycote Sample No.:

Client Sample Description	Bodycote Sample No.
Pyrogel XT	08-06-M0171 – A
Mineral Wool	08-06-M0171 – B

#### 2.0 PROCEDURE

The sample was evaluated according to the following standard test methods:

Test Description	Test Method
Standard Specification for Mineral Fibre Blanket Insulation and Blanket-Type Pipe Insulation (Metal-Mesh Covered) (Industrial Type) - Resistance to Vibration	ASTM C 592 – 04 Section 11.11 Modified

##### ASTM C 592 Section 11.11 Resistance to Vibration - Modified

Testing to this method was conducted in accordance with section 11.11 of ASTM C 592. The following testing specifics apply, and where appropriate are deviations from the method.

Each sample was initially weighed at ambient laboratory conditions (nominally 23°C and 60% relative humidity). The weights were recorded to an accuracy of 0.1 grams. Immediately after weighing, the sample was heated on a hot plate apparatus to 400°C for greater than 96 hours with a temperature gradient through the sample from 400°C at the hot plate surface to ambient laboratory conditions on the opposite face. After at least 96 hours had elapsed the samples were removed from the hot plate, allowed to cool to room temperature and weighed.

The sample was then transferred to the vibration fixture, comprised of 6 equally spaced rods on which the sample was impaled. The sample was held horizontally on the vibration table for 6 hours, being vibrated at a frequency of 12 Hz, with a displacement of 3 mm (peak to peak). Vibration was conducted in an ambient lab environment. The sample was then carefully removed from the table and a final weight taken.

### Appendix K ASTM C 592-04 – HEAT AND VIBRATION AGING

Bodycote Testing Group

Evaluation of the Effect of Heat and Vibration Aging on Thermal Insulation  
for Aspen Aerogels Inc.

Page 3 of 3  
Report No. 08-06-M0171, Revision 2

#### 3.0 RESULTS

Table 1 – Heat & Vibration Aging of Thermal Insulating Material ASTM C 592 §11.11 Modified Bodycote Sample No. 08-06-M0171-A (Pyrogel XT)	
Change in Mass after Vibration (heat aged sample)	Observations
- 0.19 %	Blackening around edges of sample on mid thickness plies.


Initial mass of specimen 3523.0 g  
Specimen mass after 96 hrs at 400°C 3449.6 g  
Specimen mass after 96 hrs at 400°C and 6 hours vibration 3442.9 g


Table 2 – Heat & Vibration Aging of Thermal Insulating Material ASTM C 592 §11.11 Modified Bodycote Sample No. 08-06-M0171-B (Mineral Wool)	
Change in Mass after Vibration (heat aged sample)	Observations
- 0.51 %	No change observed.

Initial mass of specimen 3211.0 g  
Specimen mass after 96 hrs at 400°C 3215.4 g  
Specimen mass after 96 hrs at 400°C and 6 hours vibration 3199.0 g

Reported by:

Reviewed by:

  
David Beauchamp, B.Sc., Ext. 228  
Scientist, Building Performance Centre  
Product Testing Group

  
Franz C. Bauer, Ext. 403  
Manager, Building Performance Centre  
Product Testing Group

*This report refers only to the particular samples, units, material, instrument, or other subject used and referred to in it, and is limited by the tests and/or analyses performed. Similar articles may not be of like quality, and other testing and/or analysis programs might be desirable and might give different results.*

**Appendix L** BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

*classification report*

**Bodycote**

**Title:**  
CLASSIFICATION OF  
REACTION TO FIRE  
PERFORMANCE  
IN ACCORDANCE WITH  
EN 13501-1: 2007

**Notified Body No:**  
0833

**Product Name:**  
Pyrogel XT

**Report No:**  
180079

**Issue No:**  
2

**Prepared for:**  
Aspen Aerogels Inc.  
30 Forbes Road Building B  
Northborough  
MA 01532  
United States Of America

**Date:**  
20<sup>th</sup> January 2009

**business partner**  
**LABC**

 **warringtonfire**  
global safety  
TESTING



### Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Classification Report  
No. 180079  
Issue 2  
Page 2 of 5

#### 1. Introduction

This classification report defines the classification assigned to "Pyrogel XT", a batting insulation, in line with the procedures given in EN 13501-1:2007

#### 2. Details of classified product

##### 2.1 General

The product, "Pyrogel XT", a batting insulation, is deemed as being suitable for construction applications, excluding flooring and linear pipe thermal insulation in building and construction.

##### 2.2 Product description

The product, "Pyrogel XT", a batting insulation, is fully described below and in the test reports provided in support of classification listed in Clause 3.1.

General description		A batting insulation mounted onto a calcium silicate based substrate utilising screws
Batting	Product reference	"Pyrogel XT"
	Detailed description / composition details	Silica based aerogel insulation batting
	Name of manufacturer	Aspen Aerogels, Inc.
	Density	0.18 g/cm <sup>3</sup> (stated by sponsor) 0.19 g/cm <sup>3</sup> (Determined by <b>Bodycote warringtonfire</b> )
	Weight per unit area	896g/m <sup>2</sup> (Determined by <b>Bodycote warringtonfire</b> )
	Thickness	5-10mm (stated by sponsor) 4.73 - 9.86mm (determined by <b>Bodycote warringtonfire</b> )
	Colour	Beige
	Flame retardant details	See Note 1
Substrate	Product reference	"Promat – Brandschultzbauplatten; Promatect-H"
	Generic type	Calcium Silicate based board
	Name of manufacturer	Promat
	Thickness	12mm
	Density	870kg/m <sup>3</sup>
	Flame retardant details	The substrate is inherently flame retardant
Mounting and fixing details		The specimen was mechanically fixed to the calcium silicate substrate utilising 16mm long screws. The screws were located around the perimeter of each wall and were positioned in the corners and at approximately 350mm intervals.
Brief description of manufacturing process		Aspen Aerogels produces nanoporous insulating materials, the process involves casting of the aerogels into fibrous battings.

### Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Classification Report  
No. 180079  
Issue 2  
Page 3 of 5

Note 1 - The sponsor of the test has provided this information but at the specific request of the sponsor, these details have been omitted from the report and are instead held on the confidential file relating to this investigation.

#### 3. Test reports/extended application reports & test results in support of classification

##### 3.1 Test reports/extended application reports

Name of Laboratory	Name of sponsor	Test reports/extended application report Nos.	Test method / extended application rules & date
Bodycote warringtonfire	Aspen Aerogels Inc	WF 178244 WF 178245	EN 13823
Bodycote warringtonfire	Aspen Aerogels Inc	WF 178243	EN ISO 1716

##### 3.2 Test results

Test method & test number	Parameter	No. tests	Results	
			Continuous parameter - mean (m)	Compliance parameters
EN 13823	FIGRA <sub>0.2MJ</sub>	4	0	Compliant
	THR <sub>600s</sub>		0.49, 0.56, 0.13, 0.37	Compliant
	LSF		No	Compliant
	SMOGRA		0, 0, 0, 0	Compliant
	TSP <sub>60Cs</sub>		42, 36, 36, 34	Compliant
EN ISO 1716	PCS ≤ 2,0 MJ/kg (1) PCS ≤ 2,0 MJ/kg (2)(2a) PCS ≤ 1,4 MJ/m <sup>2</sup> (3) PCS ≤ 2,0 MJ/kg (4)	3	2.1 MJ/kg	Compliant
	Total			



### Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Classification Report  
No. 180079  
Issue 2  
Page 4 of 5

#### 4. Classification and field of application

##### 4.1 Reference of classification

This classification has been carried out in accordance with clause 8 of EN 13501-1:2007

##### 4.2 Classification

The product, "Pyrogel XT", a batting insulation, in relation to its reaction to fire behaviour is classified:

**Reaction to fire classification: A2-s1,d0**

##### 4.3 Field of application

This classification is valid for the following end use applications:

- i) Construction applications, excluding flooring and linear pipe thermal insulation in building and construction.
- ii) As a suspended ceiling membrane.

This classification is also valid for the following product parameters:

Product thickness	5-10mm
Product density	No variation allowed
Product colour	No variation allowed
Product composition	No variation allowed
Product construction	No variation allowed

The classification is valid for the following substrates and airgaps:

Directly against an A1 or A2 substrate with a density of 615 kg/m<sup>3</sup> and greater

**Appendix L** BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Classification Report  
No. 180079  
Issue 2  
Page 5 of 5

**5. Limitations**

This classification report does not represent type approval or certification of the product.

**SIGNED**

*L.S. Hill*

.....  
**Leigh Hill**  
Technical Consultant  
Technical Department

**APPROVED**

*Janet Murrell*


.....  
**Janet Murrell**  
Technical Manager  
Technical Department  
on behalf of:  
**Bodycote warringtonfire**

This copy has been produced from a .pdf format electronic file that has been provided by Bodycote **warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Bodycote **warringtonfire**. The original signed paper version of this report is the sole authentic version. Only original paper versions of this report bear authentic signatures of the responsible Bodycote **warringtonfire** staff.

**Appendix L** BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE





**Appendix L** BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE



Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178243 (Issue 2)  
Page 3 of 8

CONTENTS	PAGE NO.
TEST DETAILS.....	4
DESCRIPTION OF TEST SPECIMENS .....	5
TEST RESULTS .....	6
SIGNATORIES.....	7
Table 1 .....	8





#### Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178243 (Issue 2)  
Page 4 of 8

#### Test Details

<b>Purpose of test</b>	<p>To determine the calorific potential of a building material during combustion when it is tested in accordance with the test specified in BS EN ISO 1716:2002 "Reaction To Fire Tests For Building Products – Determination Of The Heat Of Combustion".</p> <p>The test was performed in accordance with the procedure specified in BS EN ISO 1716:2002 and this test report should be read in conjunction with that European Standard.</p>
<b>Scope of test</b>	<p>BS EN ISO 1716 specifies a method of test for determining the heat of combustion of building materials at constant volume in a bomb calorimeter. Results are reported as individual values which may be interpreted by reference to other documents; e.g. EN 13501-1:2002 "Fire Classification of Construction Products and Building Elements Part 1 Classification using Test Data from Reaction to Fire Tests.</p> <p>The test is intended for materials or products whether composite products or coated products.</p>
<b>Fire test study group/EGOLF</b>	<p>Certain aspects of some fire test specifications are open to different interpretations. The Fire Test Study Group and EGOLF have identified a number of such areas and has agreed Resolutions which define common agreement of interpretations between fire test laboratories which are members of the Groups. Where such Resolutions are applicable to this test they have been followed.</p>
<b>Instruction to test</b>	<p>The test was conducted on the 17<sup>th</sup> December 2008 at the request of Aspen Aerogels Inc., the sponsor of the test.</p>
<b>Provision of test specimens</b>	<p>The specimens were supplied by the sponsor of the test. <b>Bodycote warringtonfire</b> was not involved in any selection or sampling procedure.</p>
<b>Conditioning of specimens</b>	<p>The specimens were received on the 10<sup>th</sup> November 2008. Prior to test the prepared specimens were conditioned for at least 48 hours at a temperature of <math>23 \pm 2^{\circ}\text{C}</math> and a relative humidity of <math>55 \pm 5\%</math>, in accordance with BS EN 13238:2001</p>
<b>Test procedure</b>	<p>The specimens were tested using an additional combustible substance of known and high calorific value which for this test was paraffin oil. The specimens were tested using the crucible method in an isoperibol bomb calorimeter.</p> <p>The water equivalent (E) of the bomb calorimeter was 0.01012 MJ/K</p>

### Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178243 (Issue 2)  
Page 5 of 8

#### Description of Test Specimens

The description of the specimens given below has been prepared from information provided by the sponsor of the test. All values quoted are nominal, unless tolerances are given.

General description	Insulation
Product reference	"Pyrogel XT"
Detailed description / composition details	Silica based aerogel insulation batting
Name of manufacturer	Aspen Aerogels, Inc.
Density	0.18 g/cm <sup>3</sup> (stated by sponsor)
Weight per unit area	896g/m <sup>2</sup> (Determined by <b>Bodycote warringtonfire</b> )
Thickness	5mm (stated by sponsor) 4.7mm (determined by <b>Bodycote warringtonfire</b> )
Colour	Beige
Flame retardant details	<b>See Note 1</b>
Brief description of manufacturing process	Aspen Aerogels produces nanoporous insulating materials, the process involves casting of the aerogels into fibrous battings.

**Note 1:** The sponsor of the test has provided this information but at the specific request of the sponsor, these details have been omitted from the report and are instead held on the confidential file relating to this investigation.

#### Specimen preparation

The specimens were homogeneous and were prepared by selecting portions of the material from the sample submitted for test to give a total mass of 50g. These were then ground and reduced to a fine powder prior to conditioning for test.

**Appendix L** BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178243 (Issue 2)  
Page 6 of 8

## Test Results

### Results of test

The results are detailed in Table 1.

The test results relate only to the specimens of the product in the form in which they were tested. Small differences in the composition of the product may significantly affect the performance during the test and may therefore invalidate the test results. Care should be taken to ensure that any product which is supplied or used is fully represented by the specimens which were tested.

The test results relate to the behaviour of the test specimen of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use.

For the product tested, the following results relating to the gross calorific potential were obtained.

Gross Calorific Value per Unit Mass MJ/Kg	Gross Calorific Value per Unit Area MJ/m <sup>2</sup>
<b>2.0789</b>	--

### Validity


The specification and interpretation of fire test methods are the subject of ongoing development and refinement. Changes in associated legislation may also occur. For these reasons it is recommended that the relevance of test reports over five years old should be considered by the user. The laboratory that issued the report will be able to offer, on behalf of the legal owner, a review of the procedures adopted for a particular test to ensure that they are consistent with current practices, and if required may endorse the test report.


This report may only be reproduced in full. Extracts or abridgements shall not be published without permission of **Bodycote warringtonfire**.

### Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178243 (Issue 2)  
Page 7 of 8

#### Signatories

  
 Responsible Officer  
 D. J. Owen \*

  
 Approved  
 M. Dale \*  
 Deputy Operations Manager

  
 Authorised  
 C. Dean \*  
 Operations Manager

\* For and on behalf of **Bodycote warringtonfire**.

Report Issued: 12<sup>th</sup> January 2009

Issue 2: 21<sup>st</sup> January 2009

This version of the report has been produced from a .pdf format electronic file that has been provided by **Bodycote warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **Bodycote warringtonfire**.



## Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178243 (Issue 2)  
Page 8 of 8

**Table 1**

**Bomb Calorimeter Calculations**

The insulation specimen (product reference "Pytugel XT 5"), is homogeneous

**End use thickness of specimen:-**                      5 mm  
**0.005 m**

**Gross Calorific Potensial Per Unit Mass**

<b>Test 1:-</b>	sample weight =	0.5356 g		
	calorific value =	2.03421 MJ/kg	=	2034.21 kJ/kg
	temperature rise =	1.5586 °C		
<b>Test 2:-</b>	sample weight =	0.5625 g		
	calorific value =	2.11392 MJ/kg	=	2113.92 kJ/kg
	temperature rise =	1.5776 °C		
<b>Test 3:-</b>	sample weight =	0.5995 g		
	calorific value =	2.08854 MJ/kg	=	2088.54 kJ/kg
	temperature rise =	1.6121 °C		
	Average =	2078.8900 kJ/kg		
		<b><u>2.0789 MJ/kg</u></b>		


Bodycote



### Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE





**Appendix L** BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE



Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178244  
Page 3 of 15

CONTENTS	PAGE NO.
TEST DETAILS.....	4
DESCRIPTION OF TEST SPECIMENS .....	5
TEST RESULTS .....	7
SIGNATORIES.....	9
Annex 1:.....	10



### Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178244  
Page 4 of 15

#### Test Details

<b>Purpose of test</b>	To provide data which, in conjunction with data from other test methods, will enable building products excluding floorings, to be classified in accordance with the Classification requirements specified in BS EN 13501-1: 2007. The test was performed in accordance with the procedure specified in BS EN 13823: 2002 and this report should be read in conjunction with that standard.
<b>Scope of test</b>	To determine the reaction-to-fire performance of construction products, excluding floorings and excluding products which are indicated in the EC Decision 2000/147/EC, when exposed to thermal attack by a single burning item (SBI) utilising the test procedures defined in BS EN 13823: 2002. There were no deviations from the defined procedures.
<b>Fire test study group/EGOLF</b>	Certain aspects of some fire test specifications are open to different interpretations. The Fire Test Study Group and EGOLF have identified a number of such areas and has agreed Resolutions which define common agreement of interpretations between fire test laboratories which are members of the Groups. Where such Resolutions are applicable to this test they have been followed.
<b>Instruction to test</b>	The test was conducted on the 16 <sup>th</sup> and the 18 <sup>th</sup> of December 2008 at the request of Aspen Aerogels, the sponsor of the test.
<b>Provision of test specimens</b>	The specimens of batting were supplied by the sponsor of the test. <b>Bodycote warringtonfire</b> was not involved in any selection or sampling procedure. <b>Bodycote warringtonfire</b> supplied the substrate and attached the batting onto the substrate.
<b>Conditioning of specimens</b>	The specimens were received on the 10 <sup>th</sup> November 2008 and were conditioned to constant mass at a temperature of 23 ± 2°C and a relative humidity of 50 ± 5% prior to testing.
<b>Intended application</b>	Thermal Insulation
<b>Test facility</b>	The SBI test facility at <b>Bodycote warringtonfire</b> is constructed in accordance with the specifications detailed in BS EN 13823: 2002.
<b>Exposed face</b>	The batting face of the specimens was exposed to the heating conditions of the test when the specimens were mounted in the test position.



**Appendix L** BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178244  
Page 5 of 15

### Description of Test Specimens

**Test specimens** The description of the specimens given below has been prepared from information provided by the sponsor of the test. All values quoted are nominal, unless tolerances are given.

The test specimen comprised two walls (or wings) mounted into an aperture in a specimen trolley such that they formed a vertical 90° corner. The dimensions of the walls were as follows:

Short wall	-	495 ± 5 mm long x 1500 ± 5 mm high
Long wall	-	1000 ± 5 mm long x 1500 ± 5 mm high

Each wall (or wing) consisted of the following product:

General description		A batting insulation mounted onto a calcium silicate based substrate utilising screws
Batting	Product reference	"Pyrogel XT"
	Detailed description / composition details	Silica based aerogel insulation batting
	Name of manufacturer	Aspen Aerogels, Inc.
	Density	0.18 g/cm <sup>3</sup> (stated by sponsor) 0.19 g/cm <sup>3</sup> (Determined by <b>Bodycote warringtonfire</b> )
	Weight per unit area	896g/m <sup>2</sup> (Determined by <b>Bodycote warringtonfire</b> )
	Thickness	5mm (stated by sponsor) 4.73mm (determined by <b>Bodycote warringtonfire</b> )
	Colour	Beige
Substrate	Flame retardant details	<b>See Note 1</b>
	Product reference	"Promat – Brandschutzbauplatten; Promatect-H"
	Generic type	Calcium Silicate based board
	Name of manufacturer	Promat
	Thickness	12mm
Mounting and fixing details	Density	870kg/m <sup>3</sup>
	Flame retardant details	The substrate is inherently flame retardant
	Brief description of manufacturing process	The specimen was mechanically fixed to the calcium silicate substrate utilising 16mm long screws. The screws were located around the perimeter of each wall and were positioned in the corners and at approximately 350mm intervals.

**Note 1 – The sponsor provided this information but at the specific request of the sponsor, this information has been omitted from the test report and is instead held on our confidential file relating to this investigation.**



**Appendix L** BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178244  
Page 6 of 15

The specimen walls (or wings) were placed in the trolley in accordance with the requirements of section 5.3 of the Standard.

Photographs of the installed product are appended as Plates 1 and 2 of this report.

Each wing was retained in the trolley using mechanical clamps which pushed the wing against a lip at the top and bottom of the aperture in the trolley.

The trolley incorporated a triangular propane sand burner of side length 250mm, which was positioned in the base of the corner formed by the two wings of the test specimen, with a horizontal separation of 40mm between the edge of the burner and the lower edges of the wings. The burner is referred to as the primary burner and has an output of 30kW. A secondary propane sand burner was attached to the fixed frame, beneath the hood but at the furthest possible distance from the specimen when the trolley was in place. The purpose of this burner is to obtain base line data without affecting the assembled specimen. The trolley incorporated a grill in its base and this was the sole source of ventilation for the test enclosure whilst the test was in progress. A plan view of the SBI apparatus is shown in Figure 1. A schematic illustration of the specimen housing and the exhaust system is shown in Figure 2.

### Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178244  
Page 7 of 15

#### Test Results

##### Results and observations

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

The test results relate only to the specimens of the product in the form in which they were tested. Small differences in the composition or thickness of the product may significantly affect the performance during the test and may therefore invalidate the test results. Care should be taken to ensure that any product which is supplied or used is fully represented by the specimens which were tested.

Observations made during the test and comments on any difficulties encountered during the test are given in Table 1.

A total of three specimens were tested. The following data, relevant to Euroclassification of Building Products was obtained:

Parameter	Result			
	Specimen 1	Specimen 2	Specimen 3	Mean
FIGRA (W/s) ( <i>THR(t) threshold of 0.2MJ</i> )	0.00	0.00	0.00	0.00
FIGRA (W/s) ( <i>THR(t) threshold of 0.4MJ</i> )	0.00	0.00	0.00	0.00
THR 600s (MJ)	0.49	0.56	0.13	0.40
SMOGRA (m <sup>2</sup> /s <sup>2</sup> )	0.00	0.00	0.00	0.00
TSP 600s (m <sup>2</sup> )	42.03	36.39	35.71	38.04
Lateral Flame Spread to End of Specimen?	None	None	None	-
Fall of Flaming Drop/Particle?	None	None	None	-
Flaming of Fallen Particle Exceeding 10s?	None	None	None	-

Curves of time averaged rate of heat release contribution of the specimen (HRRav(t)), cumulative heat release (THR(t)), and Fire Growth Rate (FIGRA) are appended as figures 3 to 5. Curves of time averaged rate of smoke production (SPRav(t)), cumulative smoke production (TSP(t)) and smoke growth rate (SMOGRA) are appended as figures 6 to 8.

Interpretation of the test results given above in the context of Euroclassification of building products should be carried out using BS EN 13501 – 1: 2007.

**Appendix L** BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178244  
Page 8 of 15

**Table 1**

Time		Observation
min	Sec	
05	12	In the case of all three specimens, discolouration of the surface of the product occurred.
06	00	In the case of all three specimens, flaming in the region of the burner began to occur.
26	00	End of test conditions. In the case of all three specimens, all flaming ceased.

Note: Impingement of the burner flame onto the specimen commenced at 5 minutes.

**Validity**


The specification and interpretation of fire test methods are the subject of ongoing development and refinement. Changes in associated legislation may also occur. For these reasons it is recommended that the relevance of test reports over five years old should be considered by the user. The laboratory that issued the report will be able to offer, on behalf of the legal owner, a review of the procedures adopted for a particular test to ensure that they are consistent with current practices, and if required may endorse the test report.


This report may only be reproduced in full. Extracts or abridgements shall not be published without permission of **Bodycote warringtonfire**.


### Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178244  
Page 9 of 15

#### Signatories

  
Responsible Officer  
K Hughes \*

  
Approved  
M. Dale \*  
Deputy Operations Manager

  
Authorised  
C. Dean \*  
Operations Manager

\* For and on behalf of **Bodycote warringtonfire**.

Report Issued: 16<sup>th</sup> January 2009

This version of the report has been produced from a .pdf format electronic file that has been provided by **Bodycote warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **Bodycote warringtonfire**.



### Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178244  
Page 10 of 15

#### Annex 1: Test apparatus and installation Figures and Plates




Plate 1: Total View of the exposed surface of the long wing.




Plate 2: Close up view of the vertical outer edge of the long wing at a height of 500mm



**Appendix L** BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE



**Appendix L** BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE



Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

Annex 2: Graphs

WF Report No. 178244  
Page 13 of 15

Figure 3.  $HRR_{av}(t)$  (kW)





Figure 4.  $THR(t)$  (MJ)



Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178244  
Page 14 of 15

Figure 5. FIGRA





Figure 6.  $SPR_{av}(t)$  ( $m^2/s$ )



Appendix L BS EN 13501-1:2007 – REACTION TO FIRE PERFORMANCE

WF Report No. 178244  
Page 15 of 15

Figure 7. TSP(t) (m<sup>2</sup>)




Figure 8. SMOGRA Graph.

